

PORTSMOUTH PEASE, NH, USA

WMO: 726055

Lat: 43.083N

Lon: 70.817W

Elev: 31

StdP: 100.96

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 04743

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.7	-13.7	-24.0	0.4	-13.8	-21.6	0.5	-11.6	12.0	-3.8	11.1	-5.1	4.9	290	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	32.0	22.6	30.1	21.8	28.4	21.0	24.1	29.5	23.1	27.8	22.3	26.6	4.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	17.2	26.5	21.8	16.5	25.7	21.0	15.7	24.8	72.5	29.7	68.8	27.8	65.7	26.4	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.0	8.0	DB	-20.3	34.7	2.7	1.4	-22.2	35.7	-23.8	36.5	-25.4	37.3	-27.3	38.3	(4)
(5)			WB	-20.8	25.8	2.6	0.8	-22.7	26.4	-24.2	26.8	-25.6	27.3	-27.5	27.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.5	-3.8	-2.0	1.9	8.0	13.4	18.7	22.1	21.4	17.3	11.0	5.2	-0.1	(6)	
	DBStd	9.88	5.77	5.28	4.98	4.30	4.03	3.89	2.98	2.85	3.78	4.01	4.57	4.90	(7)	
	HDD10.0	1624	428	337	258	87	9	0	0	0	1	36	156	313	(8)	
	HDD18.3	3550	686	571	511	311	163	42	4	6	63	229	396	571	(9)	
	CDD10.0	1440	0	1	6	27	116	262	375	354	220	67	11	1	(10)	
	CDD18.3	322	0	0	1	2	11	53	121	102	32	2	0	0	(11)	
	CDH23.3	2569	0	0	8	31	138	456	955	740	225	18	0	0	(12)	
	CDH26.7	786	0	0	2	8	43	138	317	217	59	1	0	0	(13)	
(14) Wind	WSAvg	3.6	4.2	4.2	4.3	4.2	3.6	3.2	3.0	2.9	3.0	3.5	3.7	3.9	(14)	
(15) Precipitation	PrecAvg	1171	84	81	107	101	93	102	93	88	99	119	98	105	(15)	
	PrecMax	1673	165	213	388	260	386	315	218	270	263	357	194	162	(16)	
	PrecMin	857	16	33	20	10	17	29	24	6	33	8	31	33	(17)	
	PrecStd	217	29	38	70	57	70	63	50	52	56	83	39	31	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.5	14.2	22.6	27.5	31.0	32.8	34.0	33.2	31.7	25.9	20.2	15.6	(19)	
		MCWB	11.9	10.6	14.2	16.2	20.0	23.1	24.1	23.5	22.3	18.2	15.5	11.2	(20)	
	2%	DB	9.1	10.2	15.8	22.2	27.3	30.3	32.0	31.0	28.0	22.4	17.1	11.7	(21)	
		MCWB	7.2	6.4	10.6	14.1	17.9	21.8	23.0	22.8	20.9	16.9	13.2	9.3	(22)	
	5%	DB	6.3	7.5	11.3	18.2	23.9	27.9	30.1	29.0	26.0	19.8	14.6	9.3	(23)	
		MCWB	4.1	4.4	6.9	11.6	16.3	20.3	22.1	21.5	19.5	15.4	11.2	7.4	(24)	
	10%	DB	3.8	5.1	8.6	15.2	21.0	26.0	28.2	27.4	23.7	17.4	12.3	7.1	(25)	
		MCWB	1.8	2.4	4.9	9.4	14.8	19.1	21.2	20.7	18.8	13.7	9.6	4.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.3	11.6	15.1	17.9	21.6	24.6	25.6	24.8	23.8	20.4	16.5	12.6	(27)	
		MCDB	13.5	13.0	21.6	23.9	28.6	30.3	31.7	30.7	28.7	22.8	19.0	14.5	(28)	
	2%	WB	7.7	7.5	11.3	15.5	19.5	23.2	24.3	23.7	22.3	18.0	14.3	10.1	(29)	
		MCDB	8.5	9.6	15.2	21.1	24.8	28.6	29.9	28.7	26.3	20.7	16.0	11.1	(30)	
	5%	WB	4.5	4.7	7.6	12.7	17.5	21.9	23.3	22.8	21.2	16.2	11.9	7.6	(31)	
		MCDB	6.0	6.9	10.3	17.2	22.1	26.0	28.1	27.0	24.2	18.8	13.6	8.8	(32)	
	10%	WB	1.9	2.9	5.4	10.2	15.5	20.5	22.3	21.9	19.9	14.6	9.9	5.1	(33)	
		MCDB	3.5	4.8	8.1	14.3	19.8	24.1	26.5	25.9	22.6	16.8	12.0	6.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	9.0	8.8	10.1	10.1	10.1	10.0	10.2	10.1	9.6	8.6	8.0	(35)	
		MCDBR	10.3	11.3	12.9	15.5	15.3	13.0	12.4	12.2	12.5	12.8	11.5	10.7	(36)	
	5% WB	MCWBR	9.3	8.4	8.5	9.0	7.8	6.3	5.4	5.4	6.3	7.8	8.5	9.0	(37)	
		MCWBR	10.3	10.5	12.2	13.8	13.3	11.9	10.8	10.3	10.4	10.7	9.8	10.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.286	0.296	0.319	0.357	0.394	0.441	0.459	0.426	0.374	0.332	0.311	0.291	(40)	
		taud	2.487	2.477	2.486	2.423	2.359	2.260	2.215	2.295	2.424	2.540	2.558	2.550	(41)	
	Ebn at Noon		861	911	928	910	880	836	815	831	855	857	826	825	(42)	
		Edh at Noon	71	85	95	110	121	134	139	124	101	80	67	62	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.71	2.58	3.64	4.62	5.15	5.54	5.83	5.29	4.25	2.76	1.84	1.38	(44)	
	RadStd		0.11	0.20	0.23	0.50	0.58	0.49	0.38	0.25	0.26	0.25	0.16	0.15	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	-1.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (75 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+83	+33	(47)

Nomenclature: See separate page