

SANFORD, ME, USA

WMO: 726064

Lat: 43.394N

Lon: 70.708W

Elev: 74

StdP: 100.43

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 64709

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.1	-17.6	-27.8	0.3	-17.5	-24.6	0.4	-16.1	11.3	-4.7	10.3	-4.9	1.6	240	0.532

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	32.1	22.4	29.9	21.6	28.0	20.3	23.9	29.3	22.8	27.9	21.7	26.5	3.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	17.0	27.0	21.2	16.0	25.7	20.0	14.8	24.5	71.6	29.3	67.4	27.9	63.5	26.3	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.3	7.3	DB	-26.9	34.8	3.7	1.1	-29.6	35.7	-31.8	36.3	-33.8	37.0	-36.5	37.8	(4)
(5)			WB	-27.1	25.4	3.4	1.0	-29.5	26.1	-31.5	26.7	-33.4	27.3	-35.8	28.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.7	-5.8	-4.6	0.1	6.5	12.1	17.5	20.7	19.4	15.3	9.1	3.2	-2.2	(6)	
	DBStd	10.24	6.40	5.82	5.51	4.40	4.10	4.05	3.12	3.48	4.19	4.31	4.84	5.33	(7)	
	HDD10.0	2022	492	410	310	123	22	1	0	1	4	71	209	379	(8)	
	HDD18.3	4103	749	643	564	354	200	63	12	28	110	288	453	637	(9)	
	CDD10.0	1170	1	0	4	19	86	226	332	291	163	41	6	1	(10)	
	CDD18.3	211	0	0	0	1	6	39	86	61	18	1	0	0	(11)	
	CDH23.3	2358	0	0	8	28	134	441	901	639	191	16	0	0	(12)	
	CDH26.7	729	0	0	2	8	43	142	301	182	51	1	0	0	(13)	
(14) Wind	WSAvg	2.7	3.1	3.3	3.4	3.2	2.7	2.3	2.1	2.0	2.1	2.7	2.8	2.9	(14)	
(15) Precipitation	PrecAvg	1190	86	82	110	102	94	103	96	88	100	121	101	107	(15)	
	PrecMax	1637	168	215	388	250	372	319	193	287	268	375	199	171	(16)	
	PrecMin	880	14	30	22	7	18	28	30	7	36	9	34	35	(17)	
	PrecStd	216	30	38	71	57	69	61	47	54	57	83	38	32	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.8	12.7	22.4	27.3	31.5	32.9	33.6	32.9	31.2	26.0	19.1	14.1	(19)	
		MCWB	11.2	9.2	13.5	15.9	19.4	23.0	23.7	23.6	22.7	17.2	14.1	10.3	(20)	
	2%	DB	8.7	8.9	14.9	22.1	27.4	30.9	32.1	30.8	27.8	22.3	16.3	10.9	(21)	
		MCWB	6.7	5.3	9.3	13.3	17.3	21.5	22.8	22.4	20.4	15.8	12.7	8.5	(22)	
	5%	DB	6.0	6.4	11.1	17.7	23.8	27.8	29.9	28.6	25.8	19.0	13.8	7.8	(23)	
		MCWB	3.3	2.8	6.4	10.8	15.3	19.8	21.8	21.2	19.1	14.5	10.2	5.5	(24)	
	10%	DB	2.8	3.7	7.8	15.1	21.1	26.0	27.9	27.2	22.9	17.1	11.9	5.9	(25)	
		MCWB	0.7	1.0	4.1	8.7	14.0	18.2	20.6	20.0	17.7	12.7	8.5	3.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	9.8	14.5	17.7	20.8	24.2	25.3	25.1	23.6	19.6	15.7	12.0	(27)	
		MCDB	12.8	11.8	21.5	24.1	28.6	30.5	31.6	31.0	28.8	22.0	17.8	13.7	(28)	
	2%	WB	7.1	6.0	10.1	14.7	18.6	22.7	24.0	23.5	21.9	17.2	13.5	8.4	(29)	
		MCDB	8.1	8.4	14.3	20.4	24.3	28.7	29.5	28.3	26.5	20.3	15.8	9.7	(30)	
	5%	WB	3.4	3.3	6.7	11.9	16.7	21.2	22.9	22.2	20.5	15.2	11.0	5.9	(31)	
		MCDB	5.2	5.7	9.8	16.6	22.5	26.1	28.1	26.9	23.8	18.6	13.3	8.1	(32)	
	10%	WB	0.9	1.4	4.5	9.3	14.8	19.6	21.8	21.1	18.9	13.3	8.6	3.3	(33)	
		MCDB	2.6	3.5	7.8	14.2	19.9	24.1	26.7	25.3	22.1	16.2	10.9	5.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	11.6	11.0	12.5	12.7	12.3	12.6	13.4	13.3	12.5	10.8	10.2	(35)	
		MCDBR	11.3	13.4	15.3	17.9	18.4	15.5	14.8	15.4	15.6	15.9	13.6	12.0	(36)	
	5% WB	MCWBR	10.1	10.3	10.4	10.7	9.8	8.2	7.2	8.1	9.0	10.4	10.4	10.0	(37)	
		MCWBR	11.0	12.5	13.9	16.0	15.6	13.8	12.8	12.7	12.7	13.2	12.0	11.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.284	0.296	0.320	0.352	0.388	0.437	0.454	0.422	0.373	0.331	0.311	0.290	(40)	
	taud		2.468	2.443	2.463	2.423	2.363	2.252	2.213	2.293	2.412	2.530	2.545	2.533	(41)	
	Ebn at Noon		859	907	925	914	885	838	818	834	854	856	821	821	(42)	
	Edh at Noon		72	87	97	110	120	135	139	124	102	80	67	62	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.70	2.57	3.66	4.61	5.14	5.52	5.80	5.28	4.25	2.74	1.82	1.36	(44)	
	RadStd		0.11	0.19	0.23	0.49	0.58	0.47	0.39	0.27	0.24	0.25	0.16	0.15	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (63 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+81	+30

Nomenclature: See separate page