

HANCOCK COUNTY BAR HARBOR AP, ME, USA

WMO: 726077

Lat: 44.450N

Lon: 68.367W

Elev: 27

StdP: 101.00

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14616

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-18.9	-16.7	-27.5	0.3	-17.1	-23.9	0.4	-14.9	14.4	2.0	11.7	5.0	2.7	320	0.580

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	27.6	20.4	26.2	19.3	24.1	18.3	22.0	25.8	20.9	24.2	19.9	22.8	3.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.7	24.3	19.8	14.5	22.7	18.8	13.7	21.8	64.3	25.9	60.6	24.2	57.3	23.0	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.4	7.4	-21.8	31.1	3.1	1.8	-24.0	32.4	-25.8	33.5	-27.6	34.5	-29.8	35.8		
(5)			-22.4	23.7	2.8	0.9	-24.4	24.4	-26.0	24.9	-27.6	25.4	-29.6	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-5.7	-4.3	-0.2	5.4	10.8	15.5	19.2	18.8	15.0	9.2	3.5	-1.8
	DBStd	9.49	6.14	5.50	4.64	3.34	3.14	3.08	2.45	2.39	3.26	3.76	4.48	5.25
	HDD10.0	1999	488	400	318	141	26	1	0	0	2	60	198	366
	HDD18.3	4168	746	633	575	387	234	93	19	23	107	283	444	624
	CDD10.0	973	0	0	1	4	51	167	285	272	153	36	4	0
	CDD18.3	100	0	0	0	0	1	9	45	37	8	0	0	0
	CDH23.3	598	0	0	0	0	19	72	262	196	46	3	0	0
	CDH26.7	102	0	0	0	0	3	13	46	32	8	0	0	0
Wind	WSAvg	3.2	3.3	3.3	3.7	3.7	3.3	2.9	2.7	2.6	2.8	3.2	3.2	3.1
Precipitation	PrecAvg	1374	111	94	121	119	107	104	82	71	111	144	147	141
	PrecMax	1908	250	212	213	244	301	280	181	181	261	390	287	265
	PrecMin	726	9	33	28	7	23	40	25	14	28	34	68	56
	PrecStd	234	53	40	55	60	64	61	43	45	61	76	48	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	10.4	14.1	18.8	26.3	28.8	30.2	29.9	27.4	22.2	16.3	12.4
		MCWB	10.2	8.5	8.4	10.7	16.9	21.4	22.0	21.2	20.2	15.6	13.7	11.0
	2%	DB	7.8	7.4	10.7	15.0	22.0	25.9	27.7	27.3	24.1	18.5	14.0	10.2
		MCWB	6.6	5.3	6.3	8.5	15.0	18.0	20.6	20.5	18.5	14.9	12.1	9.2
	5%	DB	6.0	5.2	7.8	12.8	18.8	23.0	26.2	25.8	22.3	17.1	12.5	7.9
		MCWB	4.4	3.3	5.0	7.9	12.9	16.4	19.5	19.3	17.4	14.2	10.6	6.7
	10%	DB	3.0	3.6	6.2	11.3	17.0	21.9	24.2	23.8	20.9	15.2	11.1	6.3
		MCWB	1.5	1.8	3.3	7.2	11.6	16.3	18.8	18.4	16.9	12.6	9.4	4.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	8.6	10.3	12.9	18.8	22.2	23.4	23.5	22.2	18.1	14.7	11.7
		MCDB	10.5	9.0	13.2	15.8	24.0	27.3	27.9	27.6	26.0	18.8	15.8	12.1
	2%	WB	7.4	6.0	7.7	10.9	16.0	19.8	21.9	21.9	20.3	16.4	12.8	9.2
		MCDB	7.8	7.1	8.7	12.4	19.6	23.2	25.8	25.3	22.5	17.8	13.9	9.9
	5%	WB	4.4	3.7	5.6	9.1	14.0	18.3	21.0	20.8	18.8	14.8	11.2	7.5
		MCDB	5.8	5.0	7.6	11.6	17.6	21.5	24.5	23.7	20.8	16.6	12.2	7.9
	10%	WB	1.9	2.2	3.8	7.8	12.5	17.1	20.0	19.7	17.6	13.0	9.1	4.9
		MCDB	3.1	3.4	5.8	10.1	15.2	19.6	23.1	22.4	19.0	14.8	10.5	6.5
Mean Daily Temperature Range	5% DB	MDBR	8.9	9.1	8.4	8.8	9.3	9.3	9.5	9.7	9.4	8.6	7.7	8.2
		MCDBR	11.1	9.2	10.3	12.1	13.8	12.3	11.8	11.7	11.4	10.0	9.1	10.4
		MCWBR	11.2	8.0	7.5	7.4	7.5	6.6	6.0	6.1	6.8	7.2	8.2	10.1
	5% WB	MCDBR	11.2	9.0	9.3	9.8	11.3	10.2	9.9	9.5	9.3	8.9	8.2	10.4
		MCWBR	11.5	8.6	8.0	7.2	7.4	6.6	5.9	5.8	6.6	7.6	8.4	10.7
Clear-Sky Solar Irradiance	taub	0.289	0.300	0.323	0.352	0.376	0.416	0.430	0.404	0.362	0.332	0.314	0.295	
	taud	2.480	2.465	2.474	2.429	2.402	2.307	2.286	2.348	2.448	2.531	2.547	2.509	
	Ebn at Noon	842	896	917	911	894	856	838	848	862	847	807	798	
	Edh at Noon	69	84	95	108	115	127	128	117	97	79	66	62	
All-Sky Solar Radiation	RadAvg	1.60	2.46	3.65	4.53	5.18	5.62	5.85	5.22	4.22	2.70	1.66	1.25	
	RadStd	0.14	0.20	0.22	0.47	0.62	0.46	0.43	0.30	0.26	0.25	0.15	0.13	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page