

MORRISVILLE-STOWE, VT, USA

WMO: 726114

Lat: 44.534N

Lon: 72.614W

Elev: 223

StdP: 98.67

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 54771

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.6	-21.6	-28.8	0.3	-23.7	-26.0	0.4	-20.7	8.5	-6.9	7.5	-7.6	0.7	200	0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	30.2	21.3	28.6	20.5	27.3	19.7	22.9	27.7	21.9	26.6	21.0	25.2	2.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.3	16.4	25.1	20.4	15.4	24.3	19.2	14.4	23.3	68.5	27.8	64.9	26.7	61.8	25.5	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.4	6.3	5.4	-29.5	32.9	3.6	1.3	-32.1	33.9	-34.2	34.6	-36.2	35.4	-38.7	36.3		
			-29.8	24.7	3.4	1.1	-32.2	25.5	-34.2	26.1	-36.1	26.8	-38.6	27.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.5	-8.3	-6.7	-2.1	5.5	12.4	17.2	19.8	18.9	15.1	8.2	1.9	-4.4	(6)
(7)		DBStd	11.06	7.20	6.29	6.17	4.74	4.36	3.65	2.92	3.09	4.15	4.57	5.13	6.21	(7)
(8)		HDD10.0	2378	567	469	376	152	24	0	0	0	6	92	247	446	(8)
(9)		HDD18.3	4476	825	702	632	387	189	65	18	32	113	316	494	704	(9)
(10)		CDD10.0	1110	0	0	2	16	99	215	304	276	160	35	3	1	(10)
(11)		CDD18.3	166	0	0	0	1	6	29	63	49	17	1	0	0	(11)
(12)		CDH23.3	1707	0	0	3	21	117	340	611	436	173	7	0	0	(12)
(13)		CDH26.7	416	0	0	0	4	26	88	158	98	42	0	0	0	(13)
(14)	Wind	WSAvg	1.8	1.9	2.1	2.3	2.3	2.0	1.7	1.4	1.3	1.4	1.8	1.8	1.9	(14)
(15)	Precipitation	PrecAvg	1273	77	71	80	89	101	127	142	114	104	124	97	103	(15)
(16)		PrecMax	1478	138	128	129	226	182	261	248	260	216	237	143	210	(16)
(17)		PrecMin	1006	39	30	33	25	43	34	79	34	46	48	39	48	(17)
(18)		PrecStd	102	25	23	26	47	44	59	41	49	38	53	30	34	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.8	11.0	18.8	26.2	29.8	31.9	32.2	31.5	31.0	24.1	18.4	12.6	(19)
MCWB			7.8	6.4	12.5	15.7	18.9	21.8	23.2	22.5	21.4	17.0	13.8	8.5	(20)	
2%		DB	5.8	6.9	12.7	21.5	26.6	29.0	30.1	29.0	27.5	21.3	15.4	9.0	(21)	
		MCWB	3.8	3.4	7.3	12.7	16.4	20.3	21.8	21.0	20.0	15.3	11.8	6.9	(22)	
5%		DB	3.2	4.1	9.6	17.7	23.9	27.3	28.4	27.5	25.2	18.6	12.5	6.1	(23)	
		MCWB	1.5	1.7	5.3	10.6	15.4	19.4	20.7	20.3	18.7	13.9	9.0	4.0	(24)	
10%		DB	1.7	2.4	6.8	14.2	21.5	25.1	27.0	26.0	22.7	16.1	9.6	3.6	(25)	
		MCWB	0.4	0.5	3.4	8.5	14.4	18.0	20.0	19.5	17.7	12.6	6.8	1.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	7.8	13.1	17.1	20.7	23.2	24.6	23.7	22.6	18.8	14.7	9.8	(27)
MCDWB			9.7	9.8	18.7	24.0	26.2	28.7	30.1	28.7	27.6	21.8	17.2	12.3	(28)	
2%		WB	4.1	4.0	8.2	14.1	18.8	21.9	23.1	22.3	21.1	16.5	12.1	7.1	(29)	
		MCDWB	5.5	6.1	11.2	19.5	24.1	27.0	27.6	27.1	25.6	19.5	15.1	8.9	(30)	
5%		WB	1.9	2.2	5.7	11.6	17.2	20.7	22.0	21.4	19.8	14.6	9.5	4.3	(31)	
		MCDWB	3.0	4.0	9.2	16.1	21.3	25.2	26.5	25.6	24.0	18.0	11.9	5.9	(32)	
10%		WB	0.4	0.8	3.7	9.1	15.6	19.4	21.0	20.4	18.5	12.7	7.3	2.1	(33)	
		MCDWB	1.6	2.1	6.4	14.0	19.9	23.4	25.2	24.2	22.1	15.4	9.3	3.4	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.3	11.4	10.9	11.8	12.8	12.1	12.2	12.4	10.4	8.9	8.6	(35)	
MCDBR			10.4	12.6	14.7	19.1	18.0	15.5	14.1	13.8	15.1	14.6	13.6	9.7	(36)	
MCWBR			9.2	10.0	9.9	10.8	9.4	7.7	6.8	6.8	8.1	9.0	10.1	8.2	(37)	
5% WB		MCDBR	9.3	11.5	13.3	16.5	13.8	12.9	12.1	12.0	12.7	12.6	12.3	9.3	(38)	
		MCWBR	8.4	9.6	9.6	10.2	8.1	6.9	6.3	6.3	7.2	8.6	9.9	8.2	(39)	
																(39)
(40)	Clear-Sky Solar Irradiance	taub	0.270	0.284	0.323	0.351	0.372	0.424	0.436	0.408	0.365	0.330	0.306	0.277	(40)	
taud		2.375	2.315	2.341	2.387	2.389	2.240	2.215	2.284	2.401	2.504	2.497	2.426	(41)		
Ebn at Noon		858	907	912	911	898	848	831	843	856	848	810	813	(42)		
Edh at Noon		75	96	108	113	116	136	138	124	102	80	68	65	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1.40	2.25	3.36	4.21	4.95	5.40	5.50	4.96	3.98	2.32	1.44	1.02	(44)	
(45)		RadStd	0.17	0.24	0.22	0.52	0.54	0.48	0.42	0.24	0.30	0.25	0.19	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page