

MT WASHINGTON SUMMIT, NH, USA

WMO: 726130

Lat: 44.2702N

Lon: 71.3033W

Elev: 6272

StdP: 11.66

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14755

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-22.4	-16.9	-32.5	1.1	-8.9	-26.7	1.6	-4.2	95.7	-9.3	88.7	-4.2	71.9	300	1.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	62.5	56.2	59.4	54.7	57.3	53.6	59.0	60.3	57.0	58.3	55.2	56.4	19.0	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.7	93.4	59.5	56.7	86.7	57.5	54.9	81.1	55.8	29.0	60.3	27.5	58.2	26.1	56.5	64.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 83.3	77.3	70.6	DB	-29.8	66.7	5.2	2.2	-33.6	68.2	-36.6	69.5	-39.6	70.8	-43.4	72.4	(4)
(5)			WB	-29.9	62.2	5.2	2.2	-33.6	63.8	-36.7	65.1	-39.6	66.4	-43.4	68.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	7.0	7.4	13.8	23.8	36.3	45.6	49.9	48.5	42.9	31.3	21.0	11.9		
	DBStd	18.42	13.24	12.46	11.77	9.93	9.08	7.23	5.52	5.77	7.85	9.83	11.10	11.35		
	HDD50	8071	1334	1194	1122	788	431	166	70	97	236	581	870	1182		
	HDD65	13366	1799	1614	1587	1237	890	582	470	512	664	1044	1320	1647		
	CDD50	181	0	0	0	0	6	35	66	50	22	2	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	34.2	43.9	43.7	38.8	35.1	29.6	26.4	25.2	24.2	27.3	35.6	38.4	43.0		
	PrecAvg	97.2	7.4	7.9	8.7	7.6	7.7	7.9	7.6	8.1	7.9	7.3	10.0	8.9		
(15) Precipitation	PrecMax	130.2	18.2	25.6	16.0	15.2	19.3	20.0	15.5	20.7	18.8	13.8	19.6	18.0		
	PrecMin	60.1	1.3	1.0	2.7	2.2	2.4	2.4	3.7	3.5	3.1	2.5	3.2	3.1		
	PrecStd	17.7	3.8	5.1	3.7	3.3	4.0	3.3	2.8	3.2	2.8	2.5	4.0	4.4		
	PrecStd	17.7	3.8	5.1	3.7	3.3	4.0	3.3	2.8	3.2	2.8	2.5	4.0	4.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.7	39.0	46.4	53.7	58.8	64.2	64.5	63.8	63.1	55.1	46.0	40.2		
		MCWB	39.6	37.9	43.8	45.7	51.6	57.3	58.5	56.3	53.2	45.8	44.8	38.9		
	2%	DB	37.5	34.0	38.9	46.5	54.6	60.8	61.4	60.8	59.0	52.2	43.1	36.1		
		MCWB	37.0	32.0	36.3	42.3	49.8	55.3	57.6	55.8	51.2	46.8	40.6	34.2		
	5%	DB	32.3	29.8	35.6	42.8	51.9	57.4	59.2	57.6	55.3	48.5	40.6	32.3		
		MCWB	31.5	28.4	32.9	38.5	48.4	53.7	55.9	54.2	51.3	43.4	37.7	30.5		
	10%	DB	25.4	25.2	31.7	38.6	48.3	55.1	57.1	55.4	54.0	45.6	37.1	28.1		
		MCWB	23.6	22.4	29.6	36.2	45.3	51.8	54.6	53.0	49.9	41.8	34.2	26.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	41.2	38.8	44.8	48.0	54.5	60.3	61.9	60.2	57.5	53.8	45.9	39.4		
		MCDB	41.3	39.2	46.4	50.6	56.8	62.3	62.6	60.9	59.4	53.9	45.9	39.6		
	2%	WB	37.0	32.4	37.3	43.4	51.8	57.3	59.4	57.6	55.2	49.7	42.5	35.8		
		MCDB	37.3	33.0	37.9	45.6	53.3	58.7	60.4	58.9	56.4	50.2	42.6	36.0		
	5%	WB	31.8	28.2	33.8	39.4	49.2	55.2	57.2	55.7	53.9	45.8	39.1	31.7		
		MCDB	32.7	28.9	34.3	41.4	51.1	56.6	58.2	56.9	55.1	46.6	39.5	31.9		
	10%	WB	24.6	23.1	29.1	36.2	46.1	53.6	55.3	54.5	51.6	43.1	36.0	26.9		
		MCDB	25.7	25.0	30.4	38.1	47.4	55.0	56.2	55.6	52.9	44.6	36.7	27.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.9	14.1	13.0	12.1	10.9	10.0	9.1	9.2	9.7	10.3	11.5	14.0		
		MCDBR	16.3	16.0	14.9	14.9	12.1	11.6	11.2	10.5	10.2	11.5	12.1	16.8		
		MCWBR	16.0	15.7	15.0	12.5	9.7	10.3	9.6	10.1	10.9	11.5	12.7	16.7		
	5% WB	MCDBR	16.6	16.9	15.6	15.1	10.9	10.5	9.7	9.1	9.4	12.0	12.8	17.3		
		MCWBR	16.6	16.9	16.6	14.6	9.6	10.2	9.6	9.6	11.0	13.3	13.7	17.9		
(40) Clear-Sky Solar Irradiance	taub		0.208	0.219	0.242	0.265	0.282	0.311	0.317	0.300	0.277	0.256	0.241	0.217		
	taud		2.534	2.462	2.510	2.595	2.593	2.463	2.450	2.510	2.592	2.672	2.641	2.564		
	Ebn at Noon		308	319	322	319	314	303	300	303	305	302	292	293		
	Edh at Noon		20	26	29	29	30	35	35	31	26	21	18	18		
(44) All-Sky Solar Radiation	RadAvg		481	757	1124	1390	1567	1706	1742	1583	1290	786	502	371		
	RadStd		49	77	71	162	193	149	141	91	86	80	58	33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.19	N/A	+3.33	N/A	N/A	N/A	-443	-464	N/A	N/A
(47)	Regional (52 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+133	N/A

Nomenclature: See separate page