

MT WASHINGTON SUMMIT, NH, USA

WMO: 726130

Lat: 44.2702N

Lon: 71.3033W

Elev: 1912

StdP: 80.37

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14755

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -30.2	(c) -27.2	(d) -35.9	(e) 0.2	(f) -22.7	(g) -32.6	(h) 0.2	(i) -20.1	(j) 42.8	(k) -22.9	(l) 39.7	(m) -20.1	(n) 32.2	(o) 300	(p) 1.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.1	17.0	13.5	15.2	12.6	14.0	12.0	15.0	15.7	13.9	14.6	12.9	13.6	8.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.8	13.3	15.3	13.7	12.4	14.2	12.7	11.6	13.2	49.5	15.7	46.0	14.5	42.7	13.6	18.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
37.2	34.6	31.6	-34.3	19.3	2.9	1.2	-36.4	20.1	-38.1	20.9	-39.8	21.5	-41.9	22.4
			-34.4	16.8	2.9	1.2	-36.5	17.7	-38.2	18.4	-39.8	19.1	-41.9	20.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	-2.0	-13.9	-13.7	-10.1	-4.6	2.4	7.6	9.9	9.2	6.0	-0.4	-6.1	-11.2	
	DBStd	10.23	7.36	6.92	6.54	5.52	5.04	4.02	3.07	3.21	4.36	5.46	6.17	6.31	
	HDD10.0	4484	741	663	623	438	239	92	39	54	131	323	483	657	
	HDD18.3	7426	999	897	882	687	494	323	261	284	369	580	733	915	
	CDD10.0	101	0	0	0	0	3	19	37	28	12	1	0	0	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	15.3	19.6	19.5	17.3	15.7	13.2	11.8	11.3	10.8	12.2	15.9	17.2	19.2	
Precipitation	PrecAvg	2470	187	200	220	193	196	200	192	205	200	185	254	225	
	PrecMax	3306	462	649	406	386	490	507	394	526	478	351	497	456	
	PrecMin	1526	33	25	69	56	61	62	95	90	79	64	82	78	
	PrecStd	449	96	129	93	83	101	85	71	82	70	63	101	111	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.4	3.9	8.0	12.1	14.9	17.9	18.1	17.7	17.3	12.8	7.8	4.5	
		MCWB	4.2	3.3	6.6	7.6	10.9	14.1	14.7	13.5	11.8	7.7	7.1	3.8	
	2%	DB	3.1	1.1	3.8	8.0	12.6	16.0	16.4	16.0	15.0	11.2	6.2	2.3	
		MCWB	2.8	0.0	2.4	5.7	9.9	12.9	14.2	13.2	10.6	8.2	4.8	1.2	
	5%	DB	0.2	-1.2	2.0	6.0	11.1	14.1	15.1	14.2	13.0	9.2	4.8	0.2	
		MCWB	-0.3	-2.0	0.5	3.6	9.1	12.0	13.3	12.3	10.7	6.3	3.2	-0.8	
	10%	DB	-3.7	-3.8	-0.2	3.6	9.1	12.8	13.9	13.0	12.2	7.5	2.8	-2.1	
		MCWB	-4.7	-5.4	-1.3	2.3	7.4	11.0	12.5	11.7	10.0	5.4	1.2	-3.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.1	3.8	7.1	8.9	12.5	15.7	16.6	15.6	14.2	12.1	7.7	4.1
			MCDB	5.1	4.0	8.0	10.3	13.8	16.8	17.0	16.1	15.2	12.2	7.7	4.2
2%		WB	2.8	0.2	3.0	6.3	11.0	14.0	15.2	14.2	12.9	9.9	5.8	2.1	
		MCDB	2.9	0.6	3.3	7.5	11.8	14.8	15.8	14.9	13.6	10.1	5.9	2.2	
5%		WB	-0.1	-2.1	1.0	4.1	9.6	12.9	14.0	13.1	12.1	7.7	3.9	-0.2	
		MCDB	0.4	-1.7	1.3	5.2	10.6	13.7	14.6	13.8	12.8	8.1	4.2	0.0	
10%		WB	-4.1	-5.0	-1.6	2.4	7.8	12.0	12.9	12.5	10.9	6.2	2.2	-2.8	
		MCDB	-3.5	-3.9	-0.9	3.4	8.6	12.8	13.5	13.1	11.6	7.0	2.6	-2.4	
Mean Daily Temperature Range		5% DB	MDBR	8.3	7.8	7.2	6.7	6.0	5.6	5.1	5.1	5.4	5.7	6.4	7.8
			MCDBR	9.1	8.9	8.3	8.3	6.7	6.5	6.2	5.8	5.7	6.4	6.7	9.3
	MCWBR		8.9	8.7	8.4	7.0	5.4	5.7	5.4	5.6	6.1	6.4	7.0	9.3	
	5% WB	MCDBR	9.2	9.4	8.7	8.4	6.0	5.8	5.4	5.1	5.2	6.7	7.1	9.6	
		MCWBR	9.2	9.4	9.2	8.1	5.3	5.6	5.3	5.3	6.1	7.4	7.6	10.0	
Clear-Sky Solar Irradiance	taub	0.208	0.219	0.242	0.265	0.282	0.311	0.317	0.300	0.277	0.256	0.241	0.217		
	taud	2.534	2.462	2.510	2.595	2.593	2.463	2.450	2.510	2.592	2.672	2.641	2.564		
	Ebn at Noon	971	1005	1014	1006	989	955	945	954	960	951	919	925		
	Edh at Noon	63	82	90	91	95	109	109	99	83	67	57	56		
All-Sky Solar Radiation	RadAvg	1.52	2.39	3.54	4.38	4.94	5.38	5.49	4.99	4.07	2.48	1.58	1.17		
	RadStd	0.15	0.24	0.22	0.51	0.61	0.47	0.44	0.29	0.27	0.25	0.18	0.10		

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.66	N/A	+1.85	N/A	N/A	N/A	-246	-258	N/A
(47) Regional (52 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+74

Nomenclature: See separate page