

JAFFREY, NH, USA

WMO: 726163

Lat: 42.805N

Lon: 72.004W

Elev: 1040

StdP: 14.15

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 54770

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.5	1.9	-14.9	2.5	1.5	-10.2	3.3	6.2	18.6	29.6	16.9	26.8	3.8	180	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	87.3	70.3	84.1	68.7	81.5	67.2	73.4	81.2	72.0	79.3	70.5	77.3	7.4	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.5	121.1	77.0	70.0	114.7	75.4	68.2	107.6	74.2	37.6	81.8	36.3	78.9	35.1	76.6	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	13.6	12.0	-11.7	91.8	5.5	2.4	-15.7	93.5	-18.9	94.9	-22.0	96.2	-26.0	97.9
			-12.2	76.0	5.4	1.4	-16.1	77.0	-19.2	77.9	-22.2	78.7	-26.2	79.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.3	21.9	24.3	32.2	44.2	55.3	64.0	69.3	67.8	60.5	48.5	37.9	28.1
	DBStd	18.48	11.00	9.93	9.69	8.31	7.85	6.97	5.52	5.74	7.28	8.10	8.51	9.47
	HDD50	3580	871	719	558	215	33	1	0	0	5	127	371	680
	HDD65	7234	1335	1139	1017	627	316	101	21	37	173	512	812	1144
	CDD50	2224	0	0	7	39	197	420	597	550	320	82	10	2
	CDD65	402	0	0	0	1	16	70	153	122	38	2	0	0
	CDH74	3500	0	0	7	45	249	666	1314	933	275	11	0	0
	CDH80	906	0	0	1	11	61	185	366	222	60	0	0	0
	WSAvg	4.7	5.3	5.4	5.6	5.3	4.8	4.4	4.2	3.8	3.7	4.5	4.8	5.1
	PrecAvg	46.5	3.6	3.1	3.7	3.4	3.6	3.9	4.0	4.2	4.0	4.4	3.9	4.1
(15) Precipitation	PrecMax	60.0	6.2	10.4	8.1	7.9	6.7	9.8	8.8	9.4	10.1	13.2	6.7	7.7
	PrecMin	30.3	1.3	1.3	1.0	0.6	0.9	0.8	1.3	0.3	0.4	0.6	1.1	1.9
	PrecStd	7.5	1.3	1.7	1.7	1.8	1.5	2.1	1.8	2.2	2.2	2.9	1.2	1.4
	PrecStd	7.5	1.3	1.7	1.7	1.8	1.5	2.1	1.8	2.2	2.2	2.9	1.2	1.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	54.9	55.8	71.1	80.8	85.7	90.0	90.7	89.7	86.2	75.2	64.3	59.0	
	0.4% MCWB	53.1	48.9	56.1	60.3	64.5	70.8	73.3	72.3	71.3	61.8	57.9	54.9	
	2% DB	46.9	47.7	58.1	71.8	81.0	84.7	87.3	85.3	81.0	70.8	60.8	51.3	
	2% MCWB	43.1	41.5	48.5	55.2	62.6	68.4	70.9	70.0	67.2	62.1	55.1	48.2	
	5% DB	40.8	43.0	51.9	65.2	75.4	81.3	84.0	82.0	76.7	66.3	56.2	46.0	
	5% MCWB	37.3	37.3	43.8	52.7	60.5	66.7	69.3	68.4	65.9	59.7	51.4	42.6	
	10% DB	36.3	37.4	46.1	60.3	71.0	77.4	81.3	79.4	73.1	62.6	52.1	41.6	
	10% MCWB	33.1	33.2	40.1	48.7	57.9	64.1	67.8	66.8	64.3	56.4	47.5	38.2	
	0.4% WB	53.7	52.0	57.3	62.8	68.5	74.0	76.2	75.1	73.3	68.0	61.0	54.9	
	0.4% MCDB	54.4	54.1	68.0	73.6	79.9	82.9	85.8	83.6	79.9	71.3	63.7	57.2	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	44.1	43.3	51.1	58.9	66.1	71.8	73.7	72.9	70.9	64.3	56.4	48.9	
	2% MCDB	45.6	47.2	56.6	67.7	75.4	80.3	82.0	79.9	76.5	67.6	59.3	51.0	
	5% WB	37.7	37.4	44.6	54.6	63.5	69.9	72.0	71.4	68.9	60.5	52.6	43.6	
	5% MCDB	40.6	41.3	49.0	61.9	70.7	77.2	79.8	78.0	73.9	65.5	55.1	45.9	
	10% WB	33.4	34.3	40.5	50.3	60.6	67.5	70.5	69.9	66.5	57.1	48.0	38.3	
	10% MCDB	35.5	37.3	46.2	58.4	68.4	73.7	77.6	76.1	71.4	61.3	51.5	41.1	
(35) Mean Daily Temperature Range	MDBR	16.7	18.4	18.3	20.9	21.1	19.8	19.9	19.9	20.3	18.4	16.2	15.0	
	5% DB	19.3	22.6	26.4	30.9	29.0	24.9	22.7	21.8	23.1	23.3	21.6	19.5	
	5% WB	16.9	17.4	17.2	16.3	13.5	11.0	9.4	9.3	11.7	14.3	16.6	17.2	
	MCDBR	19.0	20.6	23.5	26.1	24.2	20.5	19.5	17.8	18.4	19.6	18.6	19.0	
	MCWBR	17.4	17.1	17.6	16.7	13.1	10.6	9.5	8.8	11.4	14.4	16.5	18.2	
	MCWBR	17.4	17.1	17.6	16.7	13.1	10.6	9.5	8.8	11.4	14.4	16.5	18.2	
(40) Clear-Sky Solar Irradiance	taub	0.275	0.284	0.312	0.351	0.383	0.420	0.441	0.410	0.362	0.322	0.296	0.276	
	taud	2.450	2.428	2.455	2.407	2.352	2.266	2.218	2.289	2.405	2.538	2.563	2.540	
	Ebn at Noon	278	293	297	291	283	271	264	268	275	276	269	269	
	Edh at Noon	23	28	31	36	39	42	44	40	33	25	21	20	
(44) All-Sky Solar Radiation	RadAvg	549	822	1158	1456	1610	1740	1832	1650	1338	857	591	442	
	RadStd	39	68	78	160	189	167	116	85	94	85	54	46	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (79 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page