

JAFFREY, NH, USA

WMO: 726163

Lat: 42.805N

Lon: 72.004W

Elev: 317

StdP: 97.57

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 54770

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.2	-16.7	-26.1	0.4	-17.0	-23.4	0.5	-14.3	8.3	-1.3	7.6	-2.9	1.7	180	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	30.7	21.3	28.9	20.4	27.5	19.6	23.0	27.3	22.2	26.3	21.4	25.2	3.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	17.3	25.0	21.1	16.4	24.1	20.1	15.4	23.5	69.5	27.7	66.5	26.0	63.7	24.8	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.1	5.4	DB	-24.3	33.2	3.1	1.3	-26.5	34.2	-28.3	34.9	-30.0	35.7	-32.2	36.6	(4)
(5)			WB	-24.5	24.5	3.0	0.8	-26.7	25.0	-28.5	25.5	-30.1	25.9	-32.3	26.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-5.6	-4.3	0.1	6.8	13.0	17.8	20.7	19.9	15.8	9.2	3.3	-2.2	(6)	
	DBStd	10.27	6.11	5.52	5.39	4.62	4.36	3.87	3.06	3.19	4.04	4.50	4.73	5.26	(7)	
	HDD10.0	1989	484	399	310	119	18	1	0	0	3	71	206	378	(8)	
	HDD18.3	4019	742	633	565	348	176	56	12	21	96	284	451	636	(9)	
	CDD10.0	1236	0	0	4	22	109	233	332	306	178	46	6	1	(10)	
	CDD18.3	223	0	0	0	1	9	39	85	68	21	1	0	0	(11)	
	CDH23.3	1944	0	0	4	25	138	370	730	518	153	6	0	0	(12)	
	CDH26.7	503	0	0	1	6	34	103	203	123	33	0	0	0	(13)	
(14) Wind	WSAvg	2.1	2.4	2.4	2.5	2.4	2.2	2.0	1.9	1.7	1.7	2.0	2.1	2.3	(14)	
(15) Precipitation	PrecAvg	1181	92	80	94	86	91	100	101	106	101	112	98	105	(15)	
	PrecMax	1523	158	265	205	200	169	250	224	240	257	335	171	196	(16)	
	PrecMin	770	32	33	26	16	22	21	33	8	10	16	29	47	(17)	
	PrecStd	191	32	43	43	46	37	54	46	56	56	73	30	35	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	13.2	21.7	27.1	29.8	32.2	32.6	32.0	30.1	24.0	17.9	15.0	(19)	
		MCWB	11.7	9.4	13.4	15.7	18.0	21.6	22.9	22.4	21.9	16.5	14.4	12.7	(20)	
	2%	DB	8.3	8.7	14.5	22.1	27.2	29.3	30.7	29.6	27.2	21.6	16.0	10.7	(21)	
		MCWB	6.1	5.3	9.2	12.9	17.0	20.2	21.6	21.1	19.6	16.7	12.8	9.0	(22)	
	5%	DB	4.9	6.1	11.0	18.4	24.1	27.4	28.9	27.8	24.8	19.1	13.4	7.8	(23)	
		MCWB	3.0	3.0	6.5	11.5	15.8	19.3	20.7	20.2	18.8	15.4	10.8	5.9	(24)	
	10%	DB	2.4	3.0	7.8	15.7	21.7	25.2	27.4	26.3	22.8	17.0	11.2	5.3	(25)	
		MCWB	0.6	0.7	4.5	9.3	14.4	17.8	19.9	19.3	18.0	13.6	8.6	3.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.0	11.1	14.1	17.1	20.3	23.3	24.6	23.9	23.0	20.0	16.1	12.7	(27)	
		MCDB	12.4	12.3	20.0	23.1	26.6	28.3	29.9	28.7	26.6	21.8	17.6	14.0	(28)	
	2%	WB	6.7	6.3	10.6	15.0	18.9	22.1	23.2	22.7	21.6	17.9	13.5	9.4	(29)	
		MCDB	7.6	8.4	13.7	19.8	24.1	26.9	27.8	26.6	24.7	19.8	15.1	10.6	(30)	
	5%	WB	3.2	3.0	7.0	12.5	17.5	21.0	22.2	21.9	20.5	15.8	11.4	6.4	(31)	
		MCDB	4.8	5.2	9.5	16.6	21.5	25.1	26.6	25.6	23.3	18.6	12.8	7.7	(32)	
	10%	WB	0.8	1.3	4.7	10.2	15.9	19.7	21.4	21.0	19.2	14.0	8.9	3.5	(33)	
		MCDB	1.9	2.9	7.9	14.7	20.2	23.2	25.3	24.5	21.9	16.3	10.8	5.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	10.2	10.2	11.6	11.7	11.0	11.1	11.1	11.3	10.2	9.0	8.3	(35)	
		MCDBR	10.7	12.6	14.6	17.2	16.1	13.9	12.6	12.1	12.8	12.9	12.0	10.8	(36)	
	5% WB	MCWBR	9.4	9.7	9.6	9.1	7.5	6.1	5.2	5.2	6.5	7.9	9.2	9.6	(37)	
		MCWBR	10.5	11.5	13.1	14.5	13.4	11.4	10.8	9.9	10.2	10.9	10.3	10.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.275	0.284	0.312	0.351	0.383	0.420	0.441	0.410	0.362	0.322	0.296	0.276	(40)	
		taud	2.450	2.428	2.455	2.407	2.352	2.266	2.218	2.289	2.405	2.538	2.563	2.540	(41)	
	Ebn at Noon		875	925	936	916	891	854	831	846	867	871	848	849	(42)	
		Edh at Noon	73	89	98	112	122	133	138	125	103	80	66	62	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.73	2.59	3.65	4.59	5.08	5.49	5.77	5.20	4.22	2.70	1.86	1.39	(44)	
	RadStd		0.12	0.21	0.24	0.50	0.60	0.53	0.37	0.27	0.29	0.27	0.17	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (79 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+90	+37

Nomenclature: See separate page