

KEENE DILLANT-HOPKINS, NH, USA

WMO: 726165

Lat: 42.900N

Lon: 72.267W

Elev: 481

StdP: 14.44

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 94721

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.7	0.6	-18.9	2.0	-1.5	-11.4	3.0	3.9	20.0	24.9	18.2	22.5	1.9	190	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.2	88.5	71.5	85.7	69.7	82.3	68.1	74.4	83.8	72.6	81.4	71.0	79.2	7.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.9	120.0	79.4	70.1	112.6	77.5	68.0	104.7	75.7	38.1	83.6	36.5	80.8	35.0	79.2	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	16.1	13.4	DB	-12.2	92.8	6.3	2.7	-16.7	94.7	-20.4	96.3	-23.9	97.8	-28.5	99.8	
			WB	-12.3	76.8	5.9	2.1	-16.5	78.3	-20.0	79.5	-23.3	80.7	-27.6	82.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.8	22.0	24.9	33.2	44.8	55.9	65.0	70.1	68.1	60.7	49.0	38.2	28.4
	DBStd	18.52	11.35	10.27	9.34	8.10	7.41	6.46	5.30	5.51	7.18	7.92	8.70	9.29
	HDD50	3480	869	703	527	198	23	0	0	0	4	118	367	671
	HDD65	7077	1333	1123	985	607	297	79	14	31	170	499	804	1135
	CDD50	2310	0	0	7	42	206	450	622	562	323	85	12	1
	CDD65	437	0	0	0	1	16	79	172	128	39	2	0	0
	CDH74	4320	0	0	10	45	308	837	1617	1126	355	22	0	0
	CDH80	1278	0	0	2	11	87	247	533	305	92	1	0	0
Wind	WSAvg	4.3	4.7	4.9	5.4	5.5	4.6	4.0	3.5	3.1	3.4	4.0	4.3	4.2
Precipitation	PrecAvg	39.5	2.9	2.4	3.0	3.3	3.8	3.5	3.7	3.7	3.5	3.5	3.5	3.2
	PrecMax	59.2	8.8	6.7	5.5	6.8	10.9	8.2	7.5	9.0	9.1	16.5	6.1	8.9
	PrecMin	26.8	0.7	0.1	0.7	0.8	1.1	0.5	1.0	0.3	0.3	0.8	1.3	0.7
	PrecStd	7.3	1.7	1.1	1.2	1.3	1.9	1.9	1.6	1.7	1.9	2.6	1.3	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.2	56.9	71.8	80.9	87.9	90.9	92.7	90.8	88.2	77.0	66.3	59.3
		MCWB	53.0	47.7	56.0	59.4	66.2	72.1	75.0	73.0	70.4	63.9	59.0	54.2
	2%	DB	45.8	48.2	59.3	72.4	81.9	86.3	89.1	86.5	81.9	72.0	62.8	50.2
		MCWB	41.1	41.4	48.9	55.6	63.6	69.4	72.9	71.2	67.9	62.1	56.2	45.7
	5%	DB	39.3	43.3	52.5	66.1	76.8	82.2	85.8	83.5	78.5	67.3	57.1	45.5
		MCWB	35.2	37.2	43.5	53.3	61.1	67.4	70.7	69.8	65.6	60.5	50.9	41.4
	10%	DB	36.5	38.6	46.4	61.3	72.1	79.2	82.2	81.0	73.4	63.1	53.4	41.0
		MCWB	33.3	33.6	39.9	48.5	58.2	64.7	68.7	67.7	63.5	56.0	47.7	36.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.5	50.7	57.6	63.9	69.8	75.2	77.6	76.1	73.2	68.2	61.9	54.3
		MCDB	55.1	54.1	66.5	72.8	81.9	86.1	88.8	85.5	82.9	72.4	64.8	56.9
	2%	WB	41.3	42.3	50.4	58.9	66.4	72.6	74.8	73.5	70.7	64.3	57.3	46.6
		MCDB	45.5	47.4	57.1	69.1	76.9	82.1	84.8	81.2	78.4	68.9	62.2	48.7
	5%	WB	36.9	37.7	44.9	54.5	63.6	70.3	73.0	71.8	68.3	60.4	52.6	41.9
		MCDB	39.3	42.6	51.0	63.1	73.4	78.4	82.1	80.4	75.0	66.0	56.2	45.3
	10%	WB	33.7	34.4	40.6	50.7	60.4	68.0	71.1	70.0	66.1	56.8	47.7	37.6
		MCDB	35.9	37.9	46.6	59.9	68.9	75.2	79.3	77.6	72.4	62.4	52.1	40.5
Mean Daily Temperature Range		MDBR	17.8	19.5	19.7	22.6	23.2	22.2	22.2	22.3	22.9	21.4	18.2	16.3
		MCDBR	18.7	23.8	28.8	33.4	32.8	27.6	26.2	25.4	26.8	27.6	24.3	20.3
		MCWBR	15.9	17.8	18.7	18.6	16.4	13.8	12.2	12.0	15.0	18.1	18.5	17.1
	5% WB	MCDBR	17.9	22.6	25.7	28.7	27.4	22.8	22.7	21.6	22.4	23.5	21.0	19.0
		MCWBR	16.0	17.8	18.4	17.9	15.2	12.5	11.7	11.2	13.6	17.1	18.2	17.4
Clear-Sky Solar Irradiance	taub	0.285	0.293	0.321	0.362	0.395	0.435	0.456	0.425	0.375	0.334	0.305	0.283	
	taud	2.423	2.398	2.427	2.380	2.328	2.236	2.187	2.260	2.382	2.512	2.545	2.515	
	Ebn at Noon	272	289	293	287	279	267	259	264	271	271	265	265	
	Edh at Noon	24	29	32	36	40	43	45	41	33	26	22	20	
All-Sky Solar Radiation	RadAvg	538	812	1158	1449	1607	1735	1820	1640	1332	845	580	429	
	RadStd	41	70	78	161	187	165	118	86	94	87	55	45	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	Regional (76 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+164	+68

Nomenclature: See separate page