

GREENVILLE, ME, USA

WMO: 726190

Lat: 45.462N

Lon: 69.595W

Elev: 427

StdP: 96.30

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 94626

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-23.8	-21.1	-30.8	0.2	-17.3	-27.9	0.3	-18.3	11.7	-12.6	10.5	-12.3	5.0	330	0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	28.2	19.9	26.7	19.0	25.0	18.0	21.5	25.9	20.5	24.5	19.6	23.1	2.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	15.6	23.1	19.1	14.6	22.3	18.2	13.8	21.6	64.5	25.9	61.0	24.8	57.8	22.9	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.9	8.4	7.4	DB	-27.2	31.4	3.6	1.1	-29.8	32.2	-31.9	32.9	-33.9	33.5	-36.6	34.3	(4)
(5)			WB	-27.5	23.2	3.5	0.9	-30.0	23.8	-32.1	24.3	-34.1	24.8	-36.6	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.4	-9.1	-8.3	-3.5	3.6	10.5	15.8	19.3	18.3	14.0	7.5	0.8	-5.4	(6)	
	DBStd	11.08	7.31	6.16	5.49	4.56	4.22	3.68	2.85	2.86	3.91	4.31	4.95	6.28	(7)	
	HDD10.0	2632	593	512	420	198	44	2	0	0	8	101	277	477	(8)	
	HDD18.3	4844	850	746	678	443	244	93	22	36	138	335	526	734	(9)	
	CDD10.0	945	1	0	1	6	61	177	288	256	129	24	1	1	(10)	
	CDD18.3	117	1	0	0	0	3	17	52	34	9	1	0	0	(11)	
	CDH23.3	749	4	2	0	3	43	139	303	194	60	2	0	0	(12)	
	CDH26.7	135	0	0	0	1	8	29	54	32	12	0	0	0	(13)	
(14) Wind	WSAvg	2.8	3.4	3.5	3.6	3.3	2.7	2.3	1.9	1.9	2.3	2.8	3.1	3.5	(14)	
(15) Precipitation	PrecAvg	1151	75	70	85	90	86	114	101	94	98	126	112	102	(15)	
	PrecMax	1649	134	139	160	191	131	219	184	212	242	288	219	215	(16)	
	PrecMin	682	13	34	34	13	30	40	28	16	38	27	47	43	(17)	
	PrecStd	204	32	25	32	50	29	51	41	48	45	68	39	49	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.7	21.1	14.7	21.6	27.7	29.8	30.1	29.4	28.2	22.5	15.2	14.0	(19)	
		MCWB	7.2	6.4	10.1	12.3	17.2	20.7	21.6	20.4	20.8	15.2	12.3	3.3	(20)	
	2%	DB	11.3	7.3	8.2	16.8	23.7	27.1	28.2	27.4	24.9	18.7	12.2	9.1	(21)	
		MCWB	3.8	3.8	3.7	9.2	14.8	19.0	20.2	19.5	18.6	13.9	9.2	3.5	(22)	
	5%	DB	5.4	2.7	5.7	13.4	20.7	24.6	26.5	25.7	22.5	16.2	9.8	5.8	(23)	
		MCWB	3.6	0.6	2.0	7.6	13.4	17.3	19.5	18.7	17.3	13.1	7.4	3.2	(24)	
	10%	DB	0.9	0.6	3.7	10.9	18.1	22.5	24.9	23.8	20.4	14.0	7.7	2.6	(25)	
		MCWB	-0.6	-1.1	0.8	6.5	11.6	16.3	18.5	17.9	16.5	11.3	5.0	1.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.3	7.2	10.7	13.9	18.9	22.1	23.3	22.1	21.5	17.3	13.5	7.6	(27)	
		MCDB	16.9	17.2	14.1	18.8	24.3	27.5	27.7	26.5	26.4	19.3	14.4	8.8	(28)	
	2%	WB	5.0	3.6	4.9	10.8	16.5	20.4	21.7	21.0	19.9	15.4	10.6	4.4	(29)	
		MCDB	9.6	8.0	6.7	13.8	21.8	24.9	25.8	24.9	23.2	17.6	11.3	6.6	(30)	
	5%	WB	2.1	1.0	2.6	8.7	14.7	19.0	20.7	20.0	18.6	13.6	7.9	2.5	(31)	
		MCDB	5.8	2.8	5.1	12.3	18.7	22.9	24.7	23.6	21.3	15.9	9.0	6.4	(32)	
	10%	WB	-0.4	-0.9	0.9	6.6	12.8	17.5	19.8	19.1	17.2	11.7	5.5	0.8	(33)	
		MCDB	1.0	0.6	3.1	10.4	16.7	20.8	23.2	22.4	19.5	13.7	7.1	3.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	9.7	8.7	9.0	9.9	9.5	9.1	9.2	9.2	7.4	6.6	7.1	(35)	
		MCDBR	20.0	15.3	10.7	13.6	14.4	13.1	11.3	11.5	11.6	11.1	9.4	10.6	(36)	
	5% WB	MCWBR	14.7	11.5	7.5	8.2	7.7	6.8	5.4	5.6	6.4	7.5	7.7	8.2	(37)	
		MCWBR	18.2	15.6	9.5	12.5	12.4	11.1	9.6	9.2	9.9	9.9	8.8	9.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.246	0.264	0.302	0.326	0.348	0.385	0.396	0.377	0.344	0.314	0.289	0.259	(40)	
		taud	2.417	2.344	2.350	2.440	2.445	2.326	2.310	2.368	2.455	2.544	2.550	2.454	(41)	
	Ebn at Noon		887	929	932	935	920	882	867	871	876	862	828	831	(42)	
		Edh at Noon	69	91	106	106	110	124	125	113	95	76	63	61	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.48	2.37	3.60	4.50	4.96	5.39	5.47	4.89	4.00	2.42	1.47	1.11	(44)	
	RadStd		0.17	0.26	0.28	0.46	0.61	0.39	0.47	0.29	0.27	0.22	0.15	0.10	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+54	N/A

Nomenclature: See separate page