

MILLINOCKET, ME, USA

WMO: 726196

Lat: 45.648N

Lon: 68.693W

Elev: 406

StdP: 14.48

Time Zone: -5.00 (NAE)

Period: 95-19

WBAN: 14610

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.4	(c) -4.0	(d) -18.3	(e) 2.1	(f) -6.4	(g) -14.5	(h) 2.5	(i) -2.9	(j) 23.5	(k) 14.0	(l) 20.9	(m) 10.9	(n) 6.7	(o) 290	(p) 0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.6	(c) 86.4	(d) 69.5	(e) 83.1	(f) 67.9	(g) 80.8	(h) 66.1	(i) 72.3	(j) 81.7	(k) 70.6	(l) 78.9	(m) 69.1	(n) 76.2	(o) 6.5	(p) 290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.8	111.4	76.0	67.9	103.9	74.4	66.1	97.7	73.0	36.2	81.6	34.7	78.5	33.4	76.8	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 19.3	(b) 17.1	(c) 15.3	(e) -14.8	(f) 91.7	(g) 4.6	(h) 2.3	(i) -18.2	(j) 93.3	(k) -20.9	(l) 94.7	(m) -23.5	(n) 95.9	(o) -26.9	(p) 97.6		
(a) 19.3	(b) 17.1	(c) 15.3	(e) -15.3	(f) 75.8	(g) 4.6	(h) 2.0	(i) -18.6	(j) 77.2	(k) -21.3	(l) 78.4	(m) -23.9	(n) 79.5	(o) -27.2	(p) 81.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	43.4	16.2	18.9	28.2	40.9	53.6	62.6	68.7	66.7	59.1	46.7	34.9	23.2		
	DBStd	19.97	11.49	10.50	9.89	7.27	7.05	6.63	5.16	5.22	7.13	7.47	8.64	10.09		
	HDD50	4373	1047	870	679	286	40	2	0	0	7	155	457	830		
	HDD65	8182	1512	1290	1142	724	359	122	22	41	203	569	903	1295		
	CDD50	1979	0	0	1	12	153	378	579	518	282	51	5	0		
	CDD65	313	0	0	0	0	7	49	135	94	27	1	0	0		
	CDH74	2779	0	0	2	6	152	488	1134	759	231	7	0	0		
	CDH80	711	0	0	0	1	38	131	297	184	60	0	0	0		
(14) Wind	WSAvg	5.6	6.6	6.7	6.9	6.5	5.5	4.8	4.1	3.9	4.3	5.4	5.9	6.2		
(15) Precipitation	PrecAvg	40.9	3.0	2.6	2.7	3.2	3.5	3.6	3.9	3.7	3.7	3.5	4.0	3.6		
	PrecMax	55.1	7.1	5.9	6.1	8.7	9.4	8.6	7.4	9.4	8.0	8.8	9.3	10.4		
	PrecMin	26.1	0.5	0.5	0.4	0.6	0.4	0.7	1.2	0.7	1.3	0.9	1.1	0.9		
	PrecStd	7.1	1.5	1.3	1.2	1.8	1.8	1.8	1.6	2.1	1.6	1.7	1.9	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.4	47.1	59.4	72.0	85.4	89.0	90.4	89.7	87.6	73.7	62.5	50.3		
		MCWB	47.6	42.0	46.9	53.2	65.1	71.2	72.0	70.5	70.7	61.0	57.6	48.3		
	2%	DB	41.3	42.1	50.1	64.0	78.6	83.7	86.3	84.4	80.4	67.8	56.7	44.8		
		MCWB	38.0	36.9	40.9	49.8	59.8	67.3	70.0	68.9	67.5	59.3	52.4	41.8		
	5%	DB	36.8	37.5	45.5	59.0	72.8	79.9	83.0	81.5	75.2	63.2	52.2	40.0		
		MCWB	34.0	33.8	38.8	47.2	57.1	64.1	68.3	66.8	64.4	56.6	48.1	36.9		
	10%	DB	33.0	35.3	42.0	54.3	68.3	75.3	80.8	78.6	72.0	59.3	47.8	36.6		
		MCWB	30.7	32.4	36.2	44.9	55.2	62.1	66.8	65.6	63.1	53.4	44.4	34.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.3	44.1	50.4	58.2	67.8	73.1	75.5	73.4	72.5	64.9	59.2	48.8		
		MCDB	48.3	46.1	56.6	66.9	78.8	84.4	84.9	83.7	83.2	68.4	61.4	49.6		
	2%	WB	38.3	37.8	43.4	53.4	62.9	70.3	72.7	71.4	69.8	61.3	53.7	42.5		
		MCDB	40.3	40.7	48.4	59.2	73.3	78.9	81.8	80.1	76.1	65.8	55.1	44.6		
	5%	WB	34.0	34.7	39.4	49.6	60.0	68.0	70.9	69.8	67.3	57.8	48.2	37.6		
		MCDB	36.5	37.2	44.9	57.5	68.5	75.5	79.1	77.0	73.0	63.0	51.2	39.5		
	10%	WB	30.5	32.2	36.6	46.0	57.2	65.5	69.1	68.2	64.7	54.1	44.7	34.5		
		MCDB	32.6	35.0	40.9	52.5	65.4	72.0	76.6	74.9	69.5	58.0	47.6	36.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	16.8	18.4	17.9	18.7	20.8	19.8	19.6	20.0	20.0	17.0	13.6	14.0		
		MCDBR	18.7	18.9	21.7	28.9	30.5	26.4	23.2	24.1	24.2	23.0	19.4	15.7		
	5% WB	MCWBR	17.8	15.5	15.1	17.3	15.1	12.5	10.0	10.8	13.0	15.1	16.0	14.6		
		MCWBR	18.6	17.2	19.5	25.4	23.9	21.0	19.8	19.3	19.5	20.4	16.8	15.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.262	0.274	0.307	0.337	0.365	0.393	0.411	0.390	0.361	0.324	0.299	0.271		
		taud	2.422	2.357	2.391	2.436	2.404	2.326	2.299	2.359	2.424	2.533	2.552	2.478		
	Ebn at Noon	Ebn at Noon	273	290	294	293	286	277	270	272	272	269	258	258		
		Edh at Noon	22	29	32	34	36	39	40	36	31	24	20	19		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	466	748	1140	1432	1578	1710	1735	1550	1262	765	459	349		
	RadStd	RadStd	55	82	87	141	190	121	148	93	83	70	47	30		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (28 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page