

MILLINOCKET, ME, USA

WMO: 726196

Lat: 45.648N

Lon: 68.693W

Elev: 124

StdP: 99.85

Time Zone: -5.00 (NAE)

Period: 95-19

WBAN: 14610

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -22.4	(c) -20.0	(d) -27.9	(e) 0.3	(f) -21.3	(g) -25.9	(h) 0.4	(i) -19.4	(j) 10.5	(k) -10.0	(l) 9.3	(m) -11.7	(n) 3.0	(o) 290	(p) 0.527

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	30.2	20.9	28.4	20.0	27.1	19.0	22.4	27.6	21.5	26.0	20.6	24.6	2.9	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	15.9	24.5	19.9	14.8	23.5	19.0	14.0	22.8	66.3	27.5	62.9	25.9	59.8	24.9	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.6	(b) 7.7	(c) 6.8	(e) -26.0	(f) 33.2	(g) 2.6	(h) 1.3	(i) -27.9	(j) 34.1	(k) -29.4	(l) 34.8	(m) -30.8	(n) 35.5	(o) -32.7	(p) 36.4		
(a) 8.6	(b) 7.7	(c) 6.8	(e) -26.3	(f) 24.3	(g) 2.5	(h) 1.1	(i) -28.1	(j) 25.1	(k) -29.6	(l) 25.8	(m) -31.0	(n) 26.4	(o) -32.9	(p) 27.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.4	-8.8	-7.3	-2.1	4.9	12.0	17.0	20.4	19.3	15.1	8.2	1.6	-4.9
	DBStd	11.09	6.38	5.83	5.50	4.04	3.92	3.68	2.86	2.90	3.96	4.15	4.80	5.61
	HDD10.0	2429	582	483	377	159	22	1	0	0	4	86	254	461
	HDD18.3	4546	840	717	634	402	199	68	12	23	113	316	502	719
	CDD10.0	1099	0	0	1	7	85	210	322	288	157	28	3	0
	CDD18.3	174	0	0	0	0	4	27	75	52	15	1	0	0
	CDH23.3	1544	0	0	1	3	84	271	630	422	128	4	0	0
	CDH26.7	395	0	0	0	1	21	73	165	102	33	0	0	0
Wind	WSAvg	2.5	2.9	3.0	3.1	2.9	2.5	2.1	1.9	1.7	1.9	2.4	2.6	2.8
Precipitation	PrecAvg	1039	77	65	69	82	89	92	100	95	94	90	101	92
	PrecMax	1400	181	151	154	222	238	218	188	239	204	223	237	264
	PrecMin	664	13	12	9	15	10	17	30	18	34	22	28	23
	PrecStd	181	39	32	31	46	46	45	41	53	40	44	49	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.6	8.4	15.2	22.2	29.7	31.7	32.5	32.0	30.9	23.2	16.9	10.2
		MCWB	8.7	5.6	8.3	11.8	18.4	21.8	22.2	21.4	21.5	16.1	14.2	9.1
	2%	DB	5.1	5.6	10.1	17.8	25.9	28.7	30.2	29.1	26.9	19.9	13.7	7.1
		MCWB	3.4	2.7	5.0	9.9	15.5	19.6	21.1	20.5	19.7	15.2	11.3	5.5
	5%	DB	2.7	3.1	7.5	15.0	22.7	26.6	28.3	27.5	24.0	17.3	11.2	4.5
		MCWB	1.1	1.0	3.8	8.4	13.9	17.8	20.2	19.3	18.0	13.7	9.0	2.7
	10%	DB	0.6	1.8	5.6	12.4	20.2	24.1	27.1	25.9	22.2	15.2	8.8	2.6
		MCWB	-0.7	0.2	2.3	7.2	12.9	16.7	19.3	18.7	17.3	11.9	6.9	1.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	6.7	10.2	14.6	19.9	22.9	24.2	23.0	22.5	18.3	15.1	9.3
		MCDB	9.1	7.8	13.7	19.4	26.0	29.1	29.4	28.7	28.4	20.2	16.3	9.8
	2%	WB	3.5	3.2	6.3	11.9	17.1	21.3	22.6	21.9	21.0	16.3	12.1	5.8
		MCDB	4.6	4.8	9.1	15.1	23.0	26.1	27.7	26.7	24.5	18.8	12.8	7.0
	5%	WB	1.1	1.5	4.1	9.8	15.5	20.0	21.6	21.0	19.6	14.3	9.0	3.1
		MCDB	2.5	2.9	7.1	14.2	20.3	24.2	26.2	25.0	22.8	17.2	10.6	4.2
	10%	WB	-0.8	0.1	2.6	7.8	14.0	18.6	20.6	20.1	18.2	12.3	7.1	1.4
		MCDB	0.3	1.7	5.0	11.4	18.6	22.2	24.8	23.9	20.8	14.5	8.6	2.4
Mean Daily Temperature Range	5% DB	MDBR	9.3	10.2	9.9	10.4	11.5	11.0	10.9	11.1	11.1	9.5	7.6	7.8
		MCDBR	10.4	10.5	12.1	16.0	16.9	14.6	12.9	13.4	13.5	12.8	10.8	8.7
		MCWBR	9.9	8.6	8.4	9.6	8.4	6.9	5.5	6.0	7.2	8.4	8.9	8.1
	5% WB	MCDBR	10.3	9.5	10.8	14.1	13.3	11.7	11.0	10.7	10.8	11.4	9.3	8.7
		MCWBR	10.0	8.4	8.2	9.9	7.6	6.5	5.6	5.8	6.8	8.5	8.8	8.4
Clear-Sky Solar Irradiance	taub	0.262	0.274	0.307	0.337	0.365	0.393	0.411	0.390	0.361	0.324	0.299	0.271	
	taud	2.422	2.357	2.391	2.436	2.404	2.326	2.299	2.359	2.424	2.533	2.552	2.478	
	Ebn at Noon	861	914	927	923	902	874	852	858	857	849	813	812	
	Edh at Noon	69	90	101	107	114	124	126	114	98	77	63	60	
All-Sky Solar Radiation	RadAvg	1.47	2.36	3.60	4.51	4.97	5.39	5.47	4.88	3.98	2.41	1.45	1.10	
	RadStd	0.17	0.26	0.27	0.45	0.60	0.38	0.47	0.29	0.26	0.22	0.15	0.09	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page