

PLATTSBURGH, NY, USA

WMO: 726225

Lat: 44.650N

Lon: 73.467W

Elev: 71

StdP: 100.47

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 64776

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -22.7	(c) -19.5	(d) -27.9	(e) 0.3	(f) -21.3	(g) -25.1	(h) 0.4	(i) -18.6	(j) 10.2	(k) -2.7	(l) 9.1	(m) -4.6	(n) 2.1	(o) 280	(p) 0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	30.9	22.0	28.8	21.3	27.4	20.3	23.6	28.3	22.6	26.9	21.6	25.7	3.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.1	17.0	26.3	21.2	16.0	25.2	20.1	15.0	24.1	70.6	28.6	66.8	26.8	63.3	25.5	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.9	7.0	-26.9	34.2	4.0	1.6	-29.8	35.4	-32.1	36.3	-34.3	37.2	-37.3	38.4		
			-27.1	25.4	3.9	1.1	-29.9	26.2	-32.2	26.8	-34.4	27.5	-37.2	28.3		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-7.5	-6.3	-1.0	6.5	13.4	18.1	21.0	19.9	15.8	9.0	3.0	-3.4		
	DBStd	11.04	7.23	6.27	5.81	4.66	4.07	3.65	2.83	2.90	3.94	4.39	4.79	5.92		
	HDD10.0	2182	542	456	341	126	13	0	0	0	3	73	213	416		
	HDD18.3	4194	801	689	598	356	161	48	7	17	96	289	459	674		
	CDD10.0	1257	0	0	2	21	118	243	341	308	177	43	4	1		
	CDD18.3	226	0	0	0	1	8	41	89	66	20	1	0	0		
	CDH23.3	1893	0	0	1	25	112	374	733	483	161	5	0	0		
	CDH26.7	479	0	0	0	6	28	106	199	106	34	0	0	0		
(14) Wind	WSAvg	2.7	2.8	2.9	3.3	3.4	3.0	2.6	2.3	2.2	2.4	2.5	2.7	2.5		
(15) Precipitation	PrecAvg	672	40	34	44	60	61	64	64	83	66	56	62	47		
	PrecMax	1067	165	82	76	162	151	157	119	164	172	123	125	124		
	PrecMin	434	7	10	4	10	20	17	24	20	14	5	12	8		
	PrecStd	167	33	19	19	28	28	33	25	33	34	26	28	27		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	11.1	18.0	26.8	30.4	32.7	33.0	32.0	30.1	23.8	18.0	12.1		
		MCWB	8.7	6.9	11.3	17.2	19.0	22.3	23.5	23.0	22.1	17.5	13.6	9.0		
	2%	DB	6.8	7.1	12.8	22.0	26.3	29.6	30.9	29.1	27.3	21.1	15.2	8.9		
		MCWB	4.5	3.9	7.6	13.3	17.3	21.2	22.4	21.6	20.5	16.2	11.9	6.8		
	5%	DB	4.5	4.5	9.6	17.9	23.7	27.4	28.8	27.5	25.1	18.6	12.7	6.6		
		MCWB	2.7	2.0	5.4	10.8	15.9	19.9	21.7	20.6	19.9	14.5	9.5	4.5		
	10%	DB	2.6	2.6	7.2	14.4	21.4	25.3	27.3	26.1	22.9	16.3	10.9	4.3		
		MCWB	0.9	0.7	3.9	8.5	14.9	18.5	20.7	20.0	18.1	12.8	8.1	2.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	7.3	12.4	18.0	21.1	24.0	25.4	24.3	23.3	19.1	14.9	10.0		
		MCDB	10.6	9.7	16.8	25.0	26.2	29.4	31.0	29.4	27.8	22.2	17.3	11.3		
	2%	WB	5.0	4.3	8.5	14.5	19.3	22.5	23.9	23.0	21.7	16.9	12.2	7.0		
		MCDB	6.3	6.6	12.0	20.1	24.2	27.8	28.7	27.2	25.8	19.9	14.7	8.6		
	5%	WB	2.8	2.4	5.8	11.6	17.5	21.1	22.8	22.0	20.4	14.9	10.1	4.9		
		MCDB	4.3	4.3	9.0	16.3	21.3	25.6	26.9	25.6	24.0	18.1	12.4	6.5		
	10%	WB	1.0	0.7	4.1	9.4	15.8	19.8	21.8	21.0	19.0	13.2	8.0	2.8		
		MCDB	2.5	2.3	7.1	14.0	20.2	23.3	25.8	24.6	22.4	15.6	10.2	4.2		
(35) Mean Daily Temperature Range	MDBR		9.2	9.9	9.7	10.7	11.5	11.0	11.0	11.1	11.3	9.8	8.7	7.9		
	5% DB	MCDBR	9.4	10.6	13.7	17.1	15.9	14.0	12.7	12.7	13.5	12.6	12.2	8.6		
		MCWBR	8.2	8.6	9.4	10.1	8.3	6.9	6.3	6.4	7.7	8.1	9.5	7.5		
	5% WB	MCDBR	9.4	10.4	12.7	15.8	12.9	12.2	11.2	11.1	11.9	11.8	11.3	8.7		
		MCWBR	8.4	8.7	9.3	10.1	7.8	6.8	6.3	6.3	7.3	8.3	9.6	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.286	0.289	0.329	0.353	0.379	0.438	0.440	0.417	0.372	0.337	0.312	0.283		
	taud		2.345	2.342	2.364	2.399	2.382	2.220	2.220	2.277	2.395	2.495	2.491	2.410		
	Ebn at Noon		831	901	905	909	891	835	828	834	849	838	801	801		
	Edh at Noon		77	93	106	112	117	139	137	125	102	81	68	66		
(44) All-Sky Solar Radiation	RadAvg		1.44	2.29	3.44	4.32	5.05	5.45	5.56	4.98	4.03	2.35	1.48	1.05		
	RadStd		0.16	0.22	0.25	0.53	0.55	0.47	0.43	0.23	0.32	0.24	0.17	0.09		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+63	N/A

Nomenclature: See separate page