

ADIRONDACK, NY, USA

WMO: 726228

Lat: 44.385N

Lon: 74.207W

Elev: 507

StdP: 95.38

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 94740

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.1	-24.8	-31.3	0.2	-27.5	-27.9	0.3	-23.9	10.0	1.6	8.8	-2.4	0.7	230	0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	28.6	19.5	27.2	19.0	25.9	18.3	21.6	25.8	20.7	24.7	19.8	23.7	4.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	15.9	23.3	19.1	14.8	22.5	18.3	14.1	21.7	65.3	25.7	61.8	24.9	58.8	23.6	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.5	6.6	DB	-33.4	31.2	2.9	1.1	-35.5	32.0	-37.2	32.7	-38.8	33.3	-41.0	34.1	(4)
(5)			WB	-33.1	23.4	2.4	1.1	-34.9	24.2	-36.3	24.8	-37.7	25.4	-39.4	26.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.6	-10.0	-8.9	-4.2	3.7	10.6	15.1	17.6	16.7	13.0	6.6	0.3	-6.0	(6)	
	DBStd	11.14	7.79	6.89	6.81	5.06	4.57	3.81	3.10	3.33	4.35	4.76	5.63	6.70	(7)	
	HDD10.0	2776	619	528	440	200	49	4	0	1	19	127	292	497	(8)	
	HDD18.3	5080	877	761	698	441	243	110	51	72	167	364	541	756	(9)	
	CDD10.0	813	0	0	1	10	67	158	237	208	109	22	2	0	(10)	
	CDD18.3	74	0	0	0	0	3	14	29	22	7	0	0	0	(11)	
	CDH23.3	962	0	0	0	13	83	193	337	222	112	3	0	0	(12)	
	CDH26.7	173	0	0	0	2	13	41	61	34	22	0	0	0	(13)	
(14) Wind	WSAvg	2.5	2.8	2.8	2.8	2.9	2.6	2.3	2.1	2.0	2.1	2.5	2.6	2.7	(14)	
(15) Precipitation	PrecAvg	1033	69	59	68	84	92	104	109	100	93	97	84	84	(15)	
	PrecMax	1255	166	107	114	177	167	219	170	162	179	176	178	139	(16)	
	PrecMin	893	37	27	31	21	40	34	65	32	52	23	40	46	(17)	
	PrecStd	98	28	22	22	38	34	52	30	30	32	42	29	27	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	10.9	16.2	25.2	28.5	30.4	30.5	29.6	29.2	23.5	17.4	12.4	(19)	
		MCWB	8.9	8.4	8.7	14.7	17.6	20.2	21.8	20.6	19.7	15.8	12.5	10.1	(20)	
	2%	DB	7.1	6.9	11.5	20.7	25.9	27.7	28.2	27.5	26.4	20.6	14.3	8.3	(21)	
		MCWB	5.7	4.3	6.7	12.0	16.1	18.9	19.9	19.3	18.8	14.6	10.4	6.9	(22)	
	5%	DB	3.3	3.9	8.6	16.7	23.0	25.8	26.9	26.0	24.0	17.7	12.2	6.0	(23)	
		MCWB	2.2	2.0	5.0	9.9	14.4	17.8	19.4	19.0	17.6	13.6	9.2	4.7	(24)	
	10%	DB	0.9	1.4	6.0	13.2	20.6	23.5	25.2	24.1	21.9	15.3	9.3	2.9	(25)	
		MCWB	-0.1	0.0	2.9	7.8	13.4	16.6	18.5	18.0	16.6	12.0	7.1	1.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.0	8.8	11.3	15.9	19.8	21.9	23.4	22.4	21.5	18.2	13.4	10.3	(27)	
		MCDB	10.0	10.1	14.3	22.1	25.5	26.9	27.9	26.2	25.9	20.4	16.1	11.8	(28)	
	2%	WB	5.8	4.9	7.8	13.2	18.2	20.6	21.9	21.1	20.0	16.2	11.6	7.5	(29)	
		MCDB	6.7	6.4	10.0	19.2	23.2	25.4	26.2	25.0	24.2	18.9	13.7	8.1	(30)	
	5%	WB	2.4	2.4	5.5	10.8	16.6	19.5	20.8	20.2	18.8	14.1	9.6	4.7	(31)	
		MCDB	3.3	3.9	8.3	15.2	20.4	23.4	24.5	23.8	22.6	17.3	11.7	5.9	(32)	
	10%	WB	-0.1	0.2	3.1	8.7	15.0	18.2	19.8	19.4	17.5	12.2	7.3	2.1	(33)	
		MCDB	0.7	1.4	5.5	12.3	18.9	21.8	23.7	22.7	20.5	14.6	9.2	3.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	12.3	12.5	12.6	14.3	13.1	13.1	13.3	14.0	11.0	10.0	9.6	(35)	
		MCDBR	11.5	13.2	15.3	20.1	19.6	16.5	15.4	14.9	17.1	16.2	14.9	11.1	(36)	
		MCWBR	10.7	11.3	10.9	11.7	10.8	8.6	8.1	7.9	9.9	10.5	11.0	10.1	(37)	
	5% WB	MCDBR	11.1	12.5	13.3	16.9	15.2	12.9	12.7	12.3	13.6	13.6	12.9	10.4	(38)	
		MCWBR	10.5	11.2	10.6	11.0	9.2	7.4	7.3	7.1	8.3	9.8	10.6	9.9	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.264	0.278	0.313	0.335	0.360	0.405	0.410	0.390	0.346	0.324	0.304	0.276	(40)	
	taud		2.398	2.355	2.382	2.432	2.413	2.282	2.267	2.321	2.447	2.515	2.494	2.420	(41)	
	Ebn at Noon		871	918	925	929	909	865	856	861	879	856	815	816	(42)	
	Edh at Noon		73	92	104	108	114	130	131	120	97	79	68	66	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.39	2.23	3.38	4.29	5.03	5.42	5.55	4.96	4.01	2.34	1.49	1.02	(44)	
	RadStd		0.17	0.24	0.29	0.55	0.57	0.46	0.48	0.24	0.34	0.26	0.17	0.10	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+66	N/A

Nomenclature: See separate page