

STEVENS POINT, WI, USA

WMO: 726426

Lat: 44.550N

Lon: 89.533W

Elev: 338

StdP: 97.33

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 04895

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.8	-22.1	-28.8	0.3	-23.9	-26.2	0.4	-21.2	8.6	-5.2	7.9	-5.2	1.4	280	0.550

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	31.4	22.4	29.3	21.1	27.8	20.3	24.3	28.5	23.1	27.2	22.1	26.2	4.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.9	18.4	26.4	22.2	17.6	25.7	21.0	16.3	24.5	75.2	29.1	70.6	26.7	66.2	25.6	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
(a)	(b)	(c)		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
8.5	7.6	6.9	DB	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
			WB	-29.0	33.8	2.3	2.2	-30.7	35.4	-32.0	36.7	-33.3	37.9	-35.0	39.6	
				-29.2	25.5	2.3	1.4	-30.8	26.6	-32.2	27.4	-33.4	28.2	-35.1	29.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-9.0	-7.7	-0.9	6.4	13.1	18.2	20.9	19.5	15.3	8.1	1.2	-6.2	(6)
(7)		DBStd	11.79	6.95	6.64	6.69	5.51	4.85	3.77	3.37	3.36	4.60	5.00	5.64	6.38	(7)
(8)		HDD10.0	2463	588	495	344	134	23	1	0	0	8	99	269	503	(8)
(9)		HDD18.3	4498	846	728	597	358	173	47	13	25	113	319	516	762	(9)
(10)		CDD10.0	1246	0	0	6	27	120	247	339	296	167	40	4	0	(10)
(11)		CDD18.3	239	0	0	1	1	12	44	94	63	22	2	0	0	(11)
(12)		CDH23.3	2357	0	0	3	26	154	454	930	558	208	24	0	0	(12)
(13)		CDH26.7	659	0	0	0	5	39	121	299	143	49	3	0	0	(13)
(14)	Wind	WSAvg	2.8	2.7	2.8	2.9	3.5	3.2	2.7	2.4	2.2	2.5	2.8	2.8	2.7	(14)
(15)	Precipitation	PrecAvg	819	28	25	43	76	99	120	96	101	88	64	45	33	(15)
(16)		PrecMax	1041	63	51	86	149	179	217	245	301	234	156	135	74	(16)
(17)		PrecMin	674	9	7	7	21	48	44	25	19	9	6	1	6	(17)
(18)		PrecStd	87	15	11	22	31	31	55	52	56	52	34	31	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.6	10.2	22.2	27.1	31.0	32.4	34.5	32.5	31.0	26.3	18.8	10.9	(19)
(20)		MCWB	4.1	6.8	15.7	16.7	21.2	22.8	23.7	23.2	21.8	18.0	13.1	10.3	(20)	
(21)		2%	DB	4.0	6.4	16.3	22.5	27.4	29.7	32.1	30.1	27.8	22.6	15.1	6.2	(21)
(22)		MCWB	2.1	3.8	10.7	13.8	18.1	20.9	23.0	21.8	19.9	17.0	11.1	4.0	(22)	
(23)		5%	DB	2.2	3.4	12.4	19.0	24.5	27.7	29.8	27.9	26.0	19.3	12.4	3.6	(23)
(24)		MCWB	1.1	1.7	8.7	11.8	16.0	20.0	22.0	20.6	19.0	14.6	8.8	2.5	(24)	
(25)		10%	DB	0.7	1.4	8.7	16.3	22.2	26.2	27.9	26.5	23.7	17.0	9.6	2.2	(25)
(26)		MCWB	0.0	-0.1	5.4	9.6	15.2	18.9	20.7	19.7	18.0	13.0	7.1	1.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.5	7.4	15.6	18.0	22.3	24.8	26.4	25.6	23.4	21.2	14.7	10.6	(27)
(28)		MDCB	6.8	9.9	21.0	24.2	28.1	29.1	31.4	29.2	27.1	24.8	17.6	10.8	(28)	
(29)		2%	WB	2.5	4.1	12.3	15.2	19.8	23.0	24.9	23.7	22.0	17.8	11.9	4.5	(29)
(30)		MDCB	4.1	6.0	14.5	20.4	24.8	27.8	29.4	27.4	26.1	20.4	14.3	5.3	(30)	
(31)		5%	WB	1.1	2.0	8.6	12.8	18.0	21.7	23.6	22.4	20.7	15.7	9.2	2.7	(31)
(32)		MDCB	1.9	3.5	12.2	18.0	22.1	26.2	27.6	26.2	24.0	19.0	11.8	3.6	(32)	
(33)		10%	WB	-0.2	0.0	5.3	10.3	16.5	20.2	22.3	21.2	19.2	13.2	7.1	1.2	(33)
(34)		MDCB	0.5	1.3	8.7	15.3	20.4	24.2	26.3	24.9	22.4	16.6	9.1	2.0	(34)	
(35)	Mean Daily Temperature Range	MDBR	8.8	9.8	10.4	11.6	12.1	11.6	12.0	11.5	12.0	10.5	8.8	7.9	(35)	
(36)		5% DB	MCDBR	9.4	10.4	14.3	17.1	15.5	13.7	13.6	12.8	14.1	14.3	13.3	9.1	(36)
(37)		MCWBR	7.8	7.9	9.3	9.8	7.5	6.6	5.9	6.0	6.9	8.6	9.4	7.7	(37)	
(38)		5% WB	MCDBR	8.5	9.7	12.9	14.6	12.5	11.7	11.6	10.8	11.5	12.2	12.0	7.9	(38)
(39)		MCWBR	7.3	7.6	9.0	9.5	6.8	6.5	6.2	6.0	6.8	8.6	9.3	7.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.251	0.286	0.319	0.352	0.388	0.390	0.382	0.383	0.355	0.319	0.288	0.260	(40)	
(41)		taud	2.403	2.292	2.370	2.362	2.303	2.326	2.361	2.354	2.431	2.524	2.524	2.449	(41)	
(42)		Ebn at Noon	889	902	917	910	882	879	882	868	868	862	837	842	(42)	
(43)		Edh at Noon	72	98	105	116	127	125	119	116	99	78	65	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.69	2.79	3.93	4.54	5.42	5.94	6.08	5.20	4.12	2.60	1.65	1.23	(44)	
(45)		RadStd	0.19	0.24	0.42	0.46	0.42	0.44	0.31	0.34	0.30	0.28	0.18	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (47 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page