

PRICE COUNTY AP, WI, USA

WMO: 726468

Lat: 45.709N

Lon: 90.402W

Elev: 456

StdP: 95.96

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 54913

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.3	-24.9	-32.9	0.2	-27.5	-28.9	0.3	-24.2	8.7	-5.9	7.9	-6.7	0.6	280	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	29.9	21.9	28.0	20.6	27.2	19.8	23.7	27.7	22.5	26.3	21.5	25.1	4.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.5	18.1	25.8	21.3	16.9	24.7	20.2	15.7	23.7	73.2	27.9	68.7	26.1	64.8	24.4	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.3	6.3	DB	-32.1	32.2	2.7	2.0	-34.0	33.6	-35.6	34.7	-37.1	35.8	-39.0	37.2	(4)
(5)			WB	-32.2	25.2	2.6	1.5	-34.1	26.2	-35.6	27.1	-37.0	27.9	-38.9	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.6	-10.8	-8.9	-2.2	5.0	12.2	17.5	19.9	18.8	14.6	7.5	-0.3	-7.3	(6)	
	DBStd	12.11	7.46	7.32	7.15	5.50	4.83	3.88	3.29	3.29	4.69	5.01	5.84	6.64	(7)	
	HDD10.0	2724	644	528	383	166	31	1	0	0	12	111	311	536	(8)	
	HDD18.3	4836	903	762	637	399	199	61	22	34	128	338	558	794	(9)	
	CDD10.0	1111	0	0	5	17	99	226	306	271	151	33	2	0	(10)	
	CDD18.3	182	0	0	0	1	9	36	69	48	18	2	0	0	(11)	
	CDH23.3	1631	0	0	1	8	112	336	634	381	146	13	0	0	(12)	
	CDH26.7	362	0	0	0	1	23	74	162	75	26	1	0	0	(13)	
(14) Wind	WSAvg	2.6	2.5	2.6	2.7	3.0	2.9	2.4	2.2	2.1	2.4	2.7	2.7	2.5	(14)	
(15) Precipitation	PrecAvg	824	27	22	41	66	90	112	106	97	105	86	47	30	(15)	
	PrecMax	1071	62	55	82	141	163	214	231	254	246	178	160	59	(16)	
	PrecMin	617	7	2	7	16	46	42	28	35	24	22	3	10	(17)	
	PrecStd	147	16	14	23	33	34	41	51	50	56	45	34	15	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.2	9.1	20.1	24.0	29.1	31.2	32.7	31.2	29.1	25.1	17.3	9.0	(19)	
		MCWB	2.7	6.0	14.9	14.2	19.3	22.6	24.5	22.9	21.2	16.4	11.5	7.6	(20)	
	2%	DB	2.8	6.3	15.1	21.0	26.4	28.7	30.1	28.7	27.2	22.1	13.3	5.1	(21)	
		MCWB	1.3	3.6	10.2	11.8	17.1	20.9	22.5	21.6	19.9	16.0	9.5	3.3	(22)	
	5%	DB	1.2	3.0	11.2	17.7	23.8	27.2	28.0	27.2	24.9	18.7	11.0	2.7	(23)	
		MCWB	0.4	1.0	7.2	9.6	15.8	19.6	21.0	20.2	18.4	14.4	7.9	1.6	(24)	
	10%	DB	-0.9	1.3	7.7	14.9	21.4	25.1	27.1	25.8	22.7	16.1	7.9	1.3	(25)	
		MCWB	-1.4	-0.2	4.4	8.3	13.9	18.4	20.4	19.4	17.6	12.1	5.6	0.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.4	7.0	15.7	16.5	21.9	24.0	26.2	24.7	23.0	21.0	13.7	7.9	(27)	
		MCDB	5.0	8.2	18.9	22.1	26.3	28.6	30.2	28.3	26.9	22.1	15.5	8.7	(28)	
	2%	WB	1.6	3.8	11.2	13.4	19.3	22.4	24.1	23.1	21.2	16.8	10.5	3.5	(29)	
		MCDB	2.7	6.0	13.5	19.0	23.6	26.9	28.1	26.6	24.6	19.6	12.9	4.4	(30)	
	5%	WB	0.3	1.6	7.6	11.0	17.4	21.1	22.8	22.0	20.1	14.6	7.8	2.0	(31)	
		MCDB	1.2	3.3	10.3	15.6	21.2	25.4	26.6	25.1	23.6	18.1	9.8	2.8	(32)	
	10%	WB	-1.2	-0.1	4.6	8.9	15.6	19.8	21.6	20.7	18.7	12.5	5.9	0.4	(33)	
		MCDB	-0.6	1.2	7.6	14.4	19.8	23.5	25.2	24.2	21.8	15.4	8.2	1.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	11.1	11.3	11.8	12.7	11.8	11.7	11.4	11.4	9.9	8.1	8.1	(35)	
		MCDBR	9.5	11.1	13.5	16.8	15.5	13.2	12.8	12.8	13.3	13.7	12.2	9.1	(36)	
	5% WB	MCWBR	8.1	8.5	8.6	9.1	7.6	6.7	6.2	6.4	6.9	8.2	8.4	7.5	(37)	
		MCDWR	9.1	9.5	11.7	14.6	12.1	11.3	11.2	10.4	11.3	11.5	10.8	7.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.239	0.263	0.293	0.334	0.361	0.362	0.364	0.364	0.339	0.304	0.277	0.250	(40)	
		taud	2.399	2.332	2.401	2.425	2.388	2.405	2.416	2.429	2.495	2.579	2.544	2.442	(41)	
	Edn at Noon	Edn at Noon	893	928	943	926	906	904	896	885	881	875	841	841	(42)	
		Edh at Noon	70	92	100	108	116	115	112	106	91	73	62	61	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.56	2.66	3.81	4.55	5.32	5.83	6.08	5.10	3.95	2.46	1.47	1.07	(44)	
	RadStd	RadStd	0.17	0.23	0.35	0.47	0.40	0.45	0.26	0.35	0.25	0.28	0.16	0.12	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page