

CUSTER, SD, USA

WMO: 726514

Lat: 43.733N

Lon: 103.611W

Elev: 1690

StdP: 82.60

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 94032

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-21.9	-18.7	-27.4	0.4	-18.6	-24.1	0.5	-16.1	10.8	1.6	9.3	0.7	1.6	270	0.607

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	30.9	15.2	28.9	15.1	27.3	14.9	18.0	25.0	17.2	24.5	16.4	23.9	4.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.0	14.0	20.6	14.8	12.9	20.0	13.7	12.1	19.4	57.8	25.0	54.7	24.4	52.1	23.9	21.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	7.9	7.0	-27.5	33.8	2.3	1.3	-29.2	34.7	-30.5	35.4	-31.8	36.1	-33.5	37.0		
(5)			-27.8	19.9	2.3	0.6	-29.4	20.4	-30.7	20.7	-32.0	21.1	-33.6	21.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.1	-3.8	-4.6	0.2	4.0	8.9	14.8	19.2	18.1	13.3	6.0	0.5	-4.0	(6)
(7)		DBStd	9.89	6.18	6.82	6.07	5.13	4.78	4.10	3.25	3.31	4.88	5.53	6.17	6.23	(7)
(8)		HDD10.0	2306	427	408	305	189	79	8	0	1	24	147	286	433	(8)
(9)		HDD18.3	4570	686	641	561	431	293	118	29	44	159	383	534	691	(9)
(10)		CDD10.0	893	0	0	2	8	45	152	287	252	123	22	2	0	(10)
(11)		CDD18.3	117	0	0	0	0	1	13	57	37	9	0	0	0	(11)
(12)		CDH23.3	1706	0	0	0	1	28	231	727	525	188	6	0	0	(12)
(13)		CDH26.7	484	0	0	0	0	3	59	239	147	36	0	0	0	(13)
(14)	Wind	WSAvg	3.0	3.2	3.2	3.1	3.2	3.2	3.0	2.8	2.7	2.8	3.0	3.0	3.2	(14)
(15)	Precipitation	PrecAvg	458	9	13	22	47	78	84	80	51	39	23	14	14	(15)
(16)		PrecMax	584	24	51	54	100	224	163	192	101	123	64	43	42	(16)
(17)		PrecMin	301	0	0	0	8	2	17	9	12	2	2	0	0	(17)
(18)		PrecStd	87	6	12	13	26	51	44	43	25	32	17	10	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	13.3	18.8	22.3	26.6	31.4	33.8	32.1	29.8	24.0	18.7	12.2	(19)
(20)			MCWB	3.6	4.5	7.1	9.2	12.8	14.8	15.6	14.5	13.8	10.3	6.9	3.4	(20)
(21)		2%	DB	8.9	10.1	15.5	19.2	23.4	28.2	31.5	30.1	27.5	21.1	15.3	8.9	(21)
(22)			MCWB	2.0	2.7	5.9	8.2	12.0	14.8	15.8	14.8	13.1	9.5	5.7	2.2	(22)
(23)		5%	DB	6.7	7.6	12.6	16.6	20.8	26.1	29.3	28.3	25.7	18.1	12.4	6.8	(23)
(24)			MCWB	0.9	1.6	4.5	7.3	11.4	14.7	15.7	15.0	12.7	8.2	4.3	0.8	(24)
(25)		10%	DB	4.8	5.0	10.0	13.5	18.0	23.7	27.4	26.5	23.3	15.3	9.7	4.4	(25)
(26)			MCWB	-0.2	0.1	3.2	5.9	10.4	14.0	15.6	14.9	11.9	7.0	3.1	-0.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.0	5.1	8.2	10.5	15.2	18.8	19.5	18.6	16.9	12.1	7.6	4.1	(27)
(28)			MCDB	11.1	12.0	16.9	19.2	22.3	24.2	26.0	25.7	24.2	20.8	17.3	10.3	(28)
(29)		2%	WB	2.4	3.3	6.3	8.9	13.5	16.9	18.3	17.6	15.0	10.4	5.8	2.6	(29)
(30)			MCDB	7.9	9.2	14.6	17.0	20.1	23.4	25.4	25.1	23.5	18.0	14.2	8.4	(30)
(31)		5%	WB	1.3	1.8	4.9	7.7	12.2	15.8	17.5	16.8	13.9	9.1	4.6	1.1	(31)
(32)			MCDB	6.2	7.2	12.1	15.6	18.9	23.3	24.8	24.0	22.5	16.5	11.9	6.1	(32)
(33)		10%	WB	0.1	0.3	3.5	6.5	10.8	14.8	16.7	16.0	12.8	7.7	3.2	0.0	(33)
(34)			MCDB	4.6	4.8	9.5	12.9	17.3	22.4	24.4	23.1	21.2	14.5	9.4	4.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.8	10.9	11.5	11.7	11.7	12.9	13.8	14.0	13.9	11.8	11.0	10.4	(35)
(36)			MCDBR	11.8	12.2	15.1	17.1	16.0	16.8	16.8	16.8	17.1	16.3	14.1	11.4	(36)
(37)			MCWBR	7.2	7.3	8.1	8.6	7.5	7.3	6.3	6.4	7.0	7.9	7.6	7.0	(37)
(38)		5% WB	MCDBR	11.5	12.0	14.4	15.6	14.5	14.8	14.2	13.9	15.1	14.6	13.7	11.0	(38)
(39)			MCWBR	7.3	7.6	7.9	8.4	7.6	7.4	6.5	6.6	6.8	7.6	7.7	7.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.235	0.243	0.258	0.284	0.296	0.310	0.330	0.327	0.295	0.268	0.244	0.233	(40)	
(41)		taud	2.625	2.601	2.611	2.520	2.566	2.541	2.506	2.495	2.584	2.633	2.611	2.613	(41)	
(42)		Ebn at Noon	940	982	999	985	976	957	933	928	941	936	916	909	(42)	
(43)		Edh at Noon	60	73	83	99	98	101	103	101	85	70	60	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.99	2.90	4.09	5.06	5.97	7.03	7.08	6.12	4.88	3.21	2.18	1.65	(44)	
(45)		RadStd	0.10	0.17	0.33	0.32	0.57	0.49	0.25	0.24	0.29	0.29	0.15	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (14 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page