

WORLAND, WY, USA

WMO: 726665

Lat: 43.966N

Lon: 107.951W

Elev: 1272

StdP: 86.95

Time Zone: -7.00 (NAM)

Period: 00-19

WBAN: 24062

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-24.9	-21.5	-27.5	0.4	-24.5	-24.1	0.5	-21.1	11.0	-1.3	8.9	0.2	1.4	190	0.583

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.2	35.5	16.2	33.9	16.0	32.3	15.7	18.4	29.8	17.5	29.2	16.7	28.8	3.6	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.8	12.3	21.1	13.4	11.2	20.5	12.3	10.4	20.3	56.8	29.6	53.9	29.3	51.3	28.6	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	8.5	7.1	-31.3	38.5	3.1	1.3	-33.5	39.5	-35.3	40.2	-37.0	41.0	-39.3	42.0		
(5)			-31.5	20.0	3.0	1.3	-33.6	21.0	-35.4	21.8	-37.0	22.5	-39.2	23.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-7.9	-5.5	3.0	7.8	12.8	18.8	23.4	21.3	15.8	7.8	-0.1	-7.5	(6)
(7)		DBStd	11.82	5.87	6.64	5.59	4.45	4.50	3.99	2.65	3.01	4.24	5.03	6.28	5.90	(7)
(8)		HDD10.0	2278	556	433	221	92	24	1	0	0	6	99	303	544	(8)
(9)		HDD18.3	4280	814	666	474	316	178	42	2	10	96	328	552	802	(9)
(10)		CDD10.0	1382	0	0	5	26	111	264	414	351	180	30	1	0	(10)
(11)		CDD18.3	343	0	0	0	0	6	55	158	103	21	1	0	0	(11)
(12)		CDH23.3	5426	0	0	3	26	197	939	2208	1504	512	37	0	0	(12)
(13)		CDH26.7	2562	0	0	0	3	53	419	1160	722	198	8	0	0	(13)
(14)	Wind	WSAvg	2.5	1.8	2.2	3.0	3.5	3.1	2.9	2.6	2.5	2.4	2.4	2.1	1.9	(14)
(15)	Precipitation	PrecAvg	183	7	6	10	22	34	28	13	16	19	15	9	7	(15)
(16)		PrecMax	286	26	25	30	52	104	88	50	71	65	64	23	22	(16)
(17)		PrecMin	95	0	0	1	0	2	3	0	0	0	2	0	0	(17)
(18)		PrecStd	49	6	5	7	13	25	20	12	14	15	14	7	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.4	13.2	22.4	26.3	30.8	36.3	37.9	36.4	33.6	27.7	18.9	9.9	(19)
(20)			MCWB	3.5	5.3	9.3	10.9	14.0	15.5	17.1	16.1	15.6	13.0	8.6	4.1	(20)
(21)		2%	DB	5.5	9.1	19.0	23.2	28.1	33.8	36.1	34.5	31.3	23.4	15.1	6.0	(21)
(22)			MCWB	1.3	2.9	7.9	9.7	13.4	15.7	17.0	15.5	14.5	11.1	6.6	1.7	(22)
(23)		5%	DB	2.9	6.2	15.9	20.4	25.5	31.4	34.4	32.9	29.0	20.3	11.9	3.1	(23)
(24)			MCWB	-0.2	1.7	6.6	9.0	12.8	15.2	16.6	15.4	13.7	10.3	5.2	-0.2	(24)
(25)		10%	DB	0.5	3.8	12.6	17.6	22.7	28.9	32.8	31.1	26.4	17.1	8.9	0.7	(25)
(26)			MCWB	-1.7	0.4	5.2	7.9	11.7	14.6	16.3	15.4	13.2	8.7	3.5	-1.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	5.9	9.9	11.7	15.7	18.1	20.2	18.2	17.0	13.5	8.9	4.4	(27)
(28)			MCDWB	8.4	11.6	20.8	24.7	26.9	29.5	31.7	29.6	29.6	24.7	17.6	9.7	(28)
(29)		2%	WB	1.6	3.5	8.2	10.4	14.5	17.0	19.0	17.3	15.7	11.9	7.0	1.9	(29)
(30)			MCDWB	5.1	8.2	18.0	21.1	24.8	29.2	30.6	29.2	27.5	22.0	14.6	5.4	(30)
(31)		5%	WB	0.1	1.9	6.9	9.3	13.4	16.1	18.1	16.6	14.7	10.6	5.4	0.2	(31)
(32)			MCDWB	2.6	5.7	15.0	19.2	23.3	28.4	29.6	28.8	26.3	19.0	11.3	2.8	(32)
(33)		10%	WB	-1.6	0.4	5.5	8.2	12.4	15.3	17.4	15.9	13.6	9.2	3.9	-1.3	(33)
(34)			MCDWB	0.6	3.6	12.1	17.0	21.1	27.0	29.0	28.0	24.6	16.3	8.6	0.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.3	13.1	14.5	14.6	14.5	16.8	18.2	18.2	17.2	15.0	14.1	12.7	(35)
(36)			MCDBR	14.6	15.0	19.3	20.1	19.6	21.2	20.6	21.0	22.0	20.5	18.9	15.0	(36)
(37)			MCWBR	10.8	9.7	9.8	9.0	7.5	7.6	7.1	7.7	9.2	10.1	11.2	11.1	(37)
(38)		5% WB	MCDWB	14.3	14.5	18.0	18.5	17.5	19.0	18.4	18.3	19.4	18.8	17.9	14.3	(38)
(39)			MCWBR	10.9	9.8	9.3	8.4	7.0	7.1	6.7	6.7	8.1	9.5	10.8	10.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.247	0.253	0.277	0.313	0.332	0.339	0.363	0.355	0.320	0.281	0.256	0.244	(40)	
(41)		taud	2.547	2.552	2.507	2.403	2.410	2.411	2.374	2.376	2.468	2.561	2.555	2.546	(41)	
(42)		Ebn at Noon	913	965	972	952	937	928	901	897	909	914	891	883	(42)	
(43)		Edh at Noon	64	76	92	111	114	115	118	113	95	75	63	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.90	2.88	4.16	5.24	6.16	7.31	7.32	6.28	4.96	3.25	2.13	1.54	(44)	
(45)		RadStd	0.13	0.19	0.27	0.29	0.57	0.46	0.27	0.23	0.34	0.26	0.17	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page