

BOZEMAN YELLOWSTONE, MT, USA

WMO: 726797

Lat: 45.788N

Lon: 111.161W

Elev: 1349

StdP: 86.13

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24132

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-25.2	-21.4	-28.4	0.3	-24.8	-24.4	0.5	-21.1	10.9	2.6	9.1	2.0	1.4	180	0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	33.4	16.2	31.5	15.7	29.6	15.2	17.9	28.5	17.0	27.7	16.2	27.0	3.5	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.5	12.1	20.8	13.2	11.2	20.1	12.3	10.5	19.5	55.7	28.6	52.6	27.7	49.9	26.9	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.2	6.9	-30.8	36.3	3.9	2.0	-33.6	37.8	-35.8	38.9	-38.0	40.1	-40.8	41.5		
(5)			-30.9	20.9	3.8	3.1	-33.7	23.2	-35.9	25.0	-38.0	26.7	-40.7	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	6.3	-5.8	-4.4	1.2	5.8	10.7	15.1	20.1	18.9	13.6	6.5	-0.8	-6.2	(6)
(7)		DBStd	10.52	7.09	7.10	5.94	4.31	4.04	3.72	2.93	2.94	4.32	4.93	6.66	6.89	(7)
(8)		HDD10.0	2318	488	402	274	138	41	5	0	0	16	127	324	503	(8)
(9)		HDD18.3	4533	747	636	531	377	239	108	16	29	149	368	573	762	(9)
(10)		CDD10.0	964	0	0	2	11	62	157	314	276	124	18	1	0	(10)
(11)		CDD18.3	137	0	0	0	0	1	11	72	46	8	0	0	0	(11)
(12)		CDH23.3	2966	0	0	0	6	72	304	1275	986	308	15	0	0	(12)
(13)		CDH26.7	1206	0	0	0	0	12	101	578	409	103	2	0	0	(13)
(14)	Wind	WSAvg	2.5	2.1	2.4	2.8	3.1	2.9	2.7	2.6	2.6	2.5	2.5	2.2	2.1	(14)
(15)	Precipitation	PrecAvg	368	16	12	23	34	62	62	29	31	35	28	19	14	(15)
(16)		PrecMax	509	43	39	60	81	158	185	117	83	80	80	58	32	(16)
(17)		PrecMin	220	2	2	7	6	10	7	2	0	0	0	4	2	(17)
(18)		PrecStd	74	11	9	11	17	28	34	26	18	22	18	12	8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.7	13.0	19.8	24.1	28.4	33.0	36.7	35.4	32.5	25.3	18.2	10.9	(19)
(20)			MCWB	3.8	5.4	8.5	10.8	13.8	15.6	16.9	16.3	15.2	11.4	8.5	4.9	(20)
(21)		2%	DB	7.5	9.8	16.0	21.1	25.5	29.6	34.1	32.7	29.7	21.7	14.4	7.5	(21)
(22)			MCWB	2.9	3.9	6.8	9.7	13.0	15.9	16.3	16.0	14.0	10.6	6.5	3.0	(22)
(23)		5%	DB	5.4	7.0	13.2	17.8	22.7	26.8	32.1	30.9	27.1	18.5	11.4	5.4	(23)
(24)			MCWB	1.6	2.5	5.5	8.3	12.1	15.2	16.2	15.3	13.4	9.2	5.3	1.7	(24)
(25)		10%	DB	3.6	4.8	10.2	14.8	20.0	24.3	30.1	29.0	24.1	15.6	8.5	3.3	(25)
(26)			MCWB	0.5	1.1	4.1	7.0	11.1	14.1	15.8	14.9	12.5	7.9	3.8	0.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.5	6.1	9.0	12.0	15.2	18.4	20.2	20.1	17.0	13.1	9.3	5.2	(27)
(28)			MCDWB	8.5	12.0	18.1	22.2	24.5	29.0	30.4	26.9	26.4	22.8	17.0	10.1	(28)
(29)		2%	WB	3.0	4.2	7.2	10.1	13.9	16.8	18.3	17.2	15.4	11.0	7.0	3.4	(29)
(30)			MCDWB	6.7	9.0	14.9	19.5	23.1	27.0	29.1	28.3	26.2	19.8	13.3	7.1	(30)
(31)		5%	WB	1.8	2.8	5.8	8.7	12.7	15.6	17.5	16.2	14.1	9.8	5.6	1.9	(31)
(32)			MCDWB	4.8	6.6	12.4	16.8	21.4	24.9	28.1	27.3	24.3	17.4	10.8	4.9	(32)
(33)		10%	WB	0.7	1.3	4.5	7.4	11.5	14.7	16.7	15.5	13.0	8.3	4.0	0.6	(33)
(34)			MCDWB	3.3	4.4	9.9	14.1	19.1	23.1	27.6	26.5	23.0	14.8	8.3	3.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.9	11.6	12.9	13.8	14.4	15.5	19.2	19.4	17.4	14.7	12.2	11.0	(35)
(36)			MCDBR	12.0	13.3	17.4	19.9	19.9	20.7	22.2	22.8	22.8	20.4	15.9	11.4	(36)
(37)			MCWBR	8.3	8.4	9.5	10.1	9.4	9.3	8.1	8.7	9.6	10.6	9.4	7.8	(37)
(38)		5% WB	MCDBR	11.5	12.5	16.0	18.4	18.0	18.5	19.2	19.9	20.3	18.8	14.9	10.9	(38)
(39)			MCWBR	8.2	8.2	9.0	9.5	8.7	8.8	8.0	8.1	8.9	9.9	9.0	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.244	0.253	0.273	0.310	0.320	0.329	0.336	0.344	0.320	0.284	0.258	0.241	(40)	
(41)		taud	2.439	2.432	2.508	2.434	2.478	2.484	2.490	2.432	2.489	2.571	2.548	2.474	(41)	
(42)		Ebn at Noon	889	946	971	951	947	936	924	904	902	898	869	856	(42)	
(43)		Edh at Noon	67	83	90	106	106	106	104	106	91	72	61	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.61	2.58	3.76	4.79	5.49	6.55	7.06	6.02	4.50	2.81	1.71	1.27	(44)	
(45)		RadStd	0.14	0.18	0.25	0.32	0.53	0.51	0.33	0.34	0.39	0.23	0.16	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	-0.64	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)		N/A	N/A	N/A	N/A	N/A	-0.58	N/A	N/A	N/A	N/A

Nomenclature: See separate page