

BOISE, ID, USA

WMO: 726810

Lat: 43.567N

Lon: 116.241W

Elev: 858

StdP: 91.44

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24131

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-11.5	-8.7	-15.8	1.0	-9.6	-13.2	1.3	-5.2	11.1	6.3	9.9	5.2	2.0	130	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	37.0	17.6	35.5	17.2	33.9	16.6	18.9	33.3	18.2	32.4	17.4	31.5	4.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.2	11.2	21.8	12.8	10.2	22.1	11.6	9.5	21.6	56.8	33.0	54.3	32.4	52.0	31.3	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.5	7.6	-14.1	40.1	3.9	1.5	-16.9	41.2	-19.1	42.1	-21.3	43.0	-24.1	44.1		
(5)			-14.6	20.4	3.6	1.0	-17.2	21.1	-19.3	21.7	-21.4	22.2	-24.0	23.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	0.2	3.0	7.3	10.4	15.2	20.0	25.5	24.4	19.1	11.6	4.9	0.1
	DBStd	9.61	4.39	3.84	3.70	3.96	4.45	4.34	3.39	3.43	4.36	4.40	4.56	4.65
	HDD10.0	1151	304	197	101	42	7	0	0	0	1	31	160	308
	HDD18.3	2951	562	429	343	240	117	32	2	3	44	212	402	566
	CDD10.0	1832	0	1	16	53	170	299	481	447	273	82	8	1
	CDD18.3	590	0	0	0	2	21	81	224	192	66	4	0	0
	CDH23.3	7790	0	0	1	38	313	1106	3048	2428	794	62	0	0
	CDH26.7	3950	0	0	0	7	99	502	1728	1282	318	14	0	0
Wind	WSAvg	3.3	2.9	3.4	3.9	3.9	3.6	3.5	3.2	3.1	3.1	3.1	3.0	3.1
Precipitation	PrecAvg	295	36	25	33	31	31	19	8	7	16	20	34	36
	PrecMax	477	98	94	88	71	112	53	41	60	74	66	85	107
	PrecMin	169	5	5	4	5	0	0	0	0	0	0	4	2
	PrecStd	65	20	17	20	16	25	15	9	11	15	14	17	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.4	15.4	21.7	27.5	32.5	37.0	39.8	38.3	34.9	28.6	18.6	13.4
		MCWB	6.9	8.3	10.2	13.3	15.6	17.7	18.5	17.6	16.8	13.5	9.9	7.8
	2%	DB	9.2	12.7	18.8	23.6	29.4	34.3	37.6	36.4	32.4	24.8	15.5	10.6
		MCWB	5.5	7.1	9.2	11.8	14.8	16.4	17.7	17.3	15.9	12.5	8.8	6.6
	5%	DB	7.4	10.7	16.3	20.8	26.9	31.9	36.2	34.9	30.4	21.9	13.5	8.4
		MCWB	4.4	5.8	8.3	10.5	13.7	15.8	17.5	16.9	15.2	11.5	7.8	5.2
	10%	DB	6.0	9.0	14.1	18.1	24.3	29.6	34.6	33.2	28.2	19.2	11.4	6.3
		MCWB	3.5	4.9	7.2	9.4	13.0	15.1	17.0	16.4	14.3	10.3	6.7	3.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	9.1	11.1	14.0	16.9	19.0	20.1	19.4	19.1	15.0	11.5	8.6
		MCDB	10.3	13.9	18.5	25.0	29.0	33.9	34.8	34.1	28.7	25.0	16.3	11.8
	2%	WB	5.9	7.5	10.0	12.5	15.6	17.6	19.1	18.5	17.4	13.5	9.8	7.0
		MCDB	8.5	11.9	16.9	21.7	26.6	31.3	34.0	33.3	28.0	22.5	14.2	10.4
	5%	WB	4.8	6.4	9.0	11.2	14.6	16.6	18.5	17.7	16.1	12.1	8.4	5.6
		MCDB	7.1	10.2	15.3	19.1	24.7	29.3	33.3	32.3	28.0	20.5	12.6	8.0
	10%	WB	3.6	5.3	7.9	10.0	13.6	15.6	17.7	17.0	15.0	10.8	7.2	4.1
		MCDB	5.7	8.4	13.5	17.2	22.9	27.6	32.2	31.1	26.9	18.1	11.0	6.2
Mean Daily Temperature Range	5% DB	MDBR	6.8	8.7	10.7	11.9	13.0	14.4	16.3	15.7	14.4	12.1	8.9	6.7
		MCDBR	8.1	10.5	14.0	16.0	16.7	17.6	17.6	17.2	16.6	15.0	11.1	8.0
		MCWBR	5.4	6.2	7.2	7.3	6.5	6.2	6.2	6.3	6.8	6.7	6.1	5.2
	5% WB	MCDBR	7.6	9.7	12.2	14.2	14.9	16.1	16.2	15.7	15.0	13.4	9.9	7.3
		MCWBR	5.3	6.0	6.7	6.8	6.0	5.8	5.8	6.0	6.2	6.4	5.8	5.1
Clear-Sky Solar Irradiance	taub	0.262	0.272	0.285	0.310	0.330	0.327	0.339	0.341	0.317	0.290	0.274	0.264	
	taud	2.559	2.585	2.570	2.489	2.453	2.490	2.463	2.437	2.507	2.580	2.568	2.556	
	Ebn at Noon	896	945	966	958	941	941	925	913	915	907	871	859	
	Edh at Noon	65	75	87	102	110	106	108	107	92	75	64	60	
All-Sky Solar Radiation	RadAvg	1.61	2.62	3.91	5.45	6.62	7.55	7.74	6.67	5.19	3.40	1.99	1.32	
	RadStd	0.22	0.34	0.40	0.43	0.48	0.41	0.29	0.29	0.29	0.25	0.16	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-1.22	N/A	N/A	N/A	N/A	N/A	+91	+63
(47) Regional (13 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page