

MOUNTAIN HOME AFB, ID, USA

WMO: 726815

Lat: 43.050N

Lon: 115.867W

Elev: 913

StdP: 90.82

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24106

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-13.9	-10.5	-16.4	1.0	-12.0	-13.5	1.3	-5.3	14.4	1.6	12.8	1.7	2.4	90	0.631

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	37.7	17.1	36.1	16.7	34.5	16.2	18.7	32.8	17.8	32.2	17.1	31.5	4.2	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.8	11.7	20.1	13.0	10.4	19.4	11.8	9.7	19.7	56.1	32.6	53.4	32.3	51.1	31.2	24.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	11.0	9.6	DB	-17.4	40.4	4.1	1.4	-20.4	41.5	-22.8	42.3	-25.1	43.1	-28.1	44.1	(4)
(5)			WB	-17.8	20.2	4.2	1.4	-20.8	21.2	-23.3	22.1	-25.6	22.8	-28.7	23.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	-0.7	2.1	6.4	9.4	14.6	19.5	25.0	24.0	18.3	10.7	4.0	-1.4	(6)	
	DBStd	9.82	4.68	4.00	3.59	4.01	4.28	4.36	3.17	3.19	4.12	4.38	4.83	4.85	(7)	
	HDD10.0	1329	332	222	122	59	10	1	0	0	1	43	186	353	(8)	
	HDD18.3	3188	591	455	370	270	129	37	2	3	49	240	431	612	(9)	
	CDD10.0	1706	0	1	10	39	152	286	464	433	251	64	5	0	(10)	
	CDD18.3	524	0	0	0	1	13	73	207	177	49	3	0	0	(11)	
	CDH23.3	8109	0	0	1	52	327	1226	3070	2524	840	69	0	0	(12)	
	CDH26.7	4315	0	0	0	11	106	592	1812	1419	359	16	0	0	(13)	
(14) Wind	WSAvg	4.3	4.2	4.8	4.9	5.0	4.6	4.5	4.1	3.9	3.7	4.0	4.2	4.4	(14)	
(15) Precipitation	PrecAvg	230	27	16	25	21	28	17	5	5	9	19	21	34	(15)	
	PrecMax	343	55	47	81	49	100	50	14	16	21	57	48	103	(16)	
	PrecMin	123	4	2	1	5	1	2	0	0	0	0	0	7	(17)	
	PrecStd	63	15	11	17	10	24	13	4	5	7	15	12	22	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.1	15.7	21.9	28.1	32.5	38.3	39.6	38.9	35.3	28.8	19.0	12.5	(19)	
		MCWB	6.5	9.1	10.1	13.3	15.0	17.8	17.9	17.5	16.4	14.0	10.3	7.8	(20)	
	2%	DB	8.3	12.6	18.7	24.3	29.7	35.0	38.0	37.1	32.7	25.3	16.0	9.4	(21)	
		MCWB	5.2	7.0	9.0	11.7	14.2	16.6	17.2	17.1	15.4	12.3	8.9	6.4	(22)	
	5%	DB	6.6	10.2	16.2	21.3	27.2	32.5	36.8	35.5	30.9	22.2	13.2	7.3	(23)	
		MCWB	4.0	5.7	8.1	10.4	13.3	15.6	16.8	16.3	14.8	11.3	7.6	4.9	(24)	
	10%	DB	5.0	8.2	13.9	18.0	24.4	30.2	35.1	33.9	28.7	19.1	11.2	5.2	(25)	
		MCWB	3.1	4.9	7.1	9.1	12.5	14.9	16.5	16.0	14.2	10.1	6.9	3.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	9.6	11.7	14.0	16.1	19.0	20.2	19.8	18.0	15.0	11.9	9.1	(27)	
		MCDB	9.3	13.9	16.3	25.5	28.3	33.9	33.6	33.5	29.9	23.3	15.8	11.0	(28)	
	2%	WB	5.9	8.0	10.3	12.3	15.1	17.6	18.9	18.4	16.6	13.6	9.9	6.9	(29)	
		MCDB	7.7	11.3	16.0	22.4	26.6	32.5	33.6	31.5	28.9	22.3	14.3	8.8	(30)	
	5%	WB	4.6	6.5	9.2	11.0	14.1	16.5	18.0	17.5	15.6	12.2	8.5	5.3	(31)	
		MCDB	6.1	9.4	14.7	19.3	24.6	29.8	32.9	31.8	28.1	20.2	12.5	7.0	(32)	
	10%	WB	3.4	5.2	7.9	9.9	13.1	15.6	17.3	16.8	14.7	10.9	7.2	3.7	(33)	
		MCDB	4.7	7.9	13.3	17.1	22.5	27.6	32.2	31.1	26.8	18.0	10.5	5.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	9.9	12.9	14.3	15.2	16.6	18.4	18.5	17.5	14.9	11.2	8.1	(35)	
		MCDBR	9.3	12.0	16.3	19.8	19.6	20.9	20.7	20.6	20.6	18.3	13.3	9.5	(36)	
	5% WB	MCWBR	6.4	7.3	8.7	9.1	7.8	7.8	7.2	7.4	8.2	8.3	7.5	6.5	(37)	
		MCWBR	8.5	10.9	13.9	16.9	17.1	18.5	18.0	18.2	17.6	15.7	12.2	8.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.260	0.268	0.283	0.314	0.327	0.331	0.341	0.341	0.314	0.287	0.269	0.262	(40)	
		taud	2.578	2.591	2.572	2.465	2.462	2.479	2.463	2.447	2.514	2.584	2.587	2.570	(41)	
	Ebn at Noon		906	952	972	954	944	938	924	915	920	914	885	869	(42)	
		Edh at Noon	64	75	87	105	109	107	108	106	92	75	63	60	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.73	2.68	3.95	5.44	6.58	7.58	7.67	6.64	5.23	3.48	2.08	1.40	(44)	
	RadStd		0.22	0.36	0.39	0.42	0.54	0.46	0.35	0.33	0.29	0.24	0.17	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	-1.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		N/A	N/A	N/A	N/A	-0.40	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page