

JEROME COUNTY AP, ID, USA

WMO: 726816

Lat: 42.727N

Lon: 114.456W

Elev: 4048

StdP: 12.67

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 04110

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.4	10.7	-0.4	6.2	8.7	3.8	7.8	13.4	29.0	25.3	27.7	24.4	11.5	40	0.612

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.9	93.5	63.3	90.8	62.3	88.1	61.4	66.1	87.9	64.3	85.9	62.7	84.0	6.3	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.7	85.7	73.5	55.7	76.8	73.4	53.9	71.9	72.6	32.9	87.9	31.4	85.8	30.1	83.7	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.5	24.7	21.5	0.5	99.4	5.8	2.5	-3.7	101.2	-7.1	102.7	-10.3	104.1	-14.5	105.9		
			0.1	71.1	5.9	3.0	-4.2	73.3	-7.6	75.0	-11.0	76.7	-15.3	78.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.5	27.5	31.6	41.0	47.1	55.6	65.2	74.3	71.1	62.4	50.0	38.5	28.1
	DBStd	17.56	8.41	8.04	7.31	7.37	7.99	7.66	5.17	5.62	7.49	8.40	9.00	8.33
	HDD50	2823	696	515	291	142	35	2	0	0	6	104	354	678
	HDD65	6337	1161	934	744	539	305	92	5	17	134	468	795	1143
	CDD50	2631	0	0	12	54	210	458	754	654	378	103	8	0
	CDD65	672	0	0	0	1	15	97	294	206	56	3	0	0
	CDH74	8296	0	0	0	25	274	1323	3476	2388	747	63	0	0
	CDH80	3540	0	0	0	4	64	500	1701	1035	226	10	0	0
(14) Wind	WSAvg	9.8	11.4	11.6	11.3	11.4	10.1	9.4	7.6	7.2	7.9	9.2	10.4	10.7
(15) Precipitation	PrecAvg	10.6	1.3	0.9	1.1	0.9	1.1	0.8	0.2	0.4	0.5	0.7	1.3	1.4
	PrecMax	18.0	4.1	4.6	2.9	2.9	4.8	2.7	1.0	3.4	2.2	2.3	3.3	5.2
	PrecMin	4.8	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.9	0.9	0.8	0.7	0.6	0.9	0.7	0.2	0.6	0.5	0.6	0.8	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.0	56.1	69.7	77.4	86.3	94.4	97.9	95.4	90.4	80.8	66.2	51.4
		MCWB	41.9	44.4	48.7	52.6	57.5	62.8	65.1	63.2	60.2	54.8	49.5	43.5
	2%	DB	43.9	50.4	63.3	71.5	81.1	89.6	94.8	91.9	85.7	74.4	60.3	45.7
		MCWB	38.3	41.7	46.6	50.2	57.0	61.1	63.7	62.3	59.2	52.4	46.5	40.0
	5%	DB	40.2	46.2	58.2	66.1	76.5	85.6	92.1	89.5	82.3	69.3	55.3	42.5
		MCWB	35.9	39.3	44.4	48.7	54.7	59.2	63.3	61.9	57.6	50.7	44.3	37.8
	10%	DB	37.3	42.8	53.9	61.4	72.0	82.0	89.6	86.3	78.7	64.0	51.3	39.0
		MCWB	34.1	37.6	42.7	46.5	53.3	58.4	62.1	61.1	56.3	48.2	42.4	35.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.7	45.4	50.4	54.8	60.7	66.0	70.2	67.7	64.8	56.8	51.0	44.1
		MCDB	48.8	54.5	64.4	73.6	78.6	88.2	90.2	89.2	82.1	76.3	61.9	49.6
	2%	WB	39.0	42.7	47.8	51.9	58.0	62.6	67.0	65.2	61.8	54.2	47.7	41.1
		MCDB	42.9	49.0	60.9	67.9	75.8	84.7	89.5	86.2	79.2	69.1	58.3	45.4
	5%	WB	36.4	40.5	45.7	49.5	56.0	60.6	65.0	63.6	59.6	52.1	45.3	38.3
		MCDB	39.6	45.7	56.8	63.1	73.3	82.0	87.5	84.3	77.7	65.5	53.7	41.5
	10%	WB	34.5	37.7	43.5	47.7	54.2	59.0	63.4	62.0	57.3	49.9	43.3	36.0
		MCDB	37.3	42.1	52.8	60.1	69.8	79.4	86.0	82.5	75.7	62.5	50.5	38.9
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	14.5	19.4	22.0	23.8	26.7	28.9	28.4	26.7	22.4	18.0	12.2
		MCDBR	14.4	18.2	26.1	29.3	30.4	32.1	31.7	31.7	31.0	29.0	23.5	14.7
		MCWBR	10.3	11.7	13.7	14.2	12.8	13.0	14.3	14.3	14.3	13.7	13.1	10.2
	5% WB	MCDBR	13.2	17.0	23.8	26.0	27.5	29.9	29.5	29.4	28.3	25.0	21.6	13.5
		MCWBR	10.0	11.5	13.1	13.2	11.8	12.6	14.4	14.1	13.6	12.5	12.4	9.8
(40) Clear-Sky Solar Irradiance	taub		0.250	0.260	0.275	0.295	0.313	0.311	0.325	0.324	0.300	0.277	0.259	0.250
	taud		2.558	2.586	2.572	2.512	2.484	2.528	2.495	2.479	2.545	2.592	2.593	2.568
	Ebn at Noon		292	306	311	310	304	304	298	296	298	294	286	282
	Edh at Noon		21	24	28	32	34	32	33	33	28	23	20	19
(44) All-Sky Solar Radiation	RadAvg		570	842	1276	1734	2080	2416	2395	2078	1660	1125	686	455
	RadStd		67	106	110	121	188	167	131	107	101	77	59	65

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	N/A	-0.72	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page