

JEROME COUNTY AP, ID, USA

WMO: 726816

Lat: 42.727N

Lon: 114.456W

Elev: 1234

StdP: 87.35

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 04110

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.2	-11.8	-18.0	0.9	-12.9	-15.7	1.1	-10.3	13.0	-3.7	12.4	-4.2	5.1	40	0.612

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	34.2	17.4	32.7	16.8	31.2	16.3	19.0	31.0	17.9	30.0	17.0	28.9	2.8	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.8	12.2	23.1	13.2	11.0	23.0	12.2	10.3	22.5	58.7	31.0	55.1	29.9	52.2	28.7	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	11.0	9.6	-17.5	37.4	3.2	1.4	-19.8	38.4	-21.7	39.3	-23.5	40.0	-25.8	41.0		
(5)			-17.7	21.7	3.3	1.7	-20.1	22.9	-22.0	23.9	-23.9	24.9	-26.3	26.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.7	-2.5	-0.2	5.0	8.4	13.1	18.4	23.5	21.7	16.9	10.0	3.6	-2.2	(6)
(7)		DBStd	9.75	4.67	4.47	4.06	4.10	4.44	4.26	2.87	3.12	4.16	4.67	5.00	4.63	(7)
(8)		HDD10.0	1568	387	286	162	79	19	1	0	0	3	58	197	377	(8)
(9)		HDD18.3	3521	645	519	413	299	169	51	3	9	74	260	442	635	(9)
(10)		CDD10.0	1462	0	0	7	30	117	254	419	363	210	57	4	0	(10)
(11)		CDD18.3	373	0	0	0	1	8	54	163	114	31	2	0	0	(11)
(12)		CDH23.3	4609	0	0	0	14	152	735	1931	1327	415	35	0	0	(12)
(13)		CDH26.7	1967	0	0	0	2	36	278	945	575	126	6	0	0	(13)
(14)	Wind	WSAvg	4.4	5.1	5.2	5.0	5.1	4.5	4.2	3.4	3.2	3.6	4.1	4.6	4.8	(14)
(15)	Precipitation	PrecAvg	268	33	24	29	24	27	20	6	9	12	17	32	36	(15)
(16)		PrecMax	457	103	117	73	73	123	69	25	86	56	59	83	133	(16)
(17)		PrecMin	123	2	1	1	0	0	0	0	0	0	0	1	0	(17)
(18)		PrecStd	73	23	21	17	16	23	18	6	14	13	14	21	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.5	13.4	21.0	25.2	30.2	34.7	36.6	35.2	32.4	27.1	19.0	10.8	(19)
(20)			MCWB	5.5	6.9	9.3	11.5	14.2	17.1	18.4	17.3	15.7	12.7	9.7	6.4	(20)
(21)		2%	DB	6.6	10.2	17.4	21.9	27.3	32.0	34.9	33.3	29.8	23.5	15.7	7.6	(21)
(22)			MCWB	3.5	5.4	8.1	10.1	13.9	16.2	17.6	16.8	15.1	11.3	8.0	4.4	(22)
(23)		5%	DB	4.6	7.9	14.5	18.9	24.7	29.8	33.4	31.9	27.9	20.7	12.9	5.8	(23)
(24)			MCWB	2.2	4.1	6.9	9.3	12.6	15.1	17.4	16.6	14.2	10.4	6.8	3.2	(24)
(25)		10%	DB	3.0	6.0	12.2	16.3	22.2	27.8	32.0	30.2	25.9	17.8	10.7	3.9	(25)
(26)			MCWB	1.2	3.1	5.9	8.0	11.8	14.7	16.7	16.1	13.5	9.0	5.8	2.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.5	7.4	10.2	12.7	15.9	18.9	21.2	19.8	18.2	13.8	10.5	6.7	(27)
(28)			MCDWB	9.3	12.5	18.0	23.1	25.9	31.2	32.3	31.8	27.9	24.6	16.6	9.8	(28)
(29)		2%	WB	3.9	5.9	8.8	11.1	14.5	17.0	19.4	18.4	16.5	12.4	8.7	5.1	(29)
(30)			MCDWB	6.1	9.5	16.0	19.9	24.3	29.3	31.9	30.1	26.2	20.6	14.6	7.5	(30)
(31)		5%	WB	2.5	4.7	7.6	9.7	13.4	15.9	18.3	17.5	15.3	11.2	7.4	3.5	(31)
(32)			MCDWB	4.2	7.6	13.8	17.3	22.9	27.8	30.8	29.0	25.4	18.6	12.0	5.3	(32)
(33)		10%	WB	1.4	3.1	6.4	8.7	12.3	15.0	17.5	16.7	14.0	9.9	6.3	2.2	(33)
(34)			MCDWB	2.9	5.6	11.5	15.6	21.0	26.3	30.0	28.1	24.3	17.0	10.3	3.8	(34)
(35)	Mean Daily Temperature Range	MDBR		6.7	8.0	10.8	12.2	13.2	14.9	16.0	15.8	14.8	12.4	10.0	6.8	(35)
(36)		5% DB	MCDBR	8.0	10.1	14.5	16.3	16.9	17.9	17.6	17.6	17.2	16.1	13.1	8.2	(36)
(37)			MCWBR	5.7	6.5	7.6	7.9	7.1	7.2	7.9	7.9	8.0	7.6	7.3	5.7	(37)
(38)		5% WB	MCDWB	7.3	9.4	13.2	14.4	15.3	16.6	16.4	16.3	15.7	13.9	12.0	7.5	(38)
(39)			MCWBR	5.6	6.4	7.3	7.3	6.6	7.0	8.0	7.8	7.6	6.9	6.9	5.4	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.250	0.260	0.275	0.295	0.313	0.311	0.325	0.324	0.300	0.277	0.259	0.250	(40)
(41)		taud		2.558	2.586	2.572	2.512	2.484	2.528	2.495	2.479	2.545	2.592	2.593	2.568	(41)
(42)		Ebn at Noon		921	964	981	976	959	958	940	933	939	928	902	890	(42)
(43)		Edh at Noon		66	76	87	100	106	102	105	103	89	74	63	60	(43)
(44)	All-Sky Solar Radiation	RadAvg		1.80	2.65	4.02	5.47	6.56	7.62	7.55	6.55	5.23	3.54	2.16	1.44	(44)
(45)		RadStd		0.21	0.33	0.35	0.38	0.59	0.53	0.41	0.34	0.32	0.24	0.18	0.20	(45)

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	-0.40	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page