

REXBURG MADISON COUNTY AP, ID, USA

WMO: 726818

Lat: 43.832N

Lon: 111.808W

Elev: 4862

StdP: 12.29

Time Zone: -7.00 (NAM)

Period: 99-19

WBAN: 94194

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.0	-0.7	-11.6	3.5	-5.9	-6.4	4.7	0.5	26.5	32.7	23.9	32.0	3.7	50	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.8	90.6	60.5	88.1	59.9	85.0	58.9	63.9	83.7	62.3	82.1	60.8	80.3	8.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.9	82.7	69.8	54.8	76.7	69.0	53.4	72.6	68.1	31.5	84.1	30.3	81.9	29.1	80.1	70.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.6	20.6	18.1	DB	-14.4	95.3	6.4	2.3	-19.1	97.0	-22.8	98.3	-26.4	99.6	-31.1	101.2
			WB	-14.9	66.7	6.2	1.7	-19.3	67.9	-22.9	68.9	-26.4	69.9	-30.9	71.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	44.0	19.8	23.4	34.8	43.8	52.5	60.5	68.9	66.8	57.5	44.8	32.6	21.5	(6)
(7)		DBStd	18.56	9.74	9.45	8.53	6.93	7.18	6.66	4.33	4.76	6.84	7.73	9.03	9.96	(7)
(8)		HDD50	4046	936	745	473	206	58	7	0	0	18	197	522	884	(8)
(9)		HDD65	7923	1401	1165	935	635	391	160	16	35	236	628	972	1349	(9)
(10)		CDD50	1867	0	0	2	21	135	323	587	521	243	34	1	0	(10)
(11)		CDD65	268	0	0	0	0	2	26	138	91	11	0	0	0	(11)
(12)		CDH74	5674	0	0	0	8	151	713	2369	1927	489	17	0	0	(12)
(13)		CDH80	2076	0	0	0	0	23	199	981	754	117	2	0	0	(13)
(14)	Wind	WSAvg	7.0	5.1	6.3	8.2	9.2	8.4	8.1	6.9	6.7	6.6	6.8	6.6	5.7	(14)
(15)	Precipitation	PrecAvg	13.4	0.9	0.8	0.8	1.2	1.5	1.9	0.7	0.9	1.1	1.2	1.2	1.2	(15)
(16)		PrecMax	17.8	2.0	2.5	1.3	3.4	3.4	3.5	1.5	3.8	2.5	2.2	2.2	2.1	(16)
(17)		PrecMin	7.6	0.0	0.1	0.0	0.2	0.6	0.3	0.0	0.1	0.0	0.1	0.3	0.1	(17)
(18)		PrecStd	2.9	0.6	0.6	0.4	0.9	0.8	1.1	0.6	0.9	0.8	0.7	0.5	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.1	47.6	65.3	74.4	82.9	89.8	94.5	93.2	88.1	76.0	61.8	45.9	(19)
(20)			MCWB	36.0	39.7	46.2	50.4	56.3	59.9	62.7	60.2	58.3	52.3	45.8	39.4	(20)
(21)		2%	DB	36.9	42.2	59.0	69.0	78.6	85.3	91.3	90.3	83.3	70.0	54.9	41.2	(21)
(22)			MCWB	34.0	36.3	43.6	48.2	54.4	59.1	61.4	59.5	56.2	50.6	43.3	36.8	(22)
(23)		5%	DB	34.5	38.8	53.2	63.8	73.6	81.8	89.0	87.7	79.9	64.7	50.4	37.3	(23)
(24)			MCWB	32.7	34.3	41.5	46.0	52.8	58.8	61.2	58.7	54.8	48.5	41.4	34.1	(24)
(25)		10%	DB	32.6	36.2	48.3	59.3	69.6	78.4	85.9	84.3	75.7	60.5	45.9	34.5	(25)
(26)			MCWB	31.1	32.9	39.3	44.2	51.0	57.2	60.4	57.9	53.7	46.4	39.1	32.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.4	40.8	47.4	52.3	59.1	63.6	66.5	64.3	60.8	54.9	47.3	40.8	(27)
(28)			MDCB	39.2	46.7	61.5	70.9	77.3	82.9	87.0	86.0	77.8	71.9	57.1	45.1	(28)
(29)		2%	WB	34.7	37.3	44.8	49.1	56.2	61.4	64.8	62.4	58.6	52.3	44.4	37.3	(29)
(30)			MDCB	36.4	41.0	57.0	65.4	73.8	81.2	84.7	82.5	77.3	65.2	53.8	40.5	(30)
(31)		5%	WB	33.1	35.2	42.3	47.2	54.0	59.5	63.3	60.8	56.8	50.1	41.9	34.7	(31)
(32)			MDCB	34.3	37.8	51.8	62.0	71.0	79.2	83.1	80.6	75.1	62.3	49.2	37.1	(32)
(33)		10%	WB	31.3	33.2	40.0	45.1	52.0	57.8	61.9	59.5	54.9	47.7	39.6	32.6	(33)
(34)			MDCB	32.5	35.7	47.4	57.2	67.0	76.3	81.8	79.2	71.9	58.7	45.6	34.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.9	16.2	19.3	22.9	25.2	27.7	32.8	33.5	30.4	24.3	18.4	14.5	(35)
(36)			MCDBR	13.9	16.2	26.5	32.8	33.7	34.9	37.1	38.6	38.3	33.2	26.1	14.5	(36)
(37)			MCWBR	11.7	11.5	14.2	15.6	14.4	14.2	13.4	13.5	15.7	16.8	15.7	11.0	(37)
(38)		5% WB	MCDBR	12.4	13.0	23.9	29.4	30.4	32.0	32.9	32.7	28.7	23.4	13.0	(38)	
(39)			MCWBR	10.7	9.7	13.5	14.5	13.4	13.6	13.1	12.3	13.7	15.0	14.6	10.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.240	0.252	0.268	0.303	0.312	0.316	0.334	0.331	0.304	0.277	0.258	0.242	(40)	
(41)		taud	2.385	2.386	2.504	2.450	2.496	2.509	2.470	2.452	2.531	2.590	2.547	2.455	(41)	
(42)		Ebn at Noon	289	304	312	306	304	302	295	292	295	292	282	279	(42)	
(43)		Edh at Noon	23	29	29	34	33	33	34	33	28	23	20	20	(43)	
(44)	All-Sky Solar Radiation	RadAvg	509	800	1212	1636	1944	2282	2371	2023	1564	1005	599	411	(44)	
(45)		RadStd	62	94	101	122	190	187	109	110	117	77	57	51	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page