

STANLEY RANGER STATION, ID, USA

WMO: 726824

Lat: 44.171N

Lon: 114.927W

Elev: 6495

StdP: 11.56

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 04112

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.3	-10.9	-21.2	2.2	-16.0	-15.9	2.9	-10.6	16.8	28.6	14.8	29.1	0.8	100	0.667

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.0	85.2	54.7	82.7	53.8	79.9	52.9	57.2	77.1	55.7	76.7	54.5	75.3	7.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
51.5	72.2	59.0	48.2	63.6	57.8	45.6	57.6	57.0	27.2	76.6	26.1	76.8	25.2	75.2	63.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.8	12.0	10.6	DB	-25.4	89.8	4.7	2.2	-28.8	91.3	-31.5	92.6	-34.2	93.8	-37.6	95.4	(4)
(5)			WB	-25.7	60.5	4.5	1.7	-28.9	61.7	-31.6	62.6	-34.1	63.6	-37.4	64.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	36.8	15.9	19.7	27.3	34.0	43.4	51.4	59.3	57.1	49.2	38.7	26.7	17.3
	DBStd	17.12	11.77	9.86	8.42	7.26	6.53	6.40	4.74	4.74	6.22	7.32	10.67	13.24
	HDD50	5533	1059	849	704	479	219	58	2	7	86	353	700	1017
	HDD65	10319	1523	1269	1169	929	670	409	184	248	474	816	1150	1478
	CDD50	702	1	0	0	0	14	101	290	226	62	3	1	4
	CDD65	10	0	0	0	0	0	1	7	2	0	0	0	0
	CDH74	2324	0	0	0	0	13	216	1161	780	151	3	0	0
	CDH80	563	0	0	0	0	1	43	325	172	22	0	0	0
Wind	WSAvg	3.4	2.4	3.2	3.9	3.9	4.0	4.2	4.0	3.8	3.4	3.0	2.8	2.8
Precipitation	PrecAvg	12.5	1.3	0.9	1.1	1.2	1.5	1.1	0.5	0.7	1.0	1.0	1.5	
	PrecMax	20.2	3.1	3.5	3.0	2.2	3.3	3.3	1.1	3.0	2.0	4.9	1.8	4.7
	PrecMin	5.0	0.1	0.1	0.2	0.1	0.2	0.1	0.0	0.0	0.1	0.2	0.2	0.1
	PrecStd	3.4	0.9	0.8	0.7	0.5	0.9	0.9	0.3	0.6	0.5	0.9	0.5	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.2	46.5	55.5	65.5	75.7	85.4	89.5	87.2	83.1	70.8	60.5	63.4
		MCWB	36.0	34.8	38.8	44.2	50.0	56.2	57.1	55.1	52.9	48.5	40.0	39.4
	2%	DB	38.4	41.0	50.0	59.7	70.9	79.7	86.2	84.1	78.2	64.3	52.6	49.8
		MCWB	33.1	33.2	36.9	41.7	48.4	53.7	55.5	53.7	51.0	45.2	38.6	34.3
	5%	DB	35.6	37.5	45.3	54.9	66.6	75.6	83.8	81.8	74.6	59.8	46.5	38.7
		MCWB	32.3	31.9	34.8	39.7	46.9	51.7	54.4	53.0	49.6	43.3	36.5	33.4
	10%	DB	32.5	34.6	41.2	49.2	62.5	72.0	81.2	78.9	70.7	54.2	41.2	35.2
		MCWB	30.1	30.6	33.2	37.3	45.5	50.3	53.8	52.2	48.3	41.2	34.7	32.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.5	36.9	40.9	45.5	52.8	58.3	59.7	57.9	55.5	50.0	44.5	39.4
		MCDB	44.7	41.6	50.9	63.3	69.1	80.1	77.9	75.5	74.3	66.8	52.1	61.2
	2%	WB	34.4	34.9	38.0	42.5	50.0	55.3	58.0	56.0	53.3	47.2	40.2	36.0
		MCDB	38.4	39.2	46.3	57.1	67.4	75.2	77.9	76.1	72.9	60.4	48.4	44.2
	5%	WB	32.4	33.0	36.3	40.3	48.0	53.2	56.5	54.7	51.3	44.7	37.5	34.2
		MCDB	35.4	36.6	43.5	52.7	64.0	71.9	77.6	76.0	70.5	56.8	45.2	39.5
	10%	WB	30.1	30.6	34.4	38.1	46.1	51.3	55.2	53.4	49.3	42.4	35.2	32.2
		MCDB	32.6	34.7	40.1	47.6	60.3	68.9	76.7	75.0	67.1	52.8	41.0	36.1
Mean Daily Temperature Range	5% DB	MDBR	22.5	24.4	25.1	25.0	28.5	32.8	40.0	40.3	36.7	28.5	23.2	20.1
		MCDBR	20.3	24.4	30.6	36.0	39.8	42.2	45.9	46.1	46.5	39.0	28.0	17.0
		MCWBR	15.8	17.7	19.0	19.7	19.6	19.2	19.4	20.2	22.5	21.5	16.9	10.5
	5% WB	MCDBR	18.1	19.2	24.9	31.9	35.4	37.3	38.9	39.6	40.1	35.0	25.3	14.8
		MCWBR	14.6	14.6	15.6	17.9	17.9	17.2	16.9	17.9	19.7	19.9	16.2	10.4
Clear-Sky Solar Irradiance	taub	0.234	0.244	0.261	0.320	0.313	0.308	0.314	0.320	0.299	0.275	0.250	0.239	
	taud	2.393	2.350	2.362	2.297	2.457	2.511	2.519	2.478	2.554	2.593	2.559	2.435	
	Ebn at Noon	291	306	313	299	303	304	301	296	296	292	285	278	
	Edh at Noon	23	29	33	39	35	33	32	32	28	23	20	20	
All-Sky Solar Radiation	RadAvg	551	852	1251	1670	1938	2254	2365	2030	1573	1022	604	431	
	RadStd	67	105	120	132	187	174	140	116	118	85	53	58	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page