

LEMHI COUNTY AP, ID, USA

WMO: 726865

Lat: 45.117N

Lon: 113.883W

Elev: 4044

StdP: 12.67

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24196

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.5	-0.1	-15.3	2.8	-4.4	-8.1	4.1	-0.3	20.7	34.8	18.1	29.4	1.0	130	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.4	90.8	61.0	88.1	60.6	84.1	59.6	63.9	84.1	62.2	82.7	60.7	80.9	8.1	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.5	79.2	70.7	54.4	73.1	69.0	52.4	67.9	67.6	31.1	83.6	29.9	82.8	28.8	81.1	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years		DB	WB
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 20.1	17.1	13.6		-11.9	96.1	6.3	2.8	-16.4	98.1	-20.1	99.7	-23.6	101.3	-28.2	103.3	(4)
(5)				-12.2	68.1	7.0	2.8	-17.3	70.1	-21.4	71.7	-25.4	73.3	-30.5	75.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.1	20.1	26.3	37.4	44.4	52.8	59.5	68.5	65.9	56.6	44.0	31.8	20.6	
	DBStd	17.94	10.16	9.28	7.28	6.42	6.60	6.58	4.90	4.69	6.39	6.92	8.12	10.07	
	HDD50	3912	928	665	392	188	47	8	0	0	16	211	546	911	
	HDD65	7865	1393	1085	855	617	379	183	23	46	261	652	995	1376	
	CDD50	1757	0	0	2	22	135	294	574	492	213	24	1	0	
	CDD65	234	0	0	0	0	1	20	132	73	8	0	0	0	
	CDH74	4927	0	0	0	10	139	585	2324	1528	331	10	0	0	
	CDH80	1863	0	0	0	0	24	174	1026	563	75	1	0	0	
Wind	WSAvg	3.4	2.0	2.7	4.1	4.8	4.7	4.2	4.2	3.7	2.9	2.9	2.6	2.1	
Precipitation	PrecAvg	10.0	0.7	0.5	0.5	0.8	1.4	1.5	0.9	0.8	0.8	0.6	0.7	0.7	
	PrecMax	14.8	1.5	1.9	1.4	2.6	3.7	4.3	2.5	2.2	2.5	2.4	2.5	2.8	
	PrecMin	6.5	0.1	0.0	0.0	0.1	0.3	0.2	0.0	0.1	0.0	0.0	0.0	0.1	
	PrecStd	2.2	0.4	0.4	0.4	0.6	0.7	0.9	0.7	0.6	0.6	0.6	0.6	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.6	50.4	65.8	75.0	82.4	90.3	96.7	92.7	87.5	74.6	56.7	47.6	
		MCWB	37.4	40.7	47.3	51.7	56.6	61.2	63.1	61.5	60.0	53.6	44.3	39.4	
	2%	DB	38.7	45.4	60.1	70.1	78.7	84.2	92.5	89.8	81.7	66.3	52.1	42.6	
		MCWB	33.8	37.3	43.8	49.5	54.9	59.4	61.6	60.9	57.8	50.1	42.3	36.1	
	5%	DB	36.0	41.8	54.7	63.8	73.1	81.1	90.0	86.2	78.6	62.8	47.6	37.1	
		MCWB	31.9	35.1	41.5	46.6	53.1	58.1	60.9	60.2	56.2	48.2	40.1	32.9	
	10%	DB	33.5	37.4	51.4	58.9	69.4	76.5	86.2	82.3	73.0	57.1	44.6	34.3	
		MCWB	30.7	32.3	40.3	44.2	52.0	56.4	60.3	59.1	54.3	45.2	37.7	31.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.2	41.3	48.0	53.1	59.3	64.3	66.7	66.1	62.5	54.6	46.1	40.5
			MCDB	43.0	48.2	63.3	71.6	75.1	84.6	88.5	84.9	78.8	70.8	54.4	46.7
2%		WB	34.5	38.4	44.8	50.1	56.6	61.2	64.3	63.3	59.8	51.4	43.1	37.0	
		MCDB	38.0	44.2	57.0	66.8	74.0	79.9	84.9	83.1	77.4	64.5	50.5	41.2	
5%		WB	32.2	35.7	42.7	47.8	54.4	59.2	62.7	61.5	57.3	49.0	40.5	33.7	
		MCDB	35.2	41.0	53.2	62.6	70.9	77.6	84.0	81.5	75.1	59.9	47.0	37.0	
10%		WB	30.1	33.3	40.4	45.3	52.4	57.2	61.3	60.0	55.2	46.5	37.7	31.3	
		MCDB	32.4	37.8	49.8	58.2	67.0	74.1	82.9	80.0	71.5	57.1	42.7	34.3	
Mean Daily Temperature Range		5% DB	MDBR	14.9	16.9	21.5	24.6	26.2	27.7	34.4	34.5	31.6	25.1	18.3	14.9
			MCDBR	15.5	18.7	29.4	35.3	36.2	36.6	40.0	40.1	39.3	32.8	23.9	15.5
	MCWBR		12.0	12.4	16.3	18.4	17.4	16.8	16.1	17.9	19.8	18.8	15.6	11.8	
	5% WB	MCDBR	14.5	17.5	27.2	32.8	32.6	33.4	35.5	35.9	36.0	29.8	22.1	14.3	
		MCWBR	11.5	12.0	15.7	17.4	15.9	15.9	15.3	16.9	18.6	17.4	14.9	11.1	
Clear-Sky Solar Irradiance	taub	0.256	0.265	0.286	0.341	0.347	0.341	0.351	0.365	0.333	0.308	0.278	0.259		
	taud	2.400	2.374	2.437	2.337	2.400	2.457	2.459	2.389	2.473	2.510	2.522	2.455		
	Ebn at Noon	278	295	303	292	292	293	289	281	283	276	268	265		
	Edh at Noon	23	28	31	37	36	35	34	35	30	25	20	20		
All-Sky Solar Radiation	RadAvg	522	827	1234	1617	1848	2128	2274	1959	1499	957	572	414		
	RadStd	53	77	83	113	171	172	134	108	126	78	47	39		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	-1.49	N/A	N/A	N/A	N/A

Nomenclature: See separate page