

LEMHI COUNTY AP, ID, USA

WMO: 726865

Lat: 45.117N

Lon: 113.883W

Elev: 1233

StdP: 87.37

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 24196

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.4	-17.8	-26.3	0.4	-20.2	-22.3	0.6	-18.0	9.2	1.6	8.1	-1.4	0.4	130	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.1	32.7	16.1	31.2	15.9	28.9	15.4	17.7	28.9	16.8	28.2	15.9	27.2	3.6	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.6	11.3	21.5	12.4	10.4	20.6	11.3	9.7	19.8	54.5	28.7	51.7	28.2	49.0	27.3	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.0	7.6	6.1	-24.4	35.6	3.5	1.5	-26.9	36.7	-29.0	37.6	-30.9	38.5	-33.4	39.6		
			-24.6	20.1	3.9	1.5	-27.4	21.2	-29.7	22.1	-31.9	22.9	-34.7	24.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.7	-6.6	-3.2	3.0	6.9	11.6	15.3	20.3	18.8	13.6	6.7	-0.1	-6.3
	DBStd	9.97	5.64	5.15	4.04	3.57	3.67	3.66	2.72	2.60	3.55	3.84	4.51	5.59
	HDD10.0	2173	516	369	218	104	26	4	0	0	9	117	303	506
	HDD18.3	4369	774	603	475	343	211	102	13	26	145	362	553	764
	CDD10.0	976	0	0	1	12	75	163	319	273	118	13	1	0
	CDD18.3	130	0	0	0	0	1	11	73	41	4	0	0	0
	CDH23.3	2737	0	0	0	6	77	325	1291	849	184	6	0	0
	CDH26.7	1035	0	0	0	0	13	97	570	313	42	1	0	0
Wind	WSAvg	1.5	0.9	1.2	1.8	2.2	2.1	1.9	1.9	1.7	1.3	1.3	1.2	0.9
Precipitation	PrecAvg	253	17	12	13	21	35	38	24	21	20	15	19	18
	PrecMax	375	39	47	36	65	93	110	64	55	63	61	63	70
	PrecMin	164	2	0	0	2	8	4	0	2	0	0	1	2
	PrecStd	55	9	9	9	15	19	23	19	14	16	14	14	14
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.0	10.2	18.8	23.9	28.0	32.4	36.0	33.7	30.8	23.6	13.7	8.7
		MCWB	3.0	4.9	8.5	10.9	13.7	16.2	17.3	16.4	15.6	12.0	6.9	4.1
	2%	DB	3.7	7.5	15.6	21.1	25.9	29.0	33.6	32.1	27.6	19.1	11.2	5.9
		MCWB	1.0	2.9	6.6	9.7	12.7	15.2	16.4	16.0	14.3	10.1	5.7	2.3
	5%	DB	2.2	5.4	12.6	17.7	22.8	27.3	32.2	30.1	25.9	17.1	8.7	2.8
		MCWB	0.0	1.7	5.3	8.1	11.7	14.5	16.1	15.7	13.5	9.0	4.5	0.5
	10%	DB	0.9	3.0	10.8	15.0	20.8	24.7	30.1	27.9	22.8	14.0	7.0	1.3
		MCWB	-0.7	0.2	4.6	6.8	11.1	13.6	15.7	15.1	12.4	7.3	3.1	-0.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.5	5.2	8.9	11.7	15.1	17.9	19.3	19.0	16.9	12.6	7.9	4.7
		MCDB	6.1	9.0	17.4	22.0	23.9	29.2	31.4	29.4	26.0	21.6	12.5	8.2
	2%	WB	1.4	3.5	7.1	10.1	13.6	16.2	17.9	17.4	15.4	10.8	6.2	2.8
		MCDB	3.3	6.8	13.9	19.3	23.3	26.6	29.4	28.4	25.2	18.1	10.3	5.1
	5%	WB	0.1	2.1	6.0	8.8	12.5	15.1	17.1	16.4	14.1	9.4	4.7	0.9
		MCDB	1.8	5.0	11.8	17.0	21.6	25.3	28.9	27.5	23.9	15.5	8.3	2.8
	10%	WB	-1.0	0.7	4.7	7.4	11.3	14.0	16.3	15.6	12.9	8.0	3.2	-0.4
		MCDB	0.2	3.2	9.9	14.6	19.5	23.4	28.3	26.7	22.0	13.9	5.9	1.3
Mean Daily Temperature Range		MDBR	8.3	9.4	12.0	13.7	14.6	15.4	19.1	19.2	17.5	13.9	10.1	8.3
	5% DB	MCDBR	8.6	10.4	16.3	19.6	20.1	20.3	22.2	22.3	21.8	18.2	13.3	8.6
		MCWBR	6.6	6.9	9.1	10.2	9.7	9.3	9.0	10.0	11.0	10.4	8.7	6.5
	5% WB	MCDBR	8.0	9.7	15.1	18.2	18.1	18.6	19.7	19.9	20.0	16.5	12.3	7.9
		MCWBR	6.4	6.7	8.7	9.7	8.8	8.8	8.5	9.4	10.3	9.7	8.3	6.2
Clear-Sky Solar Irradiance	taub	0.256	0.265	0.286	0.341	0.347	0.341	0.351	0.365	0.333	0.308	0.278	0.259	
	taud	2.400	2.374	2.437	2.337	2.400	2.457	2.459	2.389	2.473	2.510	2.522	2.455	
	Ebn at Noon	875	931	955	919	921	925	910	885	891	870	846	836	
	Edh at Noon	71	89	97	118	115	109	108	111	94	78	64	62	
All-Sky Solar Radiation	RadAvg	1.65	2.61	3.89	5.10	5.83	6.71	7.17	6.18	4.72	3.02	1.80	1.31	
	RadStd	0.17	0.24	0.26	0.36	0.54	0.54	0.42	0.34	0.40	0.25	0.15	0.12	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	N/A	-0.83	N/A	N/A	N/A	N/A

Nomenclature: See separate page