

IDAHO COUNTY AP, ID, USA

WMO: 726873

Lat: 45.943N

Lon: 116.123W

Elev: 3314

StdP: 13.02

Time Zone: -8.00 (NAP)

Period: 96-19

WBAN: 00452

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.0	12.1	1.5	6.7	7.7	8.6	9.7	14.0	33.9	38.8	30.6	38.9	1.7	210	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.8	90.3	62.3	87.8	61.8	84.3	61.2	67.7	84.2	65.1	80.9	62.8	78.8	6.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.3	91.8	76.5	59.0	84.4	73.7	56.6	77.2	70.1	33.8	84.1	31.6	80.8	29.9	78.9	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.7	20.6	17.4	DB	-1.0	96.6	7.7	3.6	-6.5	99.1	-11.0	101.2	-15.3	103.2	-20.9	105.8	(4)
(5)			WB	-1.7	68.4	7.6	2.3	-7.1	70.1	-11.6	71.5	-15.9	72.8	-21.4	74.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.4	31.0	33.4	39.4	44.4	52.4	58.3	67.7	68.2	58.7	46.6	37.3	29.8	(6)	
	DBStd	15.01	8.44	8.22	7.32	6.24	6.53	6.27	5.85	5.57	8.01	7.46	7.68	8.53	(7)	
	HDD50	2818	588	465	332	192	49	9	0	0	16	155	386	626	(8)	
	HDD65	6745	1053	884	793	618	393	213	42	35	220	571	832	1091	(9)	
	CDD50	1855	0	1	4	24	124	259	548	563	278	50	4	0	(10)	
	CDD65	306	0	0	0	0	2	14	125	133	32	0	0	0	(11)	
	CDH74	4696	0	0	0	15	76	263	1858	1947	513	24	0	0	(12)	
	CDH80	1740	0	0	0	1	9	48	726	781	171	4	0	0	(13)	
(14) Wind	WSAvg	5.6	6.4	7.5	6.7	6.3	4.7	4.5	4.1	4.1	4.2	5.5	6.5	6.7	(14)	
(15) Precipitation	PrecAvg	21.0	2.0	1.4	1.9	2.3	2.8	2.2	0.9	0.7	1.0	1.6	2.2	2.1	(15)	
	PrecMax	29.1	3.2	3.0	3.3	3.5	5.4	4.1	3.2	2.1	2.8	2.6	3.6	5.0	(16)	
	PrecMin	16.5	0.9	0.5	0.6	1.1	1.1	1.1	0.2	0.0	0.1	0.6	0.9	0.8	(17)	
	PrecStd	3.7	0.7	0.7	0.7	0.7	1.3	0.7	0.9	0.6	0.8	0.6	0.8	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.5	55.3	64.3	76.6	80.9	85.8	93.5	95.8	90.2	77.9	62.9	52.4	(19)	
		MCWB	43.1	45.1	49.0	57.3	58.8	63.7	64.0	62.8	61.3	56.6	50.1	44.0	(20)	
	2%	DB	46.3	50.6	58.9	68.0	75.1	81.2	90.4	90.5	85.1	69.9	55.6	47.8	(21)	
		MCWB	39.9	43.0	46.8	52.1	57.1	61.7	63.3	61.4	59.7	52.7	45.5	42.0	(22)	
	5%	DB	43.5	46.8	54.5	63.0	71.2	77.2	87.9	87.9	80.7	63.9	52.2	44.8	(23)	
		MCWB	38.1	41.1	45.0	49.6	56.2	59.9	63.0	60.9	58.1	49.7	45.1	39.4	(24)	
	10%	DB	41.2	44.6	50.5	56.7	66.3	72.7	84.4	84.5	75.1	59.3	48.5	41.4	(25)	
		MCWB	37.2	39.4	43.3	46.1	53.3	58.0	62.3	60.5	56.5	48.1	42.9	36.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.6	45.6	51.1	58.3	62.3	67.7	71.3	71.7	67.0	57.6	51.1	44.8	(27)	
		MCDB	48.9	51.4	61.4	72.7	75.8	80.8	88.0	84.6	82.5	74.1	59.1	51.0	(28)	
	2%	WB	40.8	43.8	48.0	53.9	59.3	64.1	68.1	66.9	62.4	54.0	48.1	42.4	(29)	
		MCDB	45.5	49.7	55.9	65.7	71.4	77.3	85.3	83.7	77.3	67.3	55.1	47.0	(30)	
	5%	WB	39.0	41.9	46.0	50.3	56.8	61.6	65.8	63.2	59.6	51.3	45.2	39.5	(31)	
		MCDB	43.3	47.6	53.2	61.1	68.1	75.1	82.6	82.2	75.3	61.3	51.1	44.0	(32)	
	10%	WB	37.3	39.4	43.8	47.5	54.7	59.2	63.7	60.7	57.3	49.2	43.0	37.2	(33)	
		MCDB	40.9	43.9	50.1	56.3	64.8	70.5	79.2	80.8	74.5	57.0	48.0	41.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	12.5	17.3	18.7	21.6	22.0	28.8	30.4	25.8	20.2	14.3	11.9	(35)	
		MCDBR	14.3	16.5	23.7	30.1	29.7	29.8	34.0	34.6	33.3	28.7	19.0	14.3	(36)	
	5% WB	MCWBR	10.0	10.3	13.7	16.0	15.1	14.6	13.9	13.6	14.0	14.3	11.5	9.4	(37)	
		MCWBR	13.8	16.1	21.7	27.8	26.4	27.5	29.4	30.7	29.0	24.3	18.1	12.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.267	0.273	0.300	0.331	0.346	0.343	0.349	0.369	0.338	0.311	0.301	0.266	(40)	
		taud	2.515	2.532	2.511	2.426	2.414	2.445	2.434	2.366	2.440	2.521	2.465	2.525	(41)	
	Ebn at Noon		273	293	298	295	292	292	289	279	279	273	253	261	(42)	
		Edh at Noon	20	24	29	34	36	35	35	36	30	24	21	18	(43)	
(44) All-Sky Solar Radiation	RadAvg		429	698	1054	1505	1827	2102	2371	1994	1461	889	479	331	(44)	
	RadStd		46	79	107	128	155	164	116	116	122	81	42	39	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+128	N/A	(47)	

Nomenclature: See separate page