

IDAHO COUNTY AP, ID, USA

WMO: 726873

Lat: 45.943N

Lon: 116.123W

Elev: 1010

StdP: 89.76

Time Zone: -8.00 (NAP)

Period: 96-19

WBAN: 00452

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-13.9	-11.0	-16.9	1.0	-13.5	-13.0	1.4	-10.0	15.2	3.8	13.7	3.8	0.8	210	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	32.4	16.8	31.0	16.6	29.1	16.2	19.8	29.0	18.4	27.1	17.1	26.0	3.1	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.3	13.1	24.7	15.0	12.1	23.1	13.7	11.0	21.2	60.7	28.9	55.7	27.1	51.7	26.0	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	9.2	7.8	DB	-18.3	35.9	4.3	2.0	-21.4	37.3	-23.9	38.4	-26.3	39.6	-29.4	41.0	(4)
(5)			WB	-18.7	20.2	4.2	1.3	-21.7	21.2	-24.2	21.9	-26.6	22.7	-29.7	23.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.5	-0.5	0.8	4.1	6.9	11.3	14.6	19.8	20.1	14.9	8.1	2.9	-1.2	(6)	
	DBStd	8.34	4.69	4.57	4.07	3.47	3.63	3.49	3.25	3.09	4.45	4.15	4.27	4.74	(7)	
	HDD10.0	1566	327	258	184	107	27	5	0	0	9	86	214	348	(8)	
	HDD18.3	3747	585	491	441	343	218	118	23	19	122	317	462	606	(9)	
	CDD10.0	1031	0	1	2	13	69	144	304	313	154	28	2	0	(10)	
	CDD18.3	170	0	0	0	0	1	8	69	74	18	0	0	0	(11)	
	CDH23.3	2609	0	0	0	8	42	146	1032	1082	285	13	0	0	(12)	
	CDH26.7	967	0	0	0	1	5	27	403	434	95	2	0	0	(13)	
(14) Wind	WSAvg	2.5	2.9	3.4	3.0	2.8	2.1	2.0	1.8	1.8	1.9	2.4	2.9	3.0	(14)	
(15) Precipitation	PrecAvg	533	52	35	47	58	70	55	24	18	26	41	55	53	(15)	
	PrecMax	738	81	76	84	88	138	105	81	54	71	65	92	126	(16)	
	PrecMin	419	23	13	16	28	29	28	4	0	2	15	22	21	(17)	
	PrecStd	95	17	17	19	19	34	19	23	16	21	16	21	24	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	12.9	17.9	24.8	27.2	29.9	34.1	35.4	32.3	25.5	17.2	11.3	(19)	
		MCWB	6.2	7.3	9.5	14.1	14.9	17.6	17.8	17.1	16.3	13.7	10.0	6.6	(20)	
	2%	DB	8.0	10.3	14.9	20.0	23.9	27.3	32.4	32.5	29.5	21.0	13.1	8.8	(21)	
		MCWB	4.4	6.1	8.2	11.2	13.9	16.5	17.4	16.3	15.4	11.5	7.5	5.6	(22)	
	5%	DB	6.4	8.2	12.5	17.2	21.8	25.1	31.1	31.1	27.0	17.7	11.2	7.1	(23)	
		MCWB	3.4	5.0	7.2	9.8	13.4	15.5	17.2	16.0	14.5	9.8	7.3	4.1	(24)	
	10%	DB	5.1	7.0	10.3	13.7	19.0	22.6	29.1	29.2	24.0	15.1	9.2	5.2	(25)	
		MCWB	2.9	4.1	6.3	7.8	11.8	14.4	16.8	15.9	13.6	9.0	6.0	2.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.5	7.5	10.6	14.6	16.8	19.8	21.8	22.1	19.4	14.2	10.6	7.1	(27)	
		MCDB	9.4	10.8	16.3	22.6	24.4	27.1	31.1	29.2	28.1	23.4	15.1	10.6	(28)	
	2%	WB	4.9	6.5	8.9	12.2	15.2	17.8	20.1	19.4	16.9	12.2	9.0	5.8	(29)	
		MCDB	7.5	9.9	13.3	18.7	21.9	25.1	29.6	28.7	25.2	19.6	12.8	8.3	(30)	
	5%	WB	3.9	5.5	7.8	10.2	13.8	16.4	18.8	17.3	15.4	10.7	7.4	4.2	(31)	
		MCDB	6.3	8.6	11.8	16.2	20.1	23.9	28.1	27.9	24.1	16.3	10.6	6.7	(32)	
	10%	WB	2.9	4.1	6.6	8.6	12.6	15.1	17.6	15.9	14.0	9.6	6.1	2.9	(33)	
		MCDB	5.0	6.6	10.0	13.5	18.2	21.4	26.2	27.1	23.6	13.9	8.9	5.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.7	7.0	9.6	10.4	12.0	12.2	16.0	16.9	14.3	11.2	8.0	6.6	(35)	
		MCDBR	7.9	9.2	13.2	16.7	16.5	16.6	18.9	19.2	18.5	15.9	10.6	7.9	(36)	
	5% WB	MCWBR	5.5	5.7	7.6	8.9	8.4	8.1	7.7	7.6	7.8	7.9	6.4	5.2	(37)	
		MCWBR	7.7	9.0	12.0	15.4	14.7	15.3	16.3	17.1	16.1	13.5	10.1	7.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.267	0.273	0.300	0.331	0.346	0.343	0.349	0.369	0.338	0.311	0.301	0.266	(40)	
		taud	2.515	2.532	2.511	2.426	2.414	2.445	2.434	2.366	2.440	2.521	2.465	2.525	(41)	
	Edn at Noon		861	924	938	929	920	921	911	878	879	861	798	822	(42)	
		Edh at Noon	63	76	90	107	113	110	110	113	96	77	67	57	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.35	2.20	3.32	4.74	5.76	6.63	7.48	6.29	4.61	2.80	1.51	1.04	(44)	
	RadStd		0.14	0.25	0.34	0.40	0.49	0.52	0.37	0.36	0.39	0.25	0.13	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+71	N/A

Nomenclature: See separate page