

ROME STATE, OR, USA

WMO: 726875

Lat: 42.591N

Lon: 117.864W

Elev: 1234

StdP: 87.35

Time Zone: -7.00 (NAM)

Period: 01-19

WBAN: 94107

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.4	-12.6	-19.6	0.8	-10.4	-17.1	1.0	-4.1	12.2	6.2	10.9	5.3	1.9	180	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.4	37.0	15.6	35.4	14.9	33.8	14.5	16.8	31.9	16.0	31.5	15.4	30.8	4.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.3	10.4	18.8	10.8	9.3	18.0	9.0	8.3	17.5	51.0	31.4	48.8	31.4	46.8	30.8	20.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.1	9.3	8.2	-20.6	39.7	3.8	1.4	-23.3	40.6	-25.5	41.4	-27.7	42.2	-30.4	43.2		
(5)			-21.0	17.9	3.7	0.9	-23.6	18.6	-25.8	19.1	-27.8	19.7	-30.5	20.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	-0.9	1.7	5.7	8.2	13.0	18.0	23.6	22.1	16.8	9.7	3.5	-1.0	(6)
(7)		DBStd	9.41	5.52	4.43	4.01	4.09	4.56	4.41	3.09	3.13	4.33	4.29	4.92	5.48	(7)
(8)		HDD10.0	1422	339	233	143	81	22	2	0	0	4	57	201	341	(8)
(9)		HDD18.3	3393	597	466	393	303	175	58	3	8	78	268	446	599	(9)
(10)		CDD10.0	1451	0	1	8	27	113	242	422	376	207	48	6	1	(10)
(11)		CDD18.3	381	0	0	0	0	8	48	166	126	32	1	0	0	(11)
(12)		CDH23.3	7414	0	0	2	36	291	1058	2917	2223	830	58	0	0	(12)
(13)		CDH26.7	3847	0	0	0	4	88	484	1701	1199	357	14	0	0	(13)
(14)	Wind	WSAvg	3.4	3.0	3.5	4.1	3.9	3.6	3.5	3.3	3.2	3.1	3.2	3.2	3.2	(14)
(15)	Precipitation	PrecAvg	236	23	18	19	32	33	25	8	6	9	19	18	25	(15)
(16)		PrecMax	380	68	35	39	70	102	83	26	25	56	66	34	58	(16)
(17)		PrecMin	140	3	5	6	10	1	1	1	0	0	0	8	6	(17)
(18)		PrecStd	59	16	9	10	14	25	19	7	6	12	19	6	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.4	16.3	22.7	26.9	31.9	37.1	39.6	37.8	35.0	28.6	20.2	13.5	(19)
(20)			MCWB	6.9	7.6	9.0	11.3	13.7	16.3	16.9	15.5	14.7	12.3	9.8	6.8	(20)
(21)		2%	DB	10.9	13.6	19.2	23.7	29.0	34.0	37.6	36.1	32.5	24.5	17.0	11.2	(21)
(22)			MCWB	5.7	6.2	7.9	9.9	12.6	14.6	16.0	14.9	13.8	10.7	8.1	5.8	(22)
(23)		5%	DB	8.6	11.3	16.6	20.9	26.8	31.9	36.2	34.6	30.9	22.0	14.3	9.1	(23)
(24)			MCWB	4.1	5.3	6.9	8.9	11.8	13.8	15.3	14.5	13.3	9.9	7.2	4.8	(24)
(25)		10%	DB	6.6	9.2	14.3	17.7	23.9	29.4	34.5	32.9	28.7	19.1	11.9	7.3	(25)
(26)			MCWB	2.8	4.4	6.2	7.6	10.9	13.1	14.8	14.1	12.5	8.8	6.0	3.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	8.4	10.0	12.2	15.2	17.2	18.7	16.8	16.7	13.5	10.7	7.9	(27)
(28)			MCDWB	12.5	14.5	19.3	23.7	26.0	34.0	34.5	30.2	28.7	23.5	18.3	12.3	(28)
(29)		2%	WB	6.1	7.1	8.8	10.7	13.8	15.6	17.2	16.0	15.3	11.9	9.1	6.6	(29)
(30)			MCDWB	9.9	12.4	17.5	21.4	25.5	30.3	32.3	31.7	28.8	22.3	15.5	10.3	(30)
(31)		5%	WB	4.5	5.7	7.7	9.5	12.6	14.7	16.4	15.4	14.1	10.7	7.8	5.3	(31)
(32)			MCDWB	8.0	10.5	15.7	19.6	23.8	28.6	32.3	31.2	27.8	20.1	13.7	8.6	(32)
(33)		10%	WB	3.2	4.6	6.6	8.2	11.6	13.9	15.7	14.8	13.0	9.5	6.4	3.7	(33)
(34)			MCDWB	6.2	8.9	13.6	16.6	22.3	27.0	31.7	30.7	27.5	17.8	11.4	7.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.2	11.6	14.0	15.2	16.4	18.1	20.4	20.3	19.5	16.5	13.2	10.1	(35)
(36)			MCDBR	12.5	14.1	18.5	21.3	21.2	22.0	22.7	22.6	22.9	20.7	16.1	10.9	(36)
(37)			MCWBR	8.2	8.3	9.8	10.2	8.9	8.4	8.8	9.2	10.2	10.1	9.2	7.0	(37)
(38)		5% WB	MCDWB	11.2	12.8	16.4	18.3	18.4	19.8	19.9	20.1	20.5	18.0	14.9	9.8	(38)
(39)			MCWBR	7.6	7.8	8.9	9.1	7.7	7.6	7.5	8.0	9.2	9.2	8.8	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.251	0.261	0.271	0.293	0.312	0.311	0.320	0.316	0.296	0.273	0.256	0.250	(40)
(41)		taud		2.612	2.625	2.612	2.529	2.500	2.536	2.517	2.516	2.563	2.637	2.632	2.607	(41)
(42)		Ebn at Noon		925	966	988	979	961	958	945	942	944	936	910	895	(42)
(43)		Edh at Noon		63	73	84	99	105	102	102	99	87	71	61	58	(43)
(44)	All-Sky Solar Radiation	RadAvg		1.75	2.70	3.93	5.38	6.48	7.56	7.68	6.71	5.33	3.59	2.15	1.42	(44)
(45)		RadStd		0.26	0.35	0.36	0.43	0.56	0.44	0.33	0.32	0.26	0.24	0.17	0.26	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	-1.31	N/A	N/A	N/A	N/A	N/A	+81	+37

Nomenclature: See separate page