

NORTH BEND, OR, USA

WMO: 726917

Lat: 43.413N

Lon: 124.244W

Elev: 17

StdP: 14.69

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24284

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	31.9	34.2	23.3	17.6	37.1	27.7	21.6	38.1	28.9	53.6	26.1	52.9	5.5	150	0.606

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.6	71.6	61.2	69.4	60.7	66.4	59.5	63.2	67.5	62.0	66.3	60.9	65.2	12.7	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.3	81.2	64.1	60.6	79.0	63.8	58.6	73.6	62.8	28.6	67.9	27.6	66.2	26.9	65.2	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.1	24.6	20.9	27.8	83.0	2.8	4.5	25.7	86.2	24.1	88.8	22.5	91.3	20.5	94.5		
(5)			25.8	65.9	3.3	1.9	23.5	67.3	21.6	68.5	19.8	69.5	17.4	71.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.6	47.1	46.9	47.9	49.8	53.7	56.9	59.5	59.9	58.5	54.4	49.9	46.3	(6)
(7)		DBStd	6.37	4.78	4.65	4.10	3.80	3.72	2.73	2.61	2.63	3.39	4.12	4.69	5.14	(7)
(8)		HDD50	567	113	105	90	47	9	0	0	0	0	9	57	137	(8)
(9)		HDD65	4531	555	505	531	457	351	243	172	159	195	329	454	580	(9)
(10)		CDD50	1517	24	19	25	40	123	208	294	308	256	145	53	22	(10)
(11)		CDD65	6	0	0	0	1	1	1	1	1	1	0	0	0	(11)
(12)		CDH74	56	0	0	0	7	11	5	1	7	19	6	0	0	(12)
(13)		CDH80	13	0	0	0	2	2	2	0	2	5	0	0	0	(13)
(14)	Wind	WSAvg	8.7	7.8	7.8	8.5	8.9	9.2	9.9	11.1	9.5	8.1	7.2	7.7	8.3	(14)
(15)	Precipitation	PrecAvg	64.4	10.2	7.6	7.8	5.1	3.3	1.6	0.4	0.8	1.7	4.5	10.1	11.2	(15)
(16)		PrecMax	93.5	20.9	16.9	14.9	11.1	9.3	4.8	2.8	5.5	5.7	12.4	22.7	21.8	(16)
(17)		PrecMin	33.5	1.9	2.3	1.7	1.3	0.3	0.1	0.0	0.0	0.0	0.4	2.6	1.7	(17)
(18)		PrecStd	12.0	4.5	3.7	3.5	2.8	2.0	1.1	0.6	1.0	1.5	2.8	4.8	5.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.8	63.7	64.0	69.6	72.9	71.7	71.5	72.4	75.1	72.8	64.4	62.1	(19)
(20)		MCWB	54.2	54.3	54.6	57.3	60.2	61.6	62.9	62.6	60.8	59.2	57.3	55.2	(20)	
(21)		2%	DB	58.5	59.0	59.4	61.4	64.3	66.0	68.5	70.1	70.3	66.4	62.3	58.6	(21)
(22)		MCWB	53.5	53.2	52.4	53.3	56.9	59.3	60.8	61.5	61.2	57.9	56.4	53.9	(22)	
(23)		5%	DB	56.1	55.8	56.9	57.8	62.5	64.0	66.4	68.0	67.6	63.7	59.4	56.1	(23)
(24)		MCWB	52.0	51.4	51.7	51.6	55.9	57.3	59.8	60.3	59.9	57.3	55.5	52.5	(24)	
(25)		10%	DB	54.5	54.3	54.8	55.5	60.5	63.1	65.6	66.0	65.5	61.5	57.0	54.4	(25)
(26)		MCWB	51.0	50.4	50.7	50.7	54.6	56.5	59.5	59.5	59.6	56.2	53.4	51.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.3	57.3	57.0	58.1	61.9	63.3	63.8	64.7	64.6	63.4	60.8	57.7	(27)
(28)		MADB	60.6	61.4	61.4	65.0	69.7	65.9	68.3	69.6	69.8	66.4	63.0	60.5	(28)	
(29)		2%	WB	54.6	54.8	54.6	54.8	58.2	60.3	62.1	62.9	62.9	61.3	58.0	55.2	(29)
(30)		MADB	57.3	57.6	57.7	59.6	64.1	64.4	66.5	67.3	67.1	64.7	60.6	57.8	(30)	
(31)		5%	WB	53.1	52.9	53.1	53.2	56.4	58.6	60.8	61.5	61.4	58.9	56.1	53.4	(31)
(32)		MADB	55.5	55.2	55.6	56.7	61.3	63.1	65.3	66.0	65.3	62.7	58.9	55.4	(32)	
(33)		10%	WB	51.4	50.7	51.3	51.7	55.0	57.3	59.7	60.2	60.1	57.1	54.2	51.2	(33)
(34)		MADB	54.2	53.6	54.6	55.4	59.2	62.0	64.1	64.7	64.3	60.9	56.7	54.0	(34)	
(35)	Mean Daily Temperature Range	MDBR	11.7	12.1	12.6	12.0	11.4	11.3	11.7	12.6	14.2	14.3	12.4	11.7	(35)	
(36)		5% DB	MADB	14.1	15.0	16.0	15.4	15.1	13.6	13.3	15.4	18.3	17.2	14.8	12.7	(36)
(37)			MCWBR	9.9	10.2	10.8	9.7	9.1	8.0	7.3	8.7	10.1	10.5	10.1	9.4	(37)
(38)			MADB	11.9	12.7	13.1	13.9	13.6	12.6	12.5	13.9	14.9	14.7	12.3	10.3	(38)
(39)		5% WB	MCWBR	9.1	9.3	9.6	9.3	8.5	7.7	7.2	8.2	9.2	9.9	9.2	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.322	0.322	0.330	0.362	0.368	0.357	0.348	0.353	0.344	0.333	0.324	0.329	(40)	
(41)		taud	2.553	2.562	2.555	2.419	2.439	2.480	2.518	2.522	2.535	2.569	2.568	2.508	(41)	
(42)		Ebn at Noon	259	280	291	287	287	290	291	286	282	271	256	243	(42)	
(43)		Edh at Noon	22	25	28	35	35	34	32	31	29	24	21	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	474	731	1075	1524	1899	2079	2217	1871	1487	928	531	387	(44)	
(45)		RadStd	67	84	118	110	128	138	119	129	99	83	65	62	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+18

Nomenclature: See separate page