

NORTH BEND, OR, USA

WMO: 726917

Lat: 43.413N

Lon: 124.244W

Elev: 5

StdP: 101.26

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24284

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	0.0	1.2	-4.8	2.5	2.8	-2.4	3.1	3.4	12.9	12.0	11.7	11.6	2.4	150	0.606

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.0	22.0	16.2	20.8	16.0	19.1	15.3	17.4	19.7	16.7	19.1	16.0	18.4	5.7	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.3	11.6	17.8	15.9	11.3	17.7	14.8	10.5	17.1	48.6	19.9	46.4	19.0	44.7	18.4	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	11.0	9.4	DB	-2.4	28.3	1.6	2.5	-3.5	30.1	-4.4	31.6	-5.3	33.0	-6.4	34.7	(4)
(5)			WB	-3.4	18.8	1.8	1.1	-4.7	19.6	-5.8	20.3	-6.8	20.9	-8.1	21.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	8.4	8.3	8.8	9.9	12.1	13.8	15.3	15.5	14.7	12.5	9.9	7.9		
	DBStd	3.54	2.65	2.58	2.28	2.11	2.06	1.51	1.45	1.46	1.88	2.29	2.60	2.85		
	HDD10.0	315	63	58	50	26	5	0	0	0	0	5	32	76		
	HDD18.3	2517	308	281	295	254	195	135	96	88	108	183	252	322		
	CDD10.0	843	13	11	14	22	68	116	163	171	142	81	29	12		
	CDD18.3	3	0	0	0	1	1	1	1	1	1	0	0	0		
	CDH23.3	31	0	0	0	4	6	3	1	4	11	3	0	0		
	CDH26.7	7	0	0	0	1	1	1	0	1	3	0	0	0		
(14) Wind	WSAvg	3.9	3.5	3.5	3.8	4.0	4.1	4.4	5.0	4.2	3.6	3.2	3.4	3.7		
(15) Precipitation	PrecAvg	1635	260	194	197	130	83	41	11	21	43	115	256	284		
	PrecMax	2376	532	430	378	283	236	122	71	139	145	316	576	554		
	PrecMin	851	47	59	42	32	8	3	0	0	0	9	65	43		
	PrecStd	304	115	95	88	71	52	29	14	26	39	70	121	134		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.1	17.6	17.8	20.9	22.7	22.1	21.9	22.4	23.9	22.7	18.0	16.7		
		MCWB	12.3	12.4	12.5	14.1	15.7	16.4	17.2	17.0	16.0	15.1	14.1	12.9		
	2%	DB	14.7	15.0	15.2	16.3	17.9	18.9	20.3	21.1	21.3	19.1	16.8	14.8		
		MCWB	11.9	11.8	11.4	11.9	13.8	15.2	16.0	16.4	16.2	14.4	13.6	12.2		
	5%	DB	13.4	13.2	13.8	14.3	17.0	17.8	19.1	20.0	19.8	17.6	15.2	13.4		
		MCWB	11.1	10.8	11.0	10.9	13.3	14.0	15.5	15.7	15.5	14.1	13.0	11.4		
	10%	DB	12.5	12.4	12.6	13.0	15.8	17.3	18.6	18.9	18.6	16.4	13.9	12.4		
		MCWB	10.6	10.2	10.4	10.4	12.5	13.6	15.3	15.3	15.3	13.4	11.9	10.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	14.1	13.9	14.5	16.6	17.4	17.6	18.1	18.1	17.5	16.0	14.3		
		MCDB	15.9	16.3	16.4	18.3	21.0	18.8	20.2	20.9	21.0	19.1	17.2	15.8		
	2%	WB	12.6	12.6	12.5	12.7	14.6	15.7	16.7	17.2	17.1	16.3	14.5	12.9		
		MCDB	14.0	14.2	14.3	15.4	17.8	18.0	19.2	19.6	19.5	18.2	15.9	14.3		
	5%	WB	11.7	11.6	11.7	11.8	13.6	14.8	16.0	16.4	16.4	14.9	13.4	11.9		
		MCDB	13.0	12.9	13.1	13.7	16.3	17.3	18.5	18.9	18.5	17.1	14.9	13.0		
	10%	WB	10.8	10.4	10.7	10.9	12.8	14.1	15.4	15.7	15.6	13.9	12.3	10.7		
		MCDB	12.3	12.0	12.5	13.0	15.1	16.7	17.9	18.2	17.9	16.0	13.7	12.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	6.7	7.0	6.7	6.4	6.3	6.5	7.0	7.9	7.9	6.9	6.5		
		MCDBR	7.8	8.4	8.9	8.5	8.4	7.5	7.4	8.6	10.2	9.5	8.2	7.0		
	5% WB	MCWBR	5.5	5.7	6.0	5.4	5.0	4.4	4.1	4.9	5.6	5.8	5.6	5.2		
		MCWBR	6.6	7.1	7.3	7.7	7.6	7.0	6.9	7.7	8.3	8.2	6.8	5.7		
(40) Clear-Sky Solar Irradiance	taub		0.322	0.322	0.330	0.362	0.368	0.357	0.348	0.353	0.344	0.333	0.324	0.329		
		taud	2.553	2.562	2.555	2.419	2.439	2.480	2.518	2.522	2.535	2.569	2.568	2.508		
	Ebn at Noon		817	882	917	904	904	913	916	903	888	855	807	766		
		Edh at Noon	68	79	89	110	111	107	102	98	90	77	66	66		
(44) All-Sky Solar Radiation	RadAvg		1.49	2.30	3.39	4.80	5.99	6.55	6.99	5.90	4.69	2.92	1.68	1.22		
	RadStd		0.21	0.26	0.37	0.35	0.40	0.43	0.38	0.41	0.31	0.26	0.20	0.20		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+10

Nomenclature: See separate page