

JOHN DAY 35 WNW, OR, USA

WMO: 726970

Lat: 44.5560N

Lon: 119.6459W

Elev: 684

StdP: 93.37

Time Zone: -8.00 (NAP)

Period: 04-19

WBAN: 04125

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-11.6	-8.8	-16.0	1.0	-8.9	-13.3	1.3	-6.7	5.7	8.8	5.1	6.9	1.6	N/A	0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	37.0	16.6	35.4	16.3	33.6	15.7	18.0	32.0	17.2	31.7	16.6	31.4	2.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.8	10.7	20.8	12.5	9.8	19.3	11.0	8.9	19.5	53.2	31.7	50.7	31.7	48.6	31.6	21.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.8	4.1	3.8	-15.9	40.2	3.3	1.8	-18.2	41.5	-20.2	42.6	-22.1	43.6	-24.5	44.9		
(5)			-17.1	19.7	4.0	1.1	-20.0	20.5	-22.3	21.1	-24.5	21.7	-27.4	22.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.7	2.5	4.0	7.1	9.9	14.5	18.3	23.7	22.7	18.0	11.4	5.7	1.6	(6)
(7)		DBStd	8.55	4.84	4.44	3.79	3.80	4.16	3.97	3.22	3.40	4.16	3.96	4.91	5.24	(7)
(8)		HDD10.0	1001	233	171	104	48	7	0	0	0	1	31	143	263	(8)
(9)		HDD18.3	2854	490	401	348	255	134	47	2	5	56	217	380	519	(9)
(10)		CDD10.0	1608	1	3	14	44	146	250	423	394	242	74	14	3	(10)
(11)		CDD18.3	419	0	0	0	1	14	47	167	141	47	2	0	0	(11)
(12)		CDH23.3	6740	0	0	1	45	282	859	2633	2119	751	50	1	0	(12)
(13)		CDH26.7	3431	0	0	0	9	96	373	1484	1132	326	11	0	0	(13)
(14)	Wind	WSAvg	1.8	2.0	1.9	2.0	1.9	1.8	1.8	1.7	1.7	1.7	1.7	1.8	(14)	
(15)	Precipitation	PrecAvg	345	40	25	30	35	41	32	14	12	28	38	39	(15)	
(16)		PrecMax	477	81	51	54	62	100	57	54	32	26	45	68	83	(16)
(17)		PrecMin	243	11	11	13	15	7	3	3	0	2	11	10	18	(17)
(18)		PrecStd	65	18	11	12	12	25	15	13	10	7	11	17	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.2	17.6	21.8	28.0	32.7	37.1	39.3	38.9	35.7	28.0	20.7	15.5	(19)
(20)			MCWB	8.0	8.6	10.8	13.1	15.4	18.5	17.3	16.9	15.7	13.2	11.2	8.8	(20)
(21)		2%	DB	12.8	15.1	18.6	24.1	29.4	33.7	37.3	36.8	33.0	24.2	17.8	13.3	(21)
(22)			MCWB	6.5	8.1	9.6	11.7	14.3	16.8	16.4	16.3	15.2	11.6	10.2	7.7	(22)
(23)		5%	DB	11.1	12.9	16.4	20.8	26.5	30.8	35.9	34.8	30.6	21.3	15.2	11.3	(23)
(24)			MCWB	5.8	7.0	8.6	10.3	13.3	15.2	16.3	15.9	14.9	10.8	8.6	6.2	(24)
(25)		10%	DB	9.5	11.0	14.3	17.7	23.7	28.4	34.1	32.8	27.9	18.7	13.1	9.3	(25)
(26)			MCWB	5.0	5.8	7.6	9.2	12.3	14.0	15.8	15.6	13.7	9.9	7.2	5.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	9.9	11.8	14.1	16.6	19.7	19.4	18.3	17.7	14.4	12.3	9.9	(27)
(28)			MCDWB	14.0	16.7	18.6	25.4	28.4	33.5	33.2	32.3	29.6	24.8	19.2	14.9	(28)
(29)		2%	WB	7.1	8.9	10.4	12.7	15.3	18.1	17.9	17.5	16.6	12.9	10.8	8.5	(29)
(30)			MCDWB	12.0	15.1	16.5	23.5	25.6	31.2	32.5	32.5	30.0	20.9	16.6	13.3	(30)
(31)		5%	WB	5.9	7.7	9.4	11.2	14.4	16.5	17.2	16.8	15.5	11.8	9.2	6.6	(31)
(32)			MCDWB	10.3	13.4	15.5	20.0	24.0	29.6	32.4	32.0	29.3	19.3	14.7	10.9	(32)
(33)		10%	WB	5.1	6.6	8.2	10.0	13.4	15.3	16.5	16.2	14.4	10.7	7.8	5.1	(33)
(34)			MCDWB	8.9	11.4	14.3	17.0	22.2	26.8	32.1	31.2	26.8	17.5	12.6	8.9	(34)
(35)	Mean Daily Temperature Range	MDBR	8.5	10.0	11.4	12.9	14.1	15.6	18.8	18.4	16.8	13.1	9.9	8.1	(35)	
(36)		5% DB	MCDBR	10.3	12.4	15.1	18.5	19.0	20.2	20.7	21.0	20.7	17.2	11.9	9.0	(36)
(37)			MCWBR	6.4	6.8	7.7	8.5	7.3	7.3	7.2	7.1	7.8	7.8	6.1	5.3	(37)
(38)			MCDBR	10.1	11.4	13.1	16.7	16.1	18.7	18.6	18.9	18.9	14.8	11.0	8.4	(38)
(39)		5% WB	MCWBR	6.1	6.5	7.0	7.9	6.4	6.7	6.5	6.2	7.2	7.2	5.8	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.290	0.299	0.309	0.349	0.359	0.347	0.352	0.357	0.336	0.318	0.298	0.291	(40)	
(41)		taud	2.515	2.527	2.519	2.391	2.392	2.459	2.460	2.439	2.476	2.532	2.534	2.505	(41)	
(42)		Ebn at Noon	843	900	934	914	911	920	911	895	889	864	825	801	(42)	
(43)		Edh at Noon	67	79	91	112	116	109	108	106	94	78	65	62	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.56	2.43	3.63	5.11	6.14	7.20	7.78	6.63	5.00	3.13	1.77	1.23	(44)	
(45)		RadStd	0.18	0.28	0.34	0.43	0.50	0.38	0.29	0.39	0.31	0.25	0.15	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+74	N/A

Nomenclature: See separate page