

CARIBOU, ME, USA

WMO: 727120

Lat: 46.871N

Lon: 68.017W

Elev: 624

StdP: 14.37

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14607

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.7	-8.9	-21.1	1.8	-11.4	-16.7	2.3	-7.5	26.3	15.6	23.9	16.2	5.5	260	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.4	84.5	68.6	81.4	66.9	78.4	65.4	71.4	79.9	69.6	77.2	68.1	75.2	9.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.7	107.7	74.9	67.0	101.5	73.4	65.3	95.6	72.0	35.6	80.3	34.1	77.1	32.7	75.1	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.0	19.0	16.9	-21.6	89.4	6.2	2.5	-26.1	91.2	-29.7	92.7	-33.2	94.1	-37.7	95.9		
			-20.7	74.5	5.1	1.7	-24.4	75.8	-27.3	76.8	-30.2	77.8	-33.9	79.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.7	11.7	14.4	24.8	38.2	51.8	61.0	66.6	64.5	56.6	44.6	32.4	19.7		
	DBStd	20.90	12.50	11.40	10.40	7.66	7.31	6.70	5.27	5.56	7.26	7.68	9.06	10.88		
	HDD50	5083	1187	995	781	359	64	3	0	0	19	205	532	938		
	HDD65	9092	1652	1415	1245	803	414	157	43	78	269	634	979	1403		
	CDD50	1677	0	0	1	6	120	333	515	449	215	36	2	0		
	CDD65	212	0	0	0	0	4	37	93	62	16	0	0	0		
	CDH74	1847	0	0	0	3	97	361	742	503	137	4	0	0		
	CDH80	405	0	0	0	0	19	83	162	112	29	0	0	0		
	WSAvg	7.3	7.8	8.1	8.6	8.4	7.6	6.6	5.7	5.6	6.3	7.2	7.6	7.7		
	PrecAvg	38.3	2.6	2.2	2.6	2.7	3.3	3.5	4.1	3.8	3.4	3.5	3.4	3.4		
Precipitation	PrecMax	54.3	5.7	4.7	5.3	6.2	5.7	9.0	8.0	12.1	8.8	8.7	8.1	8.0		
	PrecMin	27.9	0.3	0.3	0.7	0.6	0.5	0.9	0.9	0.6	0.9	0.9	0.7	0.7		
	PrecStd	6.0	1.2	0.9	1.1	1.1	1.2	1.6	1.5	2.0	1.5	1.7	1.5	1.4		
	PrecStd	6.0	1.2	0.9	1.1	1.1	1.2	1.6	1.5	2.0	1.5	1.7	1.5	1.4		
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.2	45.6	54.7	68.8	82.5	86.9	88.2	87.5	83.9	73.1	60.9	47.4		
		MCWB	44.9	41.1	44.6	52.0	62.4	69.7	70.1	69.8	69.8	60.4	58.4	45.3		
	2%	DB	39.3	38.7	45.9	60.8	76.2	82.2	84.3	83.2	78.0	65.7	54.4	41.9		
		MCWB	37.4	35.2	38.9	48.4	58.7	66.4	69.0	68.2	66.5	57.2	50.1	40.0		
	5%	DB	34.9	35.2	42.0	55.5	70.9	78.2	81.1	79.4	73.3	61.3	49.4	37.5		
		MCWB	32.9	32.6	36.5	45.6	56.2	64.6	67.4	66.3	63.3	55.4	45.6	35.5		
	10%	DB	30.4	32.2	38.8	50.8	66.1	74.3	78.2	76.1	69.7	57.1	45.5	34.6		
		MCWB	28.6	30.1	34.3	42.7	54.1	62.1	65.9	64.7	62.1	51.7	42.5	33.0		
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.3	42.3	47.2	56.7	66.5	72.7	74.4	72.7	71.9	63.4	58.8	46.2		
		MCDB	46.2	44.5	50.8	64.8	77.0	82.9	82.4	82.3	81.5	68.6	60.8	47.4		
	2%	WB	37.6	36.0	40.8	51.1	62.1	69.5	71.7	70.4	68.8	59.6	51.6	40.6		
		MCDB	38.8	37.8	44.6	56.6	70.5	77.9	79.5	78.4	74.4	63.9	53.0	41.8		
	5%	WB	33.0	33.0	37.4	47.1	58.9	67.3	69.7	68.8	66.1	56.1	46.2	36.0		
		MCDB	34.6	34.8	41.0	54.4	66.8	75.0	77.5	75.9	71.5	60.7	48.6	37.2		
	10%	WB	28.8	30.1	34.8	43.6	56.1	64.7	68.1	67.1	63.2	52.4	42.8	33.1		
		MCDB	30.3	32.3	38.4	49.9	64.7	71.0	75.5	73.7	68.5	56.5	45.5	34.5		
Mean Daily Temperature Range	5% DB	MDBR	17.0	18.1	17.3	16.9	20.0	19.8	19.4	20.1	19.9	16.2	12.9	14.2		
		MCDBR	20.1	16.5	19.7	26.5	28.4	25.6	23.2	24.4	24.2	22.9	18.2	15.3		
		MCWBR	18.6	14.6	14.7	16.6	14.6	12.8	10.9	11.6	14.0	15.2	15.2	14.8		
	5% WB	MCDBR	19.0	15.6	17.1	23.1	23.3	21.1	19.7	19.7	20.4	19.8	16.3	15.1		
		MCWBR	18.9	14.6	13.9	16.2	13.9	12.5	10.8	10.9	13.2	15.1	15.3	15.1		
Clear-Sky Solar Irradiance	taub		0.253	0.270	0.304	0.342	0.357	0.378	0.407	0.387	0.358	0.320	0.293	0.272		
	taud		2.359	2.296	2.294	2.379	2.409	2.348	2.289	2.344	2.415	2.523	2.522	2.394		
	Ebn at Noon		271	287	292	290	288	281	271	272	271	267	255	248		
	Edh at Noon		22	30	35	36	36	38	40	36	31	24	20	20		
All-Sky Solar Radiation	RadAvg		445	726	1103	1412	1591	1726	1724	1516	1197	716	407	312		
	RadStd		55	82	75	126	167	117	149	95	90	65	48	29		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page