

PRESQUE ISLE, ME, USA

WMO: 727130

Lat: 46.683N

Lon: 68.050W

Elev: 163

StdP: 99.38

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 14604

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-27.2	-23.9	-32.4	0.2	-24.7	-29.9	0.2	-23.0	11.8	-5.2	10.8	-6.4	1.1	0	0.619

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	29.2	20.3	27.6	19.2	26.2	18.3	21.8	27.1	20.7	25.7	19.8	24.2	4.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	15.0	24.2	18.9	14.0	23.4	17.9	13.1	22.1	64.0	27.0	60.6	25.9	57.2	24.1	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.0	8.1	DB	-31.8	32.4	3.2	1.6	-34.0	33.5	-35.9	34.5	-37.6	35.3	-39.9	36.5	(4)
(5)			WB	-31.0	23.6	1.9	1.1	-32.4	24.4	-33.5	25.0	-34.6	25.6	-36.0	26.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.6	-11.0	-9.9	-4.1	3.3	10.6	15.7	18.9	17.8	13.3	6.6	0.2	-6.9	(6)	
	DBStd	11.54	7.25	6.57	6.00	4.19	3.96	3.80	2.96	3.17	4.11	4.24	5.17	6.28	(7)	
	HDD10.0	2849	652	558	436	205	40	2	0	0	14	122	295	524	(8)	
	HDD18.3	5113	911	792	694	452	242	97	28	49	158	363	543	783	(9)	
	CDD10.0	886	0	0	1	3	59	174	277	241	113	18	2	0	(10)	
	CDD18.3	107	0	0	0	0	2	19	47	31	8	0	0	0	(11)	
	CDH23.3	1116	0	0	0	2	57	221	442	311	82	3	0	0	(12)	
	CDH26.7	266	0	0	0	0	13	56	104	74	19	0	0	0	(13)	
(14) Wind	WSAvg	3.3	3.4	3.5	3.9	3.8	3.6	3.1	2.7	2.5	2.8	3.3	3.5	3.4	(14)	
(15) Precipitation	PrecAvg	898	58	43	53	58	83	80	99	95	91	86	76	68	(15)	
	PrecMax	1310	139	120	115	136	168	199	179	217	239	222	193	163	(16)	
	PrecMin	588	7	2	9	12	12	17	19	30	24	24	35	15	(17)	
	PrecStd	149	29	22	24	26	36	37	35	43	45	46	37	34	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	8.0	13.0	21.0	28.1	31.3	31.6	31.3	29.0	22.8	16.3	9.0	(19)	
		MCWB	8.6	5.7	6.9	10.6	17.1	21.3	21.4	20.9	21.2	15.8	14.4	7.8	(20)	
	2%	DB	4.6	3.9	8.0	16.3	24.8	27.9	29.1	28.7	26.1	18.8	12.8	6.1	(21)	
		MCWB	3.1	2.0	3.8	9.3	14.7	18.8	20.6	20.2	19.3	14.3	10.1	4.3	(22)	
	5%	DB	2.3	2.3	6.2	12.9	22.0	26.2	27.5	27.0	22.9	16.5	10.1	3.0	(23)	
		MCWB	1.1	0.8	2.7	7.8	13.4	17.7	19.5	19.0	17.2	12.9	8.0	1.6	(24)	
	10%	DB	-0.2	0.9	3.9	10.9	18.8	23.7	26.1	24.8	21.2	13.9	7.7	2.1	(25)	
		MCWB	-1.1	-0.6	1.3	6.2	11.9	16.5	18.8	18.2	16.6	10.5	5.8	0.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	6.1	8.9	13.7	19.1	22.4	23.4	22.5	22.1	17.3	14.8	8.0	(27)	
		MCDB	8.6	7.9	11.5	18.7	25.7	28.9	28.4	28.1	28.0	20.0	16.6	8.6	(28)	
	2%	WB	3.5	2.7	5.1	10.9	16.5	20.6	21.9	21.3	20.2	15.1	11.0	4.7	(29)	
		MCDB	4.4	3.7	7.6	14.1	21.4	26.0	26.7	26.3	24.1	18.2	12.6	6.2	(30)	
	5%	WB	0.8	0.7	3.1	8.4	14.6	19.3	20.8	20.3	18.9	13.1	8.0	2.2	(31)	
		MCDB	2.0	1.9	5.3	12.3	19.5	23.9	25.9	24.7	22.0	16.1	9.3	3.1	(32)	
	10%	WB	-1.2	-0.8	1.6	6.4	13.0	17.9	19.9	19.3	17.2	11.2	6.0	0.4	(33)	
		MCDB	-0.3	0.4	4.0	10.2	18.5	21.8	24.4	23.4	20.0	13.7	8.0	1.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.9	11.8	10.8	10.3	12.0	11.9	11.5	12.1	12.1	10.2	7.8	9.0	(35)	
		MCDBR	11.2	10.3	12.1	15.7	17.5	15.5	14.1	14.8	14.9	14.0	10.9	8.9	(36)	
	5% WB	MCWBR	10.9	8.9	9.0	10.0	9.2	8.1	7.1	7.7	9.0	9.9	9.2	8.5	(37)	
		MCWBR	10.8	9.0	10.7	13.7	13.8	12.6	12.0	11.9	12.4	12.5	9.7	9.0	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.254	0.271	0.306	0.341	0.361	0.382	0.409	0.391	0.360	0.321	0.296	0.273	(40)	
		taud	2.374	2.308	2.314	2.389	2.401	2.337	2.285	2.338	2.409	2.522	2.522	2.407	(41)	
	Edn at Noon	Edn at Noon	857	907	920	915	904	882	851	854	851	843	802	785	(42)	
		Edh at Noon	70	92	108	111	114	122	127	116	99	76	62	62	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.42	2.30	3.49	4.45	5.02	5.44	5.44	4.80	3.81	2.29	1.31	1.00	(44)	
	RadStd	RadStd	0.17	0.25	0.23	0.40	0.54	0.36	0.46	0.30	0.28	0.21	0.15	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	+2.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page