

WISCASSET, ME, USA

WMO: 727135

Lat: 43.964N

Lon: 69.712W

Elev: 21

StdP: 101.08

Time Zone: -5.00 (NAE)

Period: 95-19

WBAN: 94623

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.6	-17.0	-26.7	0.3	-17.2	-23.8	0.4	-14.5	7.9	3.2	7.0	0.8	0.9	300	0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	29.9	21.8	28.0	20.7	26.6	19.7	23.1	27.7	22.1	26.2	21.1	24.6	2.8	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.6	16.3	25.4	20.9	15.6	24.3	19.9	14.6	23.3	68.5	27.7	64.8	26.2	61.4	24.4	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.6	5.5	4.9	-23.8	33.2	3.8	1.5	-26.6	34.3	-28.8	35.2	-30.9	36.0	-33.7	37.1		
(5)			-24.2	24.8	3.6	0.9	-26.8	25.5	-28.9	26.1	-31.0	26.6	-33.6	27.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.7	-5.7	-4.1	0.2	6.2	11.9	16.7	20.2	19.6	15.6	9.2	3.6	-2.0
	DBStd	9.86	6.01	5.48	4.88	3.69	3.60	3.46	2.73	2.68	3.72	3.99	4.42	5.20
	HDD10.0	1964	486	395	306	123	18	1	0	0	2	64	198	372
	HDD18.3	4054	744	628	563	363	202	71	12	17	97	283	443	629
	CDD10.0	1121	0	0	2	10	78	203	316	297	171	39	4	0
	CDD18.3	168	0	0	0	0	3	23	70	56	16	1	0	0
	CDH23.3	1399	0	0	2	3	67	216	571	419	114	7	0	0
	CDH26.7	328	0	0	0	0	18	53	143	89	24	1	0	0
Wind	WSAvg	1.8	1.8	1.9	2.1	2.1	1.9	1.7	1.5	1.4	1.5	1.7	1.7	1.7
Precipitation	PrecAvg	1222	80	84	106	99	98	113	89	81	107	131	116	119
	PrecMax	1817	131	175	192	240	196	223	197	156	238	406	191	165
	PrecMin	865	12	39	27	11	29	25	16	20	5	29	35	60
	PrecStd	218	30	31	48	52	47	59	50	42	64	83	36	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	10.7	18.0	22.7	29.1	31.1	32.3	31.6	29.4	23.8	17.1	12.7
		MCWB	10.5	8.2	11.2	13.9	18.4	22.2	23.1	23.0	22.4	17.0	13.2	10.7
	2%	DB	8.6	8.0	12.4	17.8	24.8	27.9	29.9	28.9	26.5	20.0	14.8	10.3
		MCWB	6.7	5.4	7.1	10.4	16.4	20.3	22.0	21.7	19.6	15.6	12.3	8.9
	5%	DB	5.9	6.2	9.1	15.4	21.7	26.0	28.0	27.3	24.0	17.8	12.9	8.1
		MCWB	3.8	3.6	5.6	9.1	14.7	18.8	20.9	20.5	18.4	14.6	10.8	6.5
	10%	DB	3.0	3.9	7.4	13.0	18.8	23.6	26.5	25.9	22.3	16.2	11.3	6.1
		MCWB	1.0	1.7	4.4	8.1	13.1	17.2	19.9	19.5	17.7	13.1	9.2	4.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.9	9.0	12.1	15.3	19.9	23.4	24.5	24.3	22.9	18.9	15.1	11.6
		MCDB	11.6	9.7	16.3	20.4	26.5	28.8	30.3	29.7	28.1	20.8	16.3	12.3
	2%	WB	7.3	6.4	8.6	12.5	17.7	21.7	23.1	23.0	21.2	16.9	13.1	9.2
		MCDB	8.2	7.7	10.6	15.5	22.7	26.6	27.9	27.0	24.5	18.8	14.0	10.1
	5%	WB	3.9	3.9	6.5	10.6	15.8	20.2	22.1	21.9	20.1	15.4	11.4	7.1
		MCDB	5.6	5.6	8.6	13.5	20.2	24.0	26.4	25.2	22.6	17.6	12.5	7.9
	10%	WB	1.3	2.1	4.6	8.8	14.0	18.8	21.2	20.9	18.8	13.9	9.4	4.1
		MCDB	2.8	3.8	7.0	12.3	17.8	22.1	24.8	24.0	21.2	15.7	11.0	5.8
Mean Daily Temperature Range	5% DB	MDBR	10.2	10.6	9.9	10.9	11.1	10.7	10.9	11.1	11.1	10.5	9.3	9.3
		MCDBR	11.7	11.4	12.7	15.2	16.2	14.1	13.4	13.0	13.2	12.3	10.6	11.4
		MCWBR	10.5	9.4	8.7	9.0	8.4	7.2	6.3	6.5	7.5	8.4	8.7	10.2
	5% WB	MCDBR	11.5	10.6	11.5	12.1	13.8	12.4	10.9	10.7	10.4	10.7	9.1	11.0
		MCWBR	10.9	9.7	9.0	8.5	8.0	7.2	5.8	6.0	6.6	8.4	8.6	10.8
Clear-Sky Solar Irradiance	taub	0.292	0.304	0.328	0.354	0.382	0.428	0.443	0.411	0.372	0.338	0.319	0.294	
	taud	2.440	2.414	2.440	2.415	2.383	2.265	2.243	2.322	2.411	2.508	2.525	2.509	
	Ebn at Noon	840	892	912	910	890	845	827	843	853	843	803	806	
	Edh at Noon	73	89	99	110	117	133	134	120	101	81	68	63	
All-Sky Solar Radiation	RadAvg	1.62	2.52	3.70	4.61	5.19	5.57	5.85	5.29	4.26	2.73	1.73	1.28	
	RadStd	0.12	0.20	0.23	0.49	0.63	0.47	0.42	0.28	0.25	0.25	0.16	0.13	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+103	+36
(47) Regional (41 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+72	N/A

Nomenclature: See separate page