

OLD TOWN 2 W, ME, USA

WMO: 727140

Lat: 44.9281N

Lon: 68.7006W

Elev: 127

StdP: 14.63

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 94644

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.9	-4.3	-16.4	2.3	-6.7	-11.6	3.0	-0.7	15.9	15.8	14.6	16.6	2.3	N/A	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	85.4	70.8	82.3	69.1	79.6	67.0	73.0	82.5	71.4	79.4	69.7	76.6	5.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	111.1	76.6	68.6	105.7	74.9	67.4	101.0	73.7	36.6	82.8	35.2	79.5	33.8	76.6	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.6	11.8	10.0	-17.7	90.7	7.1	1.7	-22.8	91.9	-27.0	92.9	-31.0	93.8	-36.2	95.1
			-17.5	76.1	4.6	1.6	-20.8	77.3	-23.5	78.2	-26.1	79.1	-29.5	80.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	43.7	17.4	20.0	29.4	41.8	52.9	61.2	67.9	66.0	58.7	47.2	36.0	24.5
	DBStd	19.20	12.21	10.89	9.81	7.34	6.56	6.01	4.88	5.04	7.22	7.52	8.42	10.30
	HDD50	4170	1010	840	642	262	40	2	0	0	9	146	428	791
	HDD65	8029	1475	1260	1105	696	380	146	26	47	214	553	871	1256
	CDD50	1868	0	0	2	16	130	337	555	495	269	58	6	0
	CDD65	255	0	0	0	0	5	31	116	78	24	1	0	0
	CDH74	2393	0	0	5	10	120	349	1016	669	214	10	0	0
	CDH80	521	0	0	0	2	28	81	234	130	45	1	0	0
Wind	WSAvg	3.6	4.3	4.7	4.8	4.5	3.6	2.9	2.5	2.6	2.8	3.4	3.6	3.8
Precipitation	PrecAvg	39.3	3.1	2.4	2.9	2.9	3.2	3.3	3.2	3.2	3.6	3.3	3.7	3.8
	PrecMax	57.1	8.5	5.8	6.2	6.8	7.1	8.4	7.7	7.8	9.4	7.1	11.2	8.8
	PrecMin	26.1	0.4	0.5	0.2	0.6	0.1	1.1	0.6	0.5	0.7	1.0	0.8	1.3
	PrecStd	7.4	1.7	1.2	1.5	1.5	1.5	1.6	1.7	1.7	1.8	1.4	1.9	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.0	50.9	62.2	73.4	84.0	87.0	88.8	87.3	86.0	74.9	62.5	53.5
		MCWB	50.8	46.8	51.7	59.9	65.7	70.8	73.1	72.3	72.2	62.1	59.0	52.3
	2%	DB	45.6	44.2	51.4	65.8	77.2	82.0	85.4	83.6	79.7	67.8	58.6	48.2
		MCWB	43.7	38.7	44.0	53.7	61.5	68.1	71.0	70.0	67.7	60.9	54.4	46.3
	5%	DB	39.6	39.5	46.7	60.3	71.5	77.9	82.5	80.4	75.6	64.1	54.6	43.6
		MCWB	37.0	36.1	40.8	49.6	58.5	64.6	69.7	68.0	66.3	59.0	49.7	40.9
	10%	DB	34.8	35.9	42.9	55.6	67.2	74.2	79.8	77.7	71.7	60.8	50.6	39.1
		MCWB	32.1	32.5	38.1	48.0	56.2	61.6	67.7	66.0	64.3	56.3	47.2	36.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.5	50.0	57.5	60.2	69.3	72.4	76.3	74.4	73.3	66.3	59.3	52.2
		MCDB	51.4	51.1	70.8	66.9	79.6	83.3	86.2	83.4	84.5	68.7	60.8	52.9
	2%	WB	44.5	41.4	46.9	55.9	64.5	69.5	73.5	72.3	71.0	63.0	55.3	47.3
		MCDB	45.4	44.3	51.1	59.6	72.8	77.5	82.9	80.2	78.1	65.5	57.0	48.2
	5%	WB	38.3	37.0	41.5	52.1	61.6	66.7	71.8	70.4	68.7	60.8	50.2	42.1
		MCDB	40.3	40.0	45.7	56.7	67.7	73.7	80.2	77.2	74.4	63.8	53.2	43.7
	10%	WB	33.4	33.5	37.6	48.4	58.5	64.3	70.2	68.8	66.6	57.5	46.5	37.3
		MCDB	35.2	35.7	41.2	54.0	65.2	70.9	77.5	75.1	71.0	61.0	49.8	39.4
Mean Daily Temperature Range	5% DB	MDBR	19.0	20.3	19.0	20.5	21.6	20.8	21.2	21.6	22.1	19.1	16.3	16.4
		MCDBR	20.7	20.6	23.4	30.9	30.2	27.2	24.5	24.7	25.0	23.8	21.5	20.6
		MCWBR	20.6	18.3	16.7	17.4	15.8	14.6	12.3	12.3	13.7	15.8	17.9	18.1
	5% WB	MCDBR	21.2	21.5	21.8	21.4	23.7	23.2	21.1	20.4	20.9	18.6	19.6	19.0
		MCWBR	21.1	19.1	16.9	15.1	14.8	13.8	11.5	11.0	13.1	14.7	17.6	18.8
Clear-Sky Solar Irradiance	taub	0.277	0.288	0.315	0.345	0.371	0.408	0.423	0.399	0.361	0.327	0.305	0.284	
	taud	2.454	2.402	2.450	2.427	2.394	2.290	2.270	2.334	2.426	2.529	2.552	2.505	
	Ebn at Noon	270	287	293	291	285	273	267	270	273	270	258	256	
	Edh at Noon	22	28	31	34	37	41	41	37	31	25	20	19	
All-Sky Solar Radiation	RadAvg	496	773	1156	1433	1610	1746	1799	1610	1306	815	502	380	
	RadStd	49	72	77	149	198	135	143	95	81	75	47	36	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+97	N/A

Nomenclature: See separate page