

CAMBRIDGE, MN, USA

WMO: 727503

Lat: 45.559N

Lon: 93.265W

Elev: 945

StdP: 14.20

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 04909

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.8	-10.7	-24.4	1.5	-14.3	-18.4	2.1	-9.0	18.9	15.3	17.5	15.5	2.3	280	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.7	90.5	74.6	87.8	73.1	83.8	71.2	77.0	86.9	74.8	84.1	72.6	81.7	8.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.3	128.3	82.6	72.0	122.6	81.5	69.9	114.1	79.5	41.1	86.6	38.8	84.2	36.9	81.7	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.2	16.1	13.5	DB	-23.3	96.5	6.7	5.9	-28.1	100.8	-32.0	104.3	-35.7	107.6	-40.6	111.9	(4)
			WB	-23.5	80.0	6.3	2.5	-28.0	81.8	-31.7	83.3	-35.3	84.7	-39.8	86.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.4	13.5	17.8	30.6	44.7	56.9	66.8	71.8	68.7	61.1	47.6	33.1	19.2
	DBStd	22.66	13.73	12.81	12.56	10.03	8.72	7.36	6.14	6.08	9.04	9.26	11.06	12.68
	HDD50	4537	1133	903	611	217	30	1	0	0	14	157	516	955
	HDD65	8089	1598	1323	1068	612	279	65	13	30	179	544	958	1420
	CDD50	2510	1	0	9	58	246	504	675	579	347	83	8	0
	CDD65	584	0	0	0	3	29	117	223	144	63	5	0	0
	CDH74	5603	8	0	4	49	373	1158	2174	1260	529	48	0	0
	CDH80	1793	5	0	0	12	118	362	772	372	145	7	0	0
	WSAvg	5.4	5.3	5.6	5.8	6.5	6.2	5.2	4.6	4.2	5.1	5.9	5.8	5.2
	PrecAvg	31.0	0.9	0.8	1.5	2.7	3.3	4.6	4.2	3.9	3.3	2.9	1.8	1.0
Precipitation	PrecMax	39.3	2.0	1.7	3.0	7.4	6.9	7.6	7.2	9.7	7.0	6.8	5.4	2.0
	PrecMin	22.8	0.0	0.1	0.7	0.6	0.7	2.4	1.2	0.7	0.7	1.1	0.0	0.4
	PrecStd	5.0	0.6	0.5	0.7	1.5	1.7	1.6	1.7	2.0	1.9	1.5	1.5	0.5
	PrecStd	5.0	0.6	0.5	0.7	1.5	1.7	1.6	1.7	2.0	1.9	1.5	1.5	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	45.5	52.1	70.0	81.0	90.4	92.7	96.7	92.9	90.1	80.6	66.0	47.9
		MCWB	38.8	45.4	57.2	62.2	71.0	74.8	76.5	73.5	73.9	66.4	55.6	43.9
	2%	DB	38.6	43.4	60.9	72.5	82.1	88.2	90.7	88.1	83.9	72.9	59.4	43.0
		MCWB	34.9	38.0	52.2	55.6	65.8	72.1	75.7	74.4	71.2	61.2	51.3	38.3
	5%	DB	35.8	38.8	54.2	67.6	78.5	83.8	88.0	83.7	80.8	66.5	54.2	38.0
		MCWB	33.0	35.2	47.1	53.6	62.9	70.1	74.1	71.8	68.4	57.6	47.4	34.6
	10%	DB	32.0	36.0	47.7	63.0	72.8	81.0	84.0	81.2	75.4	63.1	48.2	36.0
		MCWB	29.9	33.2	42.3	50.5	59.7	67.3	72.0	69.5	65.3	54.8	43.1	33.5
	0.4%	WB	39.0	45.5	59.7	63.9	73.6	77.7	80.4	79.1	75.3	68.4	57.5	44.4
		MCDB	43.9	50.8	66.8	77.6	88.0	89.7	90.6	88.1	84.9	76.6	63.4	47.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.5	39.1	52.1	58.5	68.1	74.3	77.7	75.8	72.2	63.0	52.6	38.6
		MCDB	38.1	42.8	60.5	69.2	79.1	84.2	87.7	84.7	80.9	70.4	59.0	42.3
	5%	WB	32.4	35.9	46.8	54.4	64.6	71.6	75.6	73.1	69.6	59.4	47.2	35.4
		MCDB	34.9	39.0	52.7	65.5	74.8	81.4	84.7	81.2	78.2	66.6	52.9	37.8
	10%	WB	29.7	32.8	42.0	51.0	61.4	69.0	73.4	70.8	67.0	55.2	43.6	33.0
		MCDB	31.6	35.5	47.2	60.8	71.0	78.4	82.5	78.7	75.2	61.8	48.1	35.5
Mean Daily Temperature Range	5% DB	MDBR	17.1	18.0	18.1	20.8	21.8	20.9	20.7	20.4	20.7	18.2	15.5	14.5
		MCDBR	18.0	18.6	24.7	29.1	28.6	24.3	23.3	23.1	23.7	24.9	22.8	15.9
		MCWBR	14.4	14.7	17.0	17.1	16.0	12.9	11.9	12.7	13.2	15.8	15.9	13.2
	5% WB	MCDBR	16.7	17.6	23.2	26.0	25.1	21.6	21.1	20.7	21.4	22.2	21.2	15.0
		MCWBR	14.4	14.0	16.7	16.9	15.9	13.2	12.6	12.9	13.1	15.3	15.6	12.7
		MCWBR	14.4	14.0	16.7	16.9	15.9	13.2	12.6	12.9	13.1	15.3	15.6	12.7
Clear-Sky Solar Irradiance	taub		0.263	0.272	0.316	0.375	0.407	0.393	0.388	0.399	0.370	0.317	0.288	0.264
	taud		2.397	2.363	2.366	2.286	2.244	2.329	2.366	2.340	2.393	2.536	2.508	2.421
	Ebn at Noon		272	291	291	280	273	277	277	269	268	272	262	259
	Edh at Noon		23	29	33	39	43	39	37	37	32	24	21	20
All-Sky Solar Radiation	RadAvg		538	884	1234	1472	1691	1872	1980	1650	1276	797	503	373
	RadStd		60	82	107	138	138	138	66	122	87	106	45	48

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page