

JORDAN, MT, USA

WMO: 727684

Lat: 47.326N

Lon: 106.948W

Elev: 2662

StdP: 13.34

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 94051

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-21.5	-14.4	-26.0	1.4	-17.8	-20.0	2.0	-12.7	29.9	29.7	26.6	25.5	3.5	280	0.656

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.6	96.5	64.2	92.9	63.4	89.6	62.7	68.3	86.9	66.4	84.9	64.8	83.3	10.3	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.8	94.3	74.8	60.4	86.6	72.8	57.9	79.1	70.8	34.1	87.9	32.5	84.3	31.1	82.8	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.6	23.3	19.9	-31.9	101.9	7.2	3.0	-37.0	104.1	-41.3	105.9	-45.3	107.6	-50.5	109.8		
			-28.9	70.8	4.8	2.2	-32.3	72.4	-35.2	73.6	-37.9	74.9	-41.4	76.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	44.3	18.5	19.6	33.0	44.0	53.2	63.0	72.2	69.5	58.6	45.0	31.9	20.9
	DBStd	21.67	15.59	15.81	13.50	8.61	8.16	7.04	6.16	6.85	8.37	8.71	12.65	15.50
	HDD50	4308	977	850	534	215	60	3	0	0	21	201	545	902
	HDD65	8073	1442	1270	992	631	374	117	10	34	222	622	992	1367
	CDD50	2216	0	0	7	35	158	394	688	604	281	45	3	1
	CDD65	505	0	0	0	0	8	58	233	173	32	1	0	0
	CDH74	8718	0	0	2	41	228	1024	3608	2823	918	74	0	0
	CDH80	4095	0	0	0	6	51	358	1857	1408	397	18	0	0
Wind	WSAvg	8.3	7.6	7.5	8.6	9.6	9.5	8.9	8.1	8.0	7.8	8.3	7.8	7.1
Precipitation	PrecAvg	13.0	0.4	0.3	0.6	1.2	2.0	2.5	1.7	1.1	1.1	0.8	0.4	0.4
	PrecMax	22.1	1.7	1.8	1.4	3.3	4.9	5.7	7.4	3.2	5.2	2.9	1.2	1.7
	PrecMin	5.9	0.0	0.0	0.0	0.2	0.2	0.4	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.6	0.4	0.3	0.3	0.8	1.1	1.5	1.4	0.8	1.2	0.7	0.3	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.6	60.0	71.5	79.4	85.6	94.5	101.2	100.1	95.0	82.1	67.9	61.5
		MCWB	41.9	43.8	50.0	54.1	61.3	65.0	65.9	64.7	62.3	56.6	50.2	41.1
	2%	DB	46.5	50.3	64.9	72.2	80.2	88.3	97.2	95.7	89.8	73.3	60.1	52.0
		MCWB	37.8	40.5	47.8	52.7	58.8	64.5	65.0	63.3	60.0	52.6	45.6	39.2
	5%	DB	42.4	44.8	58.7	66.6	75.4	83.9	93.7	92.2	84.5	67.6	54.8	45.8
		MCWB	35.7	36.7	44.6	49.4	56.9	62.5	64.3	62.7	58.7	51.1	43.0	36.8
	10%	DB	38.9	39.8	52.6	61.6	70.8	80.0	90.4	88.4	79.0	61.8	49.8	41.1
		MCWB	33.7	34.2	41.7	46.9	54.6	60.8	63.8	61.8	57.1	48.2	40.5	34.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.7	45.7	51.1	56.5	63.8	69.6	71.5	69.4	65.9	58.5	51.5	43.1
		MCDB	52.5	57.8	68.1	76.6	78.0	87.4	89.0	89.2	83.0	78.1	65.7	56.6
	2%	WB	38.7	41.0	48.4	53.0	60.8	66.5	69.1	66.7	62.3	54.6	46.8	40.0
		MCDB	45.7	50.0	63.7	70.1	75.7	82.7	87.7	86.7	82.4	69.1	58.2	50.0
	5%	WB	36.1	37.1	45.3	50.4	58.3	64.4	67.3	64.8	60.0	51.7	43.5	37.1
		MCDB	41.4	43.7	58.2	65.3	72.3	79.9	86.0	84.7	80.5	65.5	53.6	45.9
	10%	WB	34.0	34.4	42.1	47.7	55.9	62.3	65.6	63.1	57.9	49.3	40.6	34.5
		MCDB	38.7	39.8	52.0	59.9	68.3	77.1	84.3	83.2	77.6	61.3	48.9	41.2
Mean Daily Temperature Range	5% DB	MDBR	22.6	23.0	23.8	25.3	24.8	25.9	30.6	30.8	30.0	25.6	24.6	23.1
		MCDBR	24.4	27.3	34.0	35.6	32.9	33.6	35.9	37.6	41.8	37.1	31.3	26.4
		MCWBR	17.5	18.1	19.0	18.5	15.7	14.4	12.0	13.6	18.0	19.3	18.9	17.0
	5% WB	MCDBR	23.4	25.8	32.8	32.9	29.3	29.3	30.8	31.3	35.9	33.9	30.6	25.5
		MCWBR	17.4	17.8	18.8	17.3	14.4	13.6	11.8	12.1	15.9	18.2	19.2	17.4
Clear-Sky Solar Irradiance	taub	0.248	0.255	0.271	0.309	0.332	0.346	0.356	0.360	0.317	0.282	0.257	0.244	
	taud	2.550	2.574	2.587	2.470	2.454	2.455	2.442	2.396	2.503	2.593	2.572	2.538	
	Ebn at Noon	278	299	307	301	296	291	286	280	285	283	272	266	
	Edh at Noon	18	23	26	32	34	34	34	35	28	22	18	16	
All-Sky Solar Radiation	RadAvg	469	764	1131	1563	1885	2140	2266	1892	1375	881	530	361	
	RadStd	44	64	118	76	162	133	85	110	107	64	57	30	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page