

JORDAN, MT, USA

WMO: 727684

Lat: 47.326N

Lon: 106.948W

Elev: 811

StdP: 91.95

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 94051

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.7	-25.8	-32.2	0.2	-27.6	-28.9	0.3	-24.8	13.4	-1.3	11.9	-3.6	1.5	280	0.656

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.0	35.8	17.9	33.8	17.4	32.0	17.1	20.2	30.5	19.1	29.4	18.2	28.5	4.6	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	13.5	23.8	15.8	12.4	22.6	14.4	11.3	21.6	61.4	31.1	57.7	29.0	54.5	28.2	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.9	10.4	8.9	-35.5	38.9	4.0	1.7	-38.4	40.1	-40.7	41.0	-42.9	42.0	-45.8	43.2		
			-33.8	21.5	2.7	1.2	-35.7	22.4	-37.3	23.1	-38.8	23.8	-40.8	24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	6.8	-7.5	-6.9	0.6	6.7	11.8	17.2	22.3	20.8	14.8	7.2	0.0	-6.2
	DBStd	12.04	8.66	8.78	7.50	4.78	4.53	3.91	3.42	3.81	4.65	4.84	7.03	8.61
	HDD10.0	2393	543	472	297	119	33	2	0	0	12	112	303	501
	HDD18.3	4485	801	706	551	351	208	65	6	19	123	346	551	759
	CDD10.0	1231	0	0	4	19	88	219	382	336	156	25	2	1
	CDD18.3	281	0	0	0	0	4	32	129	96	18	1	0	0
	CDH23.3	4843	0	0	1	23	127	569	2004	1568	510	41	0	0
	CDH26.7	2275	0	0	0	3	28	199	1032	782	221	10	0	0
Wind	WSAvg	3.7	3.4	3.4	3.8	4.3	4.3	4.0	3.6	3.6	3.5	3.7	3.5	3.2
Precipitation	PrecAvg	330	11	8	14	30	52	63	44	29	28	21	9	11
	PrecMax	562	43	45	36	83	124	144	188	82	132	74	31	43
	PrecMin	149	0	0	0	4	4	9	0	1	1	0	0	0
	PrecStd	92	10	8	8	21	28	37	36	21	31	17	8	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	15.6	22.0	26.3	29.8	34.7	38.5	37.8	35.0	27.8	19.9	16.4
		MCWB	5.5	6.5	10.0	12.3	16.3	18.4	18.8	18.2	16.8	13.7	10.1	5.1
	2%	DB	8.0	10.2	18.3	22.3	26.8	31.3	36.2	35.4	32.1	22.9	15.6	11.1
		MCWB	3.2	4.7	8.8	11.5	14.9	18.1	18.3	17.4	15.6	11.4	7.5	4.0
	5%	DB	5.8	7.1	14.8	19.2	24.1	28.8	34.3	33.4	29.2	19.8	12.6	7.7
		MCWB	2.1	2.6	7.0	9.7	13.8	16.9	17.9	17.0	14.9	10.6	6.1	2.6
	10%	DB	3.8	4.3	11.4	16.4	21.6	26.7	32.4	31.3	26.1	16.6	9.9	5.1
		MCWB	1.0	1.2	5.4	8.3	12.6	16.0	17.7	16.6	14.0	9.0	4.7	1.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.0	7.6	10.6	13.6	17.7	20.9	21.9	20.8	18.8	14.7	10.8	6.2
		MCDB	11.4	14.4	20.1	24.8	25.6	30.8	31.6	31.8	28.3	25.6	18.7	13.6
	2%	WB	3.7	5.0	9.1	11.7	16.0	19.2	20.6	19.3	16.8	12.5	8.2	4.4
		MCDB	7.6	10.0	17.6	21.1	24.3	28.2	31.0	30.4	28.0	20.6	14.6	10.0
	5%	WB	2.3	2.8	7.4	10.2	14.6	18.0	19.6	18.2	15.5	11.0	6.4	2.8
		MCDB	5.2	6.5	14.5	18.5	22.4	26.6	30.0	29.3	26.9	18.6	12.0	7.7
	10%	WB	1.1	1.3	5.6	8.7	13.3	16.8	18.7	17.3	14.4	9.6	4.8	1.4
		MCDB	3.7	4.3	11.1	15.5	20.2	25.1	29.1	28.5	25.3	16.3	9.4	5.1
Mean Daily Temperature Range	5% DB	MDBR	12.6	12.8	13.2	14.0	13.8	14.4	17.0	17.1	16.7	14.2	13.7	12.8
		MCDBR	13.5	15.1	18.9	19.8	18.3	18.7	19.9	20.9	23.2	20.6	17.4	14.6
		MCWBR	9.7	10.1	10.5	10.3	8.7	8.0	6.7	7.5	10.0	10.7	10.5	9.4
	5% WB	MCDBR	13.0	14.3	18.2	18.3	16.3	16.3	17.1	17.4	19.9	18.8	17.0	14.2
		MCWBR	9.7	9.9	10.5	9.6	8.0	7.6	6.6	6.7	8.8	10.1	10.6	9.7
Clear-Sky Solar Irradiance	taub	0.248	0.255	0.271	0.309	0.332	0.346	0.356	0.360	0.317	0.282	0.257	0.244	
	taud	2.550	2.574	2.587	2.470	2.454	2.455	2.442	2.396	2.503	2.593	2.572	2.538	
	Ebn at Noon	876	942	968	949	932	917	902	883	899	891	856	838	
	Edh at Noon	58	71	82	102	107	108	108	109	89	69	57	52	
All-Sky Solar Radiation	RadAvg	1.48	2.41	3.57	4.93	5.94	6.75	7.14	5.96	4.34	2.78	1.67	1.14	
	RadStd	0.14	0.20	0.37	0.24	0.51	0.42	0.27	0.35	0.34	0.20	0.18	0.09	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page