

GREAT FALLS, MT, USA

WMO: 727760

Lat: 47.4614N

Lon: 111.3847W

Elev: 1131

StdP: 88.46

Time Zone: -7.00 (NAM)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-26.2	-22.7	-29.3	0.3	-25.9	-25.7	0.4	-22.5	16.1	6.5	14.9	5.9	2.7	220	0.702

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	33.8	16.1	31.9	15.6	30.0	15.2	17.8	29.2	16.9	28.1	16.1	27.1	4.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	11.7	19.6	13.0	10.7	19.4	11.9	9.9	18.9	54.2	29.3	51.2	27.7	48.8	27.1	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	12.1	10.9	DB	-30.9	36.9	3.4	1.7	-33.4	38.1	-35.4	39.1	-37.3	40.1	-39.8	41.3	(4)
(5)			WB	-31.0	19.8	3.3	1.2	-33.3	20.7	-35.2	21.4	-37.1	22.1	-39.5	22.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.3	-3.4	-3.3	1.3	6.0	11.0	15.4	20.6	19.6	14.4	7.5	1.3	-3.4	(6)	
	DBStd	10.58	8.65	8.46	7.41	5.20	4.52	3.87	3.55	3.67	5.00	5.63	7.61	8.22	(7)	
	HDD10.0	2062	416	373	276	138	42	4	0	0	17	113	268	415	(8)	
	HDD18.3	4218	673	605	529	371	231	102	18	29	137	338	511	673	(9)	
	CDD10.0	1079	1	1	5	17	72	167	329	299	148	34	7	0	(10)	
	CDD18.3	194	0	0	0	0	2	15	89	70	17	1	0	0	(11)	
	CDH23.3	3216	0	0	0	7	76	281	1395	1117	326	14	0	0	(12)	
	CDH26.7	1348	0	0	0	1	12	85	648	487	114	2	0	0	(13)	
(14) Wind	WSAvg	5.0	6.0	5.3	5.3	5.0	4.6	4.3	4.0	4.0	4.4	5.3	6.0	6.0	(14)	
(15) Precipitation	PrecAvg	363	18	12	24	35	59	64	32	38	30	20	15	16	(15)	
	PrecMax	595	48	31	53	109	132	174	119	124	82	81	43	49	(16)	
	PrecMin	231	1	0	2	1	13	12	1	1	2	0	2	1	(17)	
	PrecStd	86	12	8	14	24	28	37	27	30	20	16	11	12	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.5	15.1	19.6	24.3	28.4	32.4	36.8	35.7	32.7	25.3	19.3	12.9	(19)	
		MCWB	5.3	6.3	8.3	11.1	14.2	16.6	17.5	16.2	15.1	12.0	9.0	5.5	(20)	
	2%	DB	10.8	11.9	16.6	20.9	25.5	29.1	34.5	33.4	30.0	21.9	15.6	10.5	(21)	
		MCWB	4.4	4.9	7.1	9.9	13.1	15.9	16.6	15.5	14.3	10.6	7.4	4.2	(22)	
	5%	DB	8.8	9.6	13.9	17.8	22.9	26.5	32.5	31.6	27.3	18.9	13.1	8.4	(23)	
		MCWB	3.2	3.5	5.9	8.5	12.1	14.9	16.0	15.2	13.4	9.6	5.9	3.0	(24)	
	10%	DB	6.9	7.3	11.4	15.0	20.1	24.2	30.5	29.6	24.4	16.0	10.9	6.4	(25)	
		MCWB	2.1	2.3	4.6	7.0	11.0	13.9	15.5	14.9	12.5	8.2	4.9	1.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.5	7.1	9.0	12.1	15.2	18.7	19.3	17.9	16.8	13.3	9.9	6.3	(27)	
		MCDB	11.8	13.7	18.0	22.1	25.5	28.0	30.6	30.2	27.3	23.4	17.6	12.0	(28)	
	2%	WB	4.7	5.2	7.7	10.4	13.9	17.0	18.2	16.9	15.3	11.3	7.9	4.8	(29)	
		MCDB	10.1	11.1	15.8	19.4	23.7	26.3	30.3	29.0	26.6	20.1	14.9	9.8	(30)	
	5%	WB	3.5	3.8	6.2	9.0	12.7	15.8	17.3	16.2	14.2	10.0	6.4	3.3	(31)	
		MCDB	8.3	9.1	13.5	17.1	21.3	24.6	28.9	28.2	25.6	17.8	12.5	7.8	(32)	
	10%	WB	2.3	2.4	4.9	7.5	11.5	14.7	16.5	15.4	13.0	8.7	5.1	1.9	(33)	
		MCDB	6.5	7.2	10.9	14.4	19.1	22.7	27.7	27.1	23.4	15.7	10.6	6.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.0	10.6	11.9	12.5	13.0	13.7	17.1	16.9	14.6	12.1	10.0	9.4	(35)	
		MCDBR	10.6	12.5	15.0	17.2	17.5	17.7	20.0	20.2	19.4	16.1	12.1	10.2	(36)	
	5% WB	MCWBR	6.6	7.4	8.1	8.7	7.9	7.3	7.1	7.3	8.0	7.9	6.6	6.5	(37)	
		MCWBR	10.2	12.1	14.3	16.3	15.8	16.0	17.8	18.0	18.0	14.9	12.1	10.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.247	0.256	0.272	0.315	0.326	0.327	0.331	0.348	0.312	0.282	0.255	0.242	(40)	
		taud	2.508	2.519	2.545	2.422	2.441	2.477	2.480	2.391	2.469	2.554	2.539	2.497	(41)	
	Ebn at Noon	Ebn at Noon	872	936	966	941	938	934	926	894	903	888	853	833	(42)	
		Edh at Noon	60	74	85	106	109	106	104	109	91	71	58	54	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.46	2.44	3.63	4.83	5.71	6.60	7.21	5.96	4.30	2.72	1.61	1.16	(44)	
	RadStd	RadStd	0.09	0.17	0.28	0.27	0.51	0.44	0.37	0.33	0.33	0.24	0.13	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page