

STAMPASS PASS, WA, USA

WMO: 727815

Lat: 47.277N

Lon: 121.337W

Elev: 3959

StdP: 12.71

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24237

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.6	12.1	0.3	6.5	12.8	5.5	8.4	15.3	21.1	29.1	19.1	27.3	9.0	80	0.646

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.5	80.0	59.2	76.2	58.1	72.5	56.9	61.6	75.3	59.8	72.6	58.1	69.7	5.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.5	78.8	65.7	54.7	73.8	63.5	53.1	69.6	61.4	29.2	74.9	27.9	72.7	26.7	69.7	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	14.9	12.8	DB	7.1	86.4	5.6	5.6	3.0	90.4	-0.2	93.7	-3.4	96.8	-7.4	100.9
			WB	4.7	65.4	5.9	2.3	0.4	67.1	-3.0	68.5	-6.4	69.8	-10.7	71.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	41.1	27.6	28.7	33.1	37.8	44.8	50.1	57.6	58.3	52.9	42.0	33.0	26.7	(6)
	DBStd	13.37	7.87	6.33	6.19	7.16	8.36	8.33	7.93	8.06	7.99	6.69	6.56	6.51	(7)
	HDD50	4085	696	596	526	374	208	98	18	16	57	263	510	723	(8)
	HDD65	8788	1160	1016	990	815	626	453	256	241	372	712	959	1188	(9)
	CDD50	849	0	0	1	9	48	103	254	273	144	16	1	0	(10)
	CDD65	76	0	0	0	0	1	7	27	33	8	0	0	0	(11)
	CDH74	565	0	0	0	0	11	63	211	236	44	0	0	0	(12)
	CDH80	109	0	0	0	0	1	12	46	45	5	0	0	0	(13)
(14) Wind	WSAvg	6.4	6.6	6.8	6.3	6.3	6.6	6.7	6.9	6.5	6.0	5.9	6.2	6.5	(14)
(15) Precipitation	PrecAvg	85.5	12.8	8.7	7.6	6.0	4.2	3.6	1.7	2.3	4.2	6.8	12.3	13.4	(15)
	PrecMax	124.1	30.4	20.8	15.5	12.5	9.1	7.6	5.9	7.2	9.6	23.5	21.1	28.5	(16)
	PrecMin	55.0	1.0	0.7	1.2	0.5	1.6	0.4	0.2	0.1	0.3	0.5	2.2	1.7	(17)
	PrecStd	17.4	7.2	4.9	3.1	2.8	1.7	1.8	1.2	2.0	2.8	4.7	5.0	6.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	49.6	55.2	65.4	74.9	80.5	85.8	84.8	79.2	66.1	54.1	46.7	(19)
		MCWB	43.5	39.3	42.5	48.9	55.6	58.3	61.9	60.9	56.8	51.3	45.7	40.5	(20)
	2%	DB	44.5	42.9	50.0	58.5	68.5	74.2	79.4	80.2	73.9	59.4	48.2	40.8	(21)
		MCWB	38.8	37.1	41.4	46.4	52.5	56.0	59.9	59.3	55.7	48.6	44.0	38.5	(22)
	5%	DB	39.7	39.1	45.4	53.7	62.9	68.9	75.5	76.0	69.7	54.9	44.9	37.0	(23)
		MCWB	37.1	35.6	39.0	43.9	50.0	54.1	58.9	58.4	54.2	46.4	42.2	35.3	(24)
	10%	DB	36.2	36.2	42.0	49.1	58.1	64.0	71.3	71.8	65.5	51.4	42.2	34.3	(25)
		MCWB	34.8	33.6	36.7	41.6	47.9	52.4	57.5	57.4	52.7	45.0	39.8	33.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.7	41.9	46.6	50.9	57.2	60.2	64.8	64.0	60.0	54.6	48.2	42.8	(27)
		MCDB	48.7	45.4	51.4	61.5	71.4	75.1	79.5	78.0	72.0	59.8	50.8	45.3	(28)
	2%	WB	40.4	38.9	42.7	47.9	53.4	57.4	62.0	61.6	57.7	50.3	45.1	38.4	(29)
		MCDB	42.2	41.5	47.5	56.4	64.7	71.3	75.9	75.7	68.9	56.7	47.1	39.9	(30)
	5%	WB	37.0	36.0	39.5	44.9	51.2	55.2	60.0	59.8	55.8	48.2	42.5	35.5	(31)
		MCDB	38.8	38.5	44.3	52.7	61.0	66.7	72.7	72.5	66.9	52.7	44.5	37.3	(32)
	10%	WB	34.6	33.9	37.3	42.0	49.1	53.0	58.2	58.1	53.9	46.2	39.9	33.3	(33)
		MCDB	36.1	35.7	41.1	48.1	56.6	62.6	69.4	69.6	63.3	50.3	41.9	34.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	7.9	9.2	11.4	13.2	14.4	16.9	16.5	14.2	10.5	6.9	6.4	(35)
		MCDBR	11.3	12.5	14.3	19.1	21.0	22.2	22.2	21.8	20.0	15.9	10.6	10.4	(36)
	5% WB	MCWBR	8.4	8.5	8.2	9.9	9.9	10.1	9.9	9.7	9.9	9.6	8.3	9.1	(37)
		MCWBR	10.0	10.1	12.5	18.0	18.7	20.7	20.8	20.7	18.4	13.5	10.0	10.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.268	0.264	0.277	0.316	0.327	0.320	0.310	0.312	0.299	0.289	0.273	0.277	(40)
		taud	2.439	2.460	2.453	2.366	2.444	2.504	2.554	2.551	2.593	2.608	2.568	2.392	(41)
	Ebn at Noon		265	292	303	298	297	299	301	297	293	280	264	244	(42)
		Edh at Noon	21	25	30	36	35	33	31	30	26	22	18	19	(43)
(44) All-Sky Solar Radiation	RadAvg		356	651	991	1467	1806	2043	2283	1926	1392	818	419	280	(44)
	RadStd		46	79	96	119	136	143	133	116	99	92	51	40	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+20

Nomenclature: See separate page