

STAMPASS PASS, WA, USA

WMO: 727815

Lat: 47.277N

Lon: 121.337W

Elev: 1207

StdP: 87.64

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24237

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-13.5	-11.0	-17.6	0.9	-10.6	-14.7	1.2	-9.3	9.4	-1.6	8.5	-2.6	4.0	80	0.646

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	26.7	15.1	24.5	14.5	22.5	13.8	16.4	24.1	15.4	22.5	14.5	21.0	2.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
13.6	11.3	18.7	12.6	10.5	17.5	11.7	9.9	16.3	50.1	23.9	47.0	22.6	44.1	21.0	21.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.6	5.7	-13.9	30.2	3.1	3.1	-16.1	32.5	-17.9	34.3	-19.6	36.0	-21.9	38.3		
(5)			DB	WB	-15.2	18.6	3.3	1.3	-17.5	19.5	-19.5	20.3	-21.3	21.0	-23.7	21.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.1	-2.5	-1.8	0.6	3.2	7.1	10.1	14.2	14.6	11.6	5.6	0.6	-3.0
	DBStd	7.43	4.37	3.52	3.44	3.98	4.64	4.63	4.41	4.48	4.44	3.72	3.64	3.62
	HDD10.0	2269	387	331	292	208	116	54	10	9	32	146	283	402
	HDD18.3	4882	644	564	550	453	348	252	142	134	207	396	533	660
	CDD10.0	472	0	0	1	5	27	57	141	152	80	9	1	0
	CDD18.3	42	0	0	0	0	1	4	15	18	4	0	0	0
	CDH23.3	314	0	0	0	0	6	35	117	131	24	0	0	0
	CDH26.7	61	0	0	0	0	1	7	26	25	3	0	0	0
	WSAvg	2.9	2.9	3.0	2.8	2.8	2.9	3.0	3.1	2.9	2.7	2.6	2.8	2.9
(15) Precipitation	PrecAvg	2171	324	222	194	152	107	92	43	59	106	173	312	340
	PrecMax	3152	773	528	394	318	232	194	151	182	245	598	536	725
	PrecMin	1398	25	17	31	12	40	9	5	3	7	13	56	44
	PrecStd	441	184	124	80	72	43	46	30	52	70	120	127	159
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	9.8	12.9	18.6	23.9	27.0	29.9	29.3	26.2	19.0	12.3	8.2
		MCWB	6.4	4.1	5.8	9.4	13.1	14.6	16.6	16.1	13.8	10.7	7.6	4.7
	2%	DB	7.0	6.0	10.0	14.7	20.3	23.5	26.4	26.8	23.3	15.2	9.0	4.9
		MCWB	3.8	2.8	5.2	8.0	11.4	13.3	15.5	15.2	13.2	9.2	6.7	3.6
	5%	DB	4.3	3.9	7.5	12.0	17.2	20.5	24.1	24.5	20.9	12.7	7.2	2.8
		MCWB	2.8	2.0	3.9	6.6	10.0	12.3	14.9	14.7	12.3	8.0	5.7	1.8
	10%	DB	2.3	2.3	5.6	9.5	14.5	17.8	21.9	22.1	18.6	10.8	5.7	1.3
		MCWB	1.6	0.9	2.6	5.4	8.8	11.3	14.2	14.1	11.5	7.2	4.4	0.6
	0.4%	WB	7.6	5.5	8.1	10.5	14.0	15.7	18.2	17.8	15.6	12.6	9.0	6.0
		MCDB	9.3	7.5	10.8	16.4	21.9	23.9	26.4	25.6	22.2	15.5	10.4	7.4
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	4.7	3.9	5.9	8.9	11.9	14.1	16.7	16.4	14.3	10.2	7.3	3.6
		MCDB	5.6	5.3	8.6	13.5	18.2	21.8	24.4	24.3	20.5	13.7	8.4	4.4
	5%	WB	2.8	2.2	4.2	7.1	10.7	12.9	15.6	15.4	13.2	9.0	5.8	1.9
		MCDB	3.8	3.6	6.9	11.5	16.1	19.3	22.6	22.5	19.4	11.5	6.9	3.0
	10%	WB	1.4	1.0	3.0	5.5	9.5	11.7	14.5	14.5	12.1	7.9	4.4	0.7
		MCDB	2.3	2.1	5.1	8.9	13.7	17.0	20.8	20.9	17.4	10.2	5.5	1.3
(35) Mean Daily Temperature Range	5% DB	MDBR	3.8	4.4	5.1	6.3	7.3	8.0	9.4	9.2	7.9	5.8	3.8	3.5
		MCDBR	6.3	6.9	7.9	10.6	11.7	12.3	12.3	12.1	11.1	8.9	5.9	5.8
		MCWBR	4.6	4.7	4.5	5.5	5.5	5.6	5.5	5.4	5.5	5.3	4.6	5.0
		MCDBR	5.5	5.6	6.9	10.0	10.4	11.5	11.5	11.5	10.2	7.5	5.6	5.8
	5% WB	MCWBR	4.6	4.4	4.5	5.5	5.3	5.7	5.5	5.4	5.4	5.3	4.7	5.3
(40) Clear-Sky Solar Irradiance	taub		0.268	0.264	0.277	0.316	0.327	0.320	0.310	0.312	0.299	0.289	0.273	0.277
	taud		2.439	2.460	2.453	2.366	2.444	2.504	2.554	2.551	2.593	2.608	2.568	2.392
	Ebn at Noon		835	922	956	939	937	942	948	935	923	884	832	768
	Edh at Noon		65	79	93	113	109	103	97	93	81	68	58	61
(44) All-Sky Solar Radiation	RadAvg		1.12	2.05	3.12	4.62	5.69	6.44	7.20	6.07	4.39	2.58	1.32	0.88
	RadStd		0.14	0.25	0.30	0.37	0.43	0.45	0.42	0.37	0.31	0.29	0.16	0.13

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+11

Nomenclature: See separate page