

GRANT COUNTY INTL, WA, USA

WMO: 727827

Lat: 47.208N

Lon: 119.319W

Elev: 365

StdP: 97.02

Time Zone: -8.00 (NAP)

Period: 97-19

WBAN: 24110

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-13.8	-10.8	-17.9	0.8	-12.1	-15.0	1.1	-8.8	11.0	3.5	9.5	3.8	2.5	350	0.560

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	36.8	19.2	34.9	18.1	32.9	17.8	20.6	33.4	19.4	32.0	18.5	31.1	3.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.1	12.0	25.4	14.3	10.6	23.8	13.1	9.8	22.9	60.6	32.9	56.5	32.3	53.3	31.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	8.4	7.4	DB	-17.6	39.7	5.0	1.7	-21.1	40.9	-24.0	41.9	-26.8	42.8	-30.4	44.0	(4)
(5)			WB	-17.9	21.9	4.9	2.1	-21.5	23.5	-24.4	24.7	-27.1	25.9	-30.7	27.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	-0.9	2.0	6.5	10.4	15.4	19.3	23.5	22.7	17.4	10.2	3.4	-1.3	(6)
(7)		DBStd	9.36	4.68	3.92	3.51	3.31	3.86	3.65	3.20	3.06	3.53	3.73	4.67	4.66	(7)
(8)		HDD10.0	1309	337	225	116	34	3	0	0	0	1	42	201	349	(8)
(9)		HDD18.3	3169	596	458	368	238	107	31	2	3	58	253	448	607	(9)
(10)		CDD10.0	1585	0	1	7	46	171	278	417	392	222	48	3	1	(10)
(11)		CDD18.3	403	0	0	0	1	17	58	161	137	29	1	0	0	(11)
(12)		CDH23.3	6451	0	0	0	32	352	940	2481	2056	575	16	0	0	(12)
(13)		CDH26.7	3128	0	0	0	5	117	401	1339	1049	215	2	0	0	(13)
(14)	Wind	WSAvg	3.2	2.6	3.0	3.5	3.7	3.6	3.7	3.3	3.0	3.0	2.8	2.5	(14)	
(15)	Precipitation	PrecAvg	181	23	12	17	13	16	17	5	6	6	17	22	28	(15)
(16)		PrecMax	260	67	28	40	31	42	41	18	21	18	64	45	64	(16)
(17)		PrecMin	114	4	0	4	1	4	0	0	1	1	3	3	3	(17)
(18)		PrecStd	47	17	7	9	8	12	13	5	6	5	14	11	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	14.1	19.8	27.0	32.9	37.4	39.1	38.0	34.7	25.8	17.0	12.7	(19)
(20)			MCWB	7.2	8.9	11.4	14.2	16.3	19.7	19.7	19.4	17.9	15.0	11.6	8.5	(20)
(21)		2%	DB	8.6	11.4	17.4	23.2	30.0	33.6	37.2	36.3	31.6	22.2	14.0	9.0	(21)
(22)			MCWB	5.3	6.8	9.9	12.6	15.7	18.4	19.6	18.8	17.5	13.1	9.1	6.2	(22)
(23)		5%	DB	6.6	9.7	15.3	21.1	27.3	31.1	35.3	34.1	29.0	19.7	12.1	7.0	(23)
(24)			MCWB	4.2	5.8	8.4	11.4	14.7	17.2	18.2	18.0	15.9	11.4	8.2	4.7	(24)
(25)		10%	DB	4.5	7.8	13.4	18.2	24.7	28.5	33.6	32.4	26.9	17.5	10.1	4.5	(25)
(26)			MCWB	2.8	4.7	7.4	9.9	13.5	15.9	17.9	17.6	15.1	10.5	7.0	2.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.5	9.6	12.2	15.1	17.8	21.7	22.8	21.9	20.0	16.0	12.2	9.1	(27)
(28)			MCDWB	10.3	13.5	18.2	25.0	30.4	31.5	36.3	35.7	32.0	23.2	15.5	12.8	(28)
(29)		2%	WB	5.7	7.6	10.4	13.1	16.4	19.2	20.8	20.1	18.0	13.8	10.2	6.6	(29)
(30)			MCDWB	8.0	10.6	16.0	22.0	27.6	31.9	33.7	33.0	29.4	20.0	13.2	8.9	(30)
(31)		5%	WB	4.4	6.3	9.3	11.8	15.4	17.8	19.7	19.0	16.8	12.5	8.8	4.8	(31)
(32)			MCDWB	6.3	9.0	14.4	19.9	25.2	29.9	32.4	31.7	27.2	18.2	11.3	6.6	(32)
(33)		10%	WB	3.0	5.1	8.1	10.5	14.3	16.5	18.6	18.1	15.6	11.4	7.5	3.0	(33)
(34)			MCDWB	4.1	7.6	12.6	17.3	23.0	26.9	31.4	30.3	25.0	16.5	9.6	4.2	(34)
(35)	Mean Daily Temperature Range			MDBR	6.3	8.9	11.9	13.7	14.5	14.7	16.9	16.2	13.2	9.1	6.4	(35)
(36)		5% DB	MCDBR	8.5	11.0	14.7	17.9	18.6	18.8	19.8	20.0	20.0	15.9	11.0	8.6	(36)
(37)			MCWBR	6.2	7.1	8.4	8.9	7.4	7.6	7.4	7.7	9.0	8.5	7.2	6.3	(37)
(38)		5% WB	MCDWB	7.9	10.0	13.6	17.0	16.5	17.9	18.0	18.0	18.0	13.6	9.8	7.8	(38)
(39)			MCWBR	5.9	6.8	8.3	8.8	7.0	7.6	7.6	7.6	8.6	7.8	6.8	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.278	0.282	0.293	0.321	0.335	0.336	0.337	0.337	0.323	0.303	0.287	0.273	(40)
(41)		taud		2.528	2.573	2.573	2.460	2.437	2.462	2.455	2.447	2.485	2.543	2.547	2.526	(41)
(42)		Ebn at Noon		831	906	942	936	929	926	920	907	891	863	811	793	(42)
(43)		Edh at Noon		61	72	84	103	109	107	107	103	90	73	60	55	(43)
(44)	All-Sky Solar Radiation	RadAvg		1.09	2.21	3.54	5.24	6.38	7.01	7.59	6.35	4.68	2.88	1.45	0.90	(44)
(45)		RadStd		0.13	0.28	0.24	0.32	0.39	0.39	0.29	0.34	0.26	0.23	0.16	0.12	(45)

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days						
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46)	Station Only	N/A	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	+125	+70	(46)		
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	-0.36	N/A	N/A	N/A	+98	+49	(47)		

Nomenclature: See separate page