

COEUR D'ALENE, ID, USA

WMO: 727834

Lat: 47.767N

Lon: 116.817W

Elev: 2307

StdP: 13.51

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24136

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.7	11.5	-4.3	4.8	7.8	2.8	6.9	15.0	27.0	40.5	23.6	33.3	9.1	30	0.594

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	28.7	92.0	63.3	89.7	62.9	85.5	61.6	66.2	86.1	64.4	84.1	62.8	81.8	6.6	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
59.1	81.5	71.9	56.8	75.0	70.3	54.9	69.9	69.3	32.1	86.5	30.7	83.5	29.4	82.2	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.9	18.8	16.7	-2.6	97.1	7.5	3.8	-8.0	99.9	-12.4	102.1	-16.6	104.2	-22.0	107.0		
(5)			-3.4	69.2	7.3	2.1	-8.7	70.7	-13.0	72.0	-17.1	73.2	-22.4	74.8	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.5	29.7	31.8	38.6	45.6	54.4	60.4	69.0	68.2	59.5	46.6	36.5	28.9	(6)	(7)
	DBStd	15.70	8.04	7.70	6.65	6.20	7.17	6.85	6.17	5.95	7.04	6.72	7.39	7.84	(7)	(8)
	HDD50	2908	628	510	355	162	35	4	0	0	7	145	408	654	(8)	(9)
	HDD65	6734	1093	930	818	581	335	171	32	36	193	570	856	1119	(9)	(10)
	CDD50	2007	0	0	2	31	172	316	589	563	292	40	2	0	(10)	(11)
	CDD65	358	0	0	0	0	7	33	156	135	27	0	0	0	(11)	(12)
	CDH74	5577	0	0	0	12	188	552	2274	2019	523	9	0	0	(12)	(13)
	CDH80	2272	0	0	0	1	37	179	1007	879	169	0	0	0	(13)	(14)
	WSAvg	7.4	7.6	7.9	8.0	8.1	7.7	7.2	6.7	6.7	7.0	7.1	7.6	7.5	(14)	(15)
	PrecAvg	25.8	3.4	2.4	2.4	1.7	2.1	1.9	0.9	1.4	1.2	1.5	3.4	3.6	(15)	(16)
(16) Precipitation	PrecMax	34.1	8.2	5.7	4.9	3.5	4.8	4.6	3.2	3.7	2.6	3.5	8.7	7.8	(16)	(17)
	PrecMin	19.1	0.4	0.5	0.2	0.2	0.5	0.5	0.0	0.0	0.0	0.0	0.6	0.8	(17)	(18)
	PrecStd	3.9	1.9	1.3	1.2	0.8	1.1	1.1	0.8	1.1	0.7	1.0	1.9	1.7	(18)	(19)
															(19)	(20)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	48.1	53.6	63.2	75.1	84.0	91.1	97.3	96.6	90.5	73.3	58.0	49.8	(20)	(21)
		MCWB	44.1	45.0	48.7	55.7	60.8	64.7	65.8	63.7	61.1	56.3	52.2	44.0	(21)	(22)
	2%	DB	44.6	47.8	56.9	69.6	79.4	84.3	92.7	91.8	84.3	66.3	53.8	44.9	(22)	(23)
		MCWB	40.6	42.4	46.1	53.3	59.1	62.3	64.2	62.6	59.6	52.4	48.2	41.3	(23)	(24)
	5%	DB	41.1	44.9	53.7	63.3	74.6	80.8	90.0	89.6	80.7	62.6	49.6	41.0	(24)	(25)
		MCWB	38.2	39.7	44.6	49.7	56.6	60.8	63.5	62.1	58.4	50.7	45.0	38.3	(25)	(26)
	10%	DB	38.6	41.4	49.3	57.5	70.1	75.3	85.9	84.4	75.0	57.1	46.3	37.5	(26)	(27)
		MCWB	36.3	37.6	42.3	46.1	54.6	58.4	62.2	60.8	56.7	48.1	42.7	35.6	(27)	(28)
	0.4%	WB	44.5	46.0	50.5	57.2	62.6	66.9	69.5	66.7	64.3	58.6	53.6	45.7	(28)	(29)
		MCDB	46.8	50.7	58.5	72.9	79.6	86.7	89.0	88.7	81.6	69.7	57.2	47.6	(29)	(30)
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	40.8	43.0	47.8	53.6	60.0	64.1	67.3	64.7	61.5	54.6	48.8	41.4	(30)	(31)
		MCDB	43.9	46.6	55.5	66.5	76.4	82.1	86.6	86.2	81.1	63.8	52.4	44.5	(31)	(32)
	5%	WB	38.5	40.3	45.3	50.5	57.8	61.8	65.4	63.4	59.4	52.1	45.8	38.5	(32)	(33)
		MCDB	40.9	44.2	52.0	61.1	72.0	78.0	85.2	84.8	77.3	60.0	48.6	40.9	(33)	(34)
	10%	WB	36.9	38.0	43.2	48.1	55.4	59.7	63.6	62.0	57.5	49.7	43.6	36.7	(34)	(35)
		MCDB	38.4	41.1	48.6	57.1	67.7	73.5	82.2	82.2	72.7	56.7	46.5	38.2	(35)	(36)
	5% DB	MDBR	9.8	13.6	17.0	19.8	22.6	22.6	28.7	29.3	26.2	19.4	12.4	9.9	(36)	(37)
		MCDBR	11.5	16.7	24.0	28.9	30.9	30.9	34.4	35.5	34.1	26.2	15.7	11.3	(37)	(38)
		MCWBR	9.0	11.7	15.1	15.8	14.4	13.6	13.1	13.6	14.5	14.6	11.1	9.1	(38)	(39)
		MCWBR	10.9	14.9	21.0	26.3	27.9	28.4	30.9	31.3	30.2	22.4	14.2	10.8	(39)	(40)
(40) Clear-Sky Solar Irradiance	taub		0.274	0.281	0.292	0.342	0.352	0.349	0.346	0.361	0.334	0.301	0.283	0.270	(40)	(41)
		taud	2.463	2.485	2.552	2.400	2.407	2.445	2.453	2.418	2.476	2.574	2.563	2.485	(41)	(42)
	Ebn at Noon		261	285	298	289	289	290	289	279	278	274	257	249	(42)	(43)
		Edh at Noon	20	24	27	35	36	35	34	34	29	22	18	17	(43)	(44)
(44) All-Sky Solar Radiation	RadAvg		325	619	947	1422	1832	1964	2326	1931	1373	810	383	256	(44)	(45)
	RadStd		43	84	115	138	147	176	134	130	133	94	43	34	(45)	(46)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+166	+67	

Nomenclature: See separate page