

COEUR D'ALENE, ID, USA

WMO: 727834

Lat: 47.767N

Lon: 116.817W

Elev: 703

StdP: 93.16

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 24136

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-14.1	-11.4	-20.2	0.7	-13.4	-16.2	1.0	-9.5	12.1	4.7	10.6	0.7	4.1	30	0.594

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.9	33.3	17.4	32.1	17.1	29.7	16.4	19.0	30.1	18.0	28.9	17.1	27.7	2.9	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.1	11.6	22.2	13.8	10.7	21.3	12.7	10.0	20.7	56.8	30.3	53.4	28.6	50.6	27.9	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.4	7.5	-19.2	36.2	4.2	2.1	-22.2	37.7	-24.6	38.9	-27.0	40.1	-30.0	41.7		
(5)			-19.7	20.7	4.1	1.2	-22.6	21.5	-25.0	22.2	-27.3	22.9	-30.2	23.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	-1.3	-0.1	3.7	7.6	12.5	15.8	20.6	20.1	15.3	8.1	2.5	-1.7		
	DBStd	8.72	4.47	4.28	3.69	3.44	3.98	3.81	3.43	3.31	3.91	3.73	4.11	4.36		
	HDD10.0	1616	349	283	197	90	19	2	0	0	4	81	227	363		
	HDD18.3	3741	607	517	454	323	186	95	18	20	107	317	476	622		
	CDD10.0	1115	0	0	1	17	96	176	327	313	162	22	1	0		
	CDD18.3	199	0	0	0	0	4	18	87	75	15	0	0	0		
	CDH23.3	3098	0	0	0	7	104	307	1263	1122	291	5	0	0		
	CDH26.7	1262	0	0	0	1	21	99	559	488	94	0	0	0		
	WSAvg	3.3	3.4	3.5	3.6	3.6	3.4	3.2	3.0	3.0	3.1	3.2	3.4	3.4		
	PrecAvg	656	86	60	60	43	54	48	22	35	30	38	87	92		
(15) Precipitation	PrecMax	865	209	144	125	90	121	117	82	93	65	89	222	199		
	PrecMin	484	10	12	4	6	12	12	0	0	0	0	14	20		
	PrecStd	99	48	34	30	21	28	28	20	29	19	26	47	43		
	PrecStd	99	48	34	30	21	28	28	20	29	19	26	47	43		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.0	12.0	17.3	24.0	28.9	32.8	36.3	35.9	32.5	22.9	14.4	9.9		
		MCWB	6.7	7.2	9.3	13.2	16.0	18.2	18.8	17.6	16.2	13.5	11.2	6.6		
	2%	DB	7.0	8.8	13.9	20.9	26.3	29.0	33.7	33.2	29.1	19.1	12.1	7.2		
		MCWB	4.8	5.8	7.8	11.8	15.0	16.8	17.9	17.0	15.3	11.4	9.0	5.2		
	5%	DB	5.0	7.2	12.1	17.4	23.7	27.1	32.2	32.0	27.0	17.0	9.8	5.0		
		MCWB	3.4	4.3	7.0	9.8	13.7	16.0	17.5	16.7	14.7	10.4	7.2	3.5		
	10%	DB	3.7	5.2	9.6	14.2	21.1	24.1	29.9	29.1	23.9	14.0	7.9	3.1		
		MCWB	2.4	3.1	5.7	7.8	12.5	14.6	16.8	16.0	13.7	8.9	5.9	2.0		
	0.4%	WB	6.9	7.8	10.3	14.0	17.0	19.4	20.8	19.3	18.0	14.8	12.0	7.6		
		MCDB	8.2	10.4	14.7	22.7	26.4	30.4	31.7	31.5	27.6	20.9	14.0	8.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	4.9	6.1	8.8	12.0	15.5	17.8	19.6	18.2	16.4	12.5	9.3	5.2		
		MCDB	6.6	8.1	13.1	19.2	24.6	27.8	30.3	30.1	27.3	17.7	11.4	6.9		
	5%	WB	3.6	4.6	7.4	10.3	14.3	16.6	18.5	17.4	15.2	11.2	7.7	3.6		
		MCDB	4.9	6.8	11.1	16.2	22.2	25.6	29.6	29.3	25.2	15.6	9.2	4.9		
	10%	WB	2.7	3.3	6.2	8.9	13.0	15.4	17.5	16.6	14.2	9.8	6.5	2.6		
		MCDB	3.6	5.1	9.2	13.9	19.8	23.1	27.9	27.9	22.6	13.7	8.0	3.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	7.5	9.5	11.0	12.5	12.6	15.9	16.3	14.6	10.8	6.9	5.5		
		MCDBR	6.4	9.3	13.4	16.0	17.2	17.2	19.1	19.7	18.9	14.6	8.7	6.3		
		MCWBR	5.0	6.5	8.4	8.8	8.0	7.6	7.3	7.6	8.1	8.1	6.2	5.1		
		MCDBR	6.0	8.3	11.7	14.6	15.5	15.8	17.1	17.4	16.8	12.4	7.9	6.0		
	5% WB	MCWBR	4.9	6.0	7.8	8.3	7.4	7.2	6.9	6.8	7.4	7.3	5.9	5.0		
		MCWBR	4.9	6.0	7.8	8.3	7.4	7.2	6.9	6.8	7.4	7.3	5.9	5.0		
(40) Clear-Sky Solar Irradiance	taub		0.274	0.281	0.292	0.342	0.352	0.349	0.346	0.361	0.334	0.301	0.283	0.270		
	taud		2.463	2.485	2.552	2.400	2.407	2.445	2.453	2.418	2.476	2.574	2.563	2.485		
	Ebn at Noon		822	897	940	911	911	913	910	881	877	863	811	784		
	Edh at Noon		63	77	85	109	112	109	107	106	91	70	58	55		
(44) All-Sky Solar Radiation	RadAvg		1.02	1.95	2.99	4.48	5.78	6.19	7.33	6.09	4.33	2.55	1.21	0.81		
	RadStd		0.14	0.27	0.36	0.43	0.46	0.55	0.42	0.41	0.42	0.29	0.14	0.11		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+92	+37

Nomenclature: See separate page