

PORT ANGELES FAIRCHILD, WA, USA

WMO: 727885

Lat: 48.120N

Lon: 123.498W

Elev: 88

StdP: 100.27

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 94266

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-3.7	-2.3	-9.2	1.7	-1.0	-6.8	2.2	-0.5	8.9	6.7	7.8	6.5	1.9	230	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.1	26.0	16.6	23.0	15.6	21.2	15.2	17.3	23.6	16.5	21.8	15.7	20.1	2.5	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.0	10.8	18.3	14.1	10.1	17.5	13.7	9.9	17.2	48.8	23.5	46.1	21.8	44.1	20.1	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.7	5.6	-6.6	30.7	2.3	2.3	-8.2	32.4	-9.6	33.7	-10.9	35.0	-12.6	36.7		
(5)			-7.4	19.3	2.3	1.4	-9.0	20.3	-10.3	21.1	-11.6	21.8	-13.2	22.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	4.4	4.5	6.0	8.2	11.0	13.3	15.5	15.8	13.9	9.6	6.2	4.0	(6)
(7)		DBStd	4.90	2.73	2.64	2.31	2.19	2.40	2.43	2.16	1.99	2.15	2.33	2.86	2.60	(7)
(8)		HDD10.0	873	175	154	126	63	17	1	0	0	1	34	117	184	(8)
(9)		HDD18.3	3278	433	387	383	305	228	154	93	84	134	271	364	443	(9)
(10)		CDD10.0	651	1	1	1	8	47	101	171	179	118	22	3	0	(10)
(11)		CDD18.3	14	0	0	0	0	0	3	6	5	1	0	0	0	(11)
(12)		CDH23.3	212	0	0	0	0	3	40	73	76	20	0	0	0	(12)
(13)		CDH26.7	51	0	0	0	0	0	9	21	19	3	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.0	2.0	2.3	2.7	2.8	2.9	3.0	2.5	2.1	1.9	2.0	2.1	(14)
(15)	Precipitation	PrecAvg	832	135	78	76	48	35	26	16	25	21	88	164	130	(15)
(16)		PrecMax	1154	220	221	169	103	73	60	39	65	59	222	360	199	(16)
(17)		PrecMin	522	52	0	22	13	6	7	4	4	1	21	41	67	(17)
(18)		PrecStd	167	50	49	36	23	18	11	10	20	16	49	87	39	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	13.0	15.1	19.6	23.2	27.7	29.2	29.0	25.8	18.5	14.2	11.9	(19)
(20)			MCWB	9.4	9.0	9.8	12.2	13.8	16.0	18.2	17.4	16.4	12.6	12.0	10.1	(20)
(21)		2%	DB	10.4	10.9	12.6	16.2	20.0	23.1	25.1	25.6	22.7	16.4	12.6	10.0	(21)
(22)			MCWB	8.8	8.2	9.1	10.3	13.0	15.3	16.7	16.7	15.2	11.8	10.8	8.4	(22)
(23)		5%	DB	9.1	9.6	11.2	13.9	17.5	19.8	22.2	22.5	20.9	14.9	11.4	8.7	(23)
(24)			MCWB	7.8	7.6	8.2	9.6	12.4	14.2	15.8	16.0	14.8	11.5	9.9	7.3	(24)
(25)		10%	DB	8.1	8.6	10.0	12.4	15.6	17.6	20.1	20.4	18.7	13.6	10.2	7.7	(25)
(26)			MCWB	6.9	6.8	7.6	8.9	11.7	13.3	15.1	15.4	14.2	11.0	8.9	6.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	10.2	11.0	12.7	15.1	17.2	19.1	18.4	17.6	14.9	12.8	10.5	(27)
(28)			MCDWB	11.3	12.3	13.5	18.1	19.9	24.4	27.5	25.5	23.2	17.2	13.6	11.1	(28)
(29)		2%	WB	9.1	8.9	9.7	11.1	14.0	15.7	17.3	17.3	16.3	13.2	11.4	8.5	(29)
(30)			MCDWB	9.9	10.3	11.7	14.7	18.6	21.8	23.7	23.6	20.9	14.8	12.2	9.4	(30)
(31)		5%	WB	8.0	7.9	8.8	10.2	12.9	14.7	16.2	16.5	15.4	12.2	10.2	7.7	(31)
(32)			MCDWB	8.8	9.2	10.7	13.2	16.8	19.3	21.3	21.7	19.2	13.7	11.1	8.3	(32)
(33)		10%	WB	7.3	7.1	7.9	9.3	11.9	13.7	15.4	15.7	14.7	11.4	9.1	6.8	(33)
(34)			MCDWB	8.1	8.3	9.6	11.9	15.0	17.3	19.5	19.9	17.9	13.0	10.0	7.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.7	6.5	7.1	7.6	7.7	7.8	8.7	9.1	9.1	7.4	6.4	5.5	(35)
(36)			MCDBR	6.5	7.2	8.5	10.7	12.1	13.0	13.6	14.0	13.2	9.2	6.5	5.9	(36)
(37)			MCWBR	5.0	5.2	5.7	6.2	6.6	6.4	6.6	6.7	6.9	5.7	5.0	4.7	(37)
(38)		5% WB	MCDWR	5.8	6.3	7.7	9.4	9.9	10.6	11.2	11.0	10.4	7.3	5.9	5.4	(38)
(39)			MCWBR	4.6	4.8	5.4	5.8	5.8	5.7	5.8	5.7	6.0	5.3	4.8	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.318	0.319	0.332	0.360	0.383	0.361	0.351	0.354	0.341	0.333	0.330	0.316	(40)	
(41)		taud	2.494	2.518	2.497	2.415	2.370	2.454	2.518	2.510	2.546	2.552	2.471	2.453	(41)	
(42)		Ebn at Noon	759	849	890	892	880	900	905	889	870	819	732	707	(42)	
(43)		Edh at Noon	63	76	90	107	117	108	100	97	85	72	64	58	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.95	1.83	2.82	4.22	5.38	5.88	6.47	5.48	3.94	2.18	1.13	0.77	(44)	
(45)		RadStd	0.13	0.24	0.33	0.40	0.43	0.57	0.47	0.36	0.34	0.24	0.17	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	-0.80	-2.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (69 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page