

NANISIVIK AP, NU, Canada

WMO: 729140

Lat: 72.980N

Lon: 84.620W

Elev: 642

StdP: 93.85

Time Zone: -5.00 (NAE)

Period: 00-10

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 2	(b) -39.2	(c) -37.4	(d) -43.5	(e) 0.1	(f) -38.9	(g) -41.9	(h) 0.1	(i) -37.4	(j) 18.0	(k) -23.1	(l) 15.8	(m) -25.1	(n) 3.1	(o) 140	(p) 1.118

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 4.2	(c) 13.4	(d) 9.6	(e) 12.0	(f) 8.7	(g) 10.6	(h) 7.7	(i) 10.7	(j) 12.2	(k) 9.0	(l) 11.5	(m) 7.8	(n) 10.3	(o) 4.6	(p) 340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 9.8	(b) 8.1	(c) 11.6	(d) 7.6	(e) 7.0	(f) 9.7	(g) 6.1	(h) 6.3	(i) 8.6	(j) 32.7	(k) 12.2	(l) 28.5	(m) 11.5	(n) 25.8	(o) 10.4	(p) 14.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 15.9	(b) 13.0	(c) 11.0	(e) -41.5	(f) 14.9	(g) 2.2	(h) 2.7	(i) -43.1	(j) 16.8	(k) -44.3	(l) 18.3	(m) -45.6	(n) 19.8	(o) -47.1	(p) 21.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-13.2	-27.7	-27.9	-26.3	-18.7	-9.3	0.0	6.1	3.3	-4.2	-10.9	-20.5	-24.0		
	DBStd	12.96	4.55	5.99	6.53	4.93	4.80	3.37	3.91	4.31	3.80	4.63	5.28	6.30		
	HDD10.0	8496	1169	1060	1125	862	597	300	130	211	424	648	914	1054		
	HDD18.3	11524	1428	1293	1383	1112	856	550	378	466	674	907	1164	1313		
	CDD10.0	14	0	0	0	0	0	0	11	3	0	0	0	0		
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH27.7	0	0	0	0	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	4.5	4.0	4.1	4.9	4.7	4.3	4.4	4.9	4.8	4.1	5.2	4.7	3.9		
(15) Precipitation	PrecAvg	206	5	4	9	11	14	20	36	39	25	24	11	8		
	PrecMax	371	13	14	41	43	44	39	91	75	61	64	31	20		
	PrecMin	116	0	2	0	1	3	1	5	8	7	7	1	0		
	PrecStd	58	3	3	8	10	10	12	18	18	13	14	6	4		
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-12.8	-4.8	-6.7	-3.5	1.3	11.2	15.9	14.3	5.2	-0.2	-6.9	-3.4		
		MCWB	-13.9	-5.3	-7.7	-6.1	-1.1	7.1	11.9	10.3	1.4	-0.6	-7.4	-5.3		
	2%	DB	-16.0	-14.7	-9.8	-7.2	0.0	8.7	14.2	12.2	3.4	-2.4	-9.0	-8.7		
		MCWB	-16.9	-15.6	-10.8	-8.6	-1.9	5.9	10.1	10.0	1.7	-3.1	-9.4	-9.5		
	5%	DB	-18.4	-17.6	-14.9	-10.2	-1.5	6.1	13.1	10.9	2.2	-3.5	-11.1	-12.5		
		MCWB	-19.1	-18.2	-15.6	-11.2	-2.9	3.9	9.2	8.7	1.2	-4.0	-11.6	-13.6		
	10%	DB	-21.1	-20.2	-17.9	-12.1	-2.8	4.4	11.8	9.6	0.7	-4.5	-12.7	-15.1		
		MCWB	-21.8	-20.8	-18.5	-13.0	-3.9	2.5	8.1	7.5	-0.1	-5.0	-13.3	-15.7		
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-14.2	-4.7	-7.5	-5.8	-0.6	7.7	12.7	11.6	2.7	-0.5	-7.3	-4.7		
		MCDB	-13.2	-4.1	-6.6	-3.9	0.6	10.2	14.6	12.6	3.4	-0.3	-6.8	-3.5		
	2%	WB	-17.7	-15.4	-10.5	-8.7	-1.6	5.9	11.7	10.5	2.0	-2.8	-9.4	-9.1		
		MCDB	-17.0	-14.5	-9.7	-7.4	-0.4	8.9	13.5	11.8	3.1	-2.6	-9.1	-8.3		
	5%	WB	-19.5	-18.0	-15.1	-11.1	-2.7	4.2	9.6	9.2	1.1	-3.8	-11.4	-13.8		
		MCDB	-18.8	-17.4	-14.6	-10.3	-1.6	5.9	12.1	11.2	2.2	-3.6	-11.2	-12.8		
	10%	WB	-22.1	-20.7	-18.2	-12.9	-3.9	2.9	8.3	7.6	0.1	-4.9	-13.3	-15.7		
		MCDB	-21.5	-20.2	-17.6	-12.3	-3.0	4.2	11.2	9.3	0.7	-4.5	-12.8	-15.0		
(35) Mean Daily Temperature Range	MDBR		4.7	4.7	4.9	4.7	4.2	3.5	4.2	3.8	2.8	3.8	4.6	4.7		
	5% DB	MCDBR	6.9	6.5	7.0	5.3	4.9	4.5	4.9	4.4	3.9	4.1	5.6	6.2		
		MCWBR	5.8	6.4	6.7	4.6	4.2	3.3	3.0	2.9	3.0	3.9	5.4	5.6		
	5% WB	MCDBR	6.4	6.7	7.4	5.1	5.0	4.3	4.9	4.7	3.4	3.9	5.7	6.3		
		MCWBR	5.9	6.4	7.0	4.5	4.4	3.2	3.3	3.0	2.8	3.8	5.5	5.9		
(40) Clear-Sky Solar Irradiance	taub		N/A	0.152	0.219	0.271	0.286	0.284	0.297	0.282	0.239	0.160	N/A	N/A		
	taud		N/A	1.926	2.211	2.135	2.205	2.429	2.515	2.544	2.431	1.935	N/A	N/A		
	Ebn at Noon		0	480	773	837	878	901	874	843	761	419	0	0		
	Edh at Noon		0	26	60	98	107	89	80	67	50	23	0	0		
(44) All-Sky Solar Radiation	RadAvg		0.00	0.16	1.51	4.12	6.20	6.32	4.97	3.21	1.29	0.31	0.00	0.00		
	RadStd		0.00	0.02	0.10	0.20	0.36	0.69	0.48	0.40	0.20	0.05	0.00	0.00		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page