

NICHOLSON PENINSULA, NT, Canada

WMO: 729560

Lat: 69.930N

Lon: 128.970W

Elev: 89

StdP: 100.26

Time Zone: -7.00 (NAM)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-41.0	-39.3	-39.5	0.1	-35.7	-38.6	0.1	-35.2	16.4	-16.7	15.0	-13.2	4.0	250	1.093

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	19.9	14.2	17.6	12.8	15.5	11.6	14.6	18.7	13.1	17.1	11.7	15.3	4.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.4	9.0	17.3	10.8	8.1	15.4	9.4	7.4	13.5	41.3	19.0	37.2	17.3	33.7	15.4	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.4	12.5	11.1	DB	-41.9	23.1	2.8	2.6	-43.8	25.0	-45.5	26.5	-47.0	28.0	-49.0	29.9	(4)
(5)			WB	-37.7	16.3	0.7	1.7	-38.2	17.6	-38.6	18.6	-39.0	19.6	-39.5	20.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-11.5	-28.5	-28.1	-24.9	-16.6	-6.0	4.5	8.1	6.7	1.4	-8.4	-22.2	-25.1	(6)
(7)		DBStd	14.95	6.74	7.98	6.41	6.86	5.52	5.08	5.13	3.97	4.06	6.19	6.58	6.85	(7)
(8)		HDD10.0	7918	1194	1066	1082	797	497	179	101	118	259	572	966	1087	(8)
(9)		HDD18.3	10887	1452	1299	1340	1047	756	415	317	360	509	830	1216	1346	(9)
(10)		CDD10.0	76	0	0	0	0	0	14	43	17	1	0	0	0	(10)
(11)		CDD18.3	2	0	0	0	0	0	0	2	0	0	0	0	0	(11)
(12)		CDH23.3	7	0	0	0	0	0	1	6	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	5.4	5.3	5.5	4.5	5.5	5.9	5.9	5.2	5.8	6.1	6.0	4.3	4.3	(14)
(15)	Precipitation	PrecAvg	107	3	3	3	2	4	9	20	30	16	10	3	3	(15)
(16)		PrecMax	184	14	15	15	8	13	46	53	62	36	25	11	13	(16)
(17)		PrecMin	63	0	0	0	0	0	0	0	4	3	0	0	0	(17)
(18)		PrecStd	31	4	4	3	2	4	9	13	17	9	7	3	3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-7.3	-6.7	-5.8	0.9	9.7	21.5	24.1	20.5	14.0	3.6	-5.8	-6.5	(19)
(20)			MCWB	-7.7	-7.0	-6.4	0.1	6.8	13.8	16.7	15.6	10.8	2.3	-6.2	-6.9	(20)
(21)		2%	DB	-10.9	-8.9	-9.3	-2.3	5.7	17.8	20.8	17.3	10.4	1.5	-7.2	-9.2	(21)
(22)			MCWB	-11.2	-9.2	-9.6	-2.7	4.3	11.7	14.4	13.5	8.1	0.7	-7.6	-9.7	(22)
(23)		5%	DB	-15.7	-12.0	-12.5	-5.0	3.1	16.0	19.0	15.2	8.3	0.0	-9.7	-11.2	(23)
(24)			MCWB	-16.1	-12.3	-12.9	-5.4	2.3	11.0	13.8	11.9	6.4	-0.4	-10.1	-11.6	(24)
(25)		10%	DB	-18.5	-15.7	-15.6	-7.1	1.1	13.4	16.6	12.9	6.5	-1.3	-13.3	-14.5	(25)
(26)			MCWB	-18.8	-16.0	-15.9	-7.5	0.6	9.4	12.6	10.4	5.1	-1.6	-13.7	-14.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-7.4	-6.7	-6.3	0.2	7.3	14.1	17.9	15.8	10.8	2.6	-6.1	-6.8	(27)
(28)			MCDWB	-7.1	-6.4	-5.9	0.8	9.3	19.4	23.9	19.8	13.6	3.3	-5.9	-6.6	(28)
(29)		2%	WB	-10.8	-8.7	-9.6	-2.7	4.3	12.4	15.2	13.9	8.4	0.9	-7.6	-9.5	(29)
(30)			MCDWB	-10.5	-8.5	-9.2	-2.4	5.7	17.3	19.5	17.0	10.2	1.4	-7.3	-9.1	(30)
(31)		5%	WB	-15.5	-11.5	-12.6	-5.5	2.3	11.2	14.0	12.0	6.7	-0.4	-10.1	-11.5	(31)
(32)			MCDWB	-15.2	-11.2	-12.3	-5.1	3.2	15.8	18.3	14.7	8.1	0.1	-9.6	-11.2	(32)
(33)		10%	WB	-18.1	-15.0	-15.8	-7.5	0.6	9.5	12.6	10.4	5.2	-1.6	-13.5	-14.6	(33)
(34)			MCDWB	-17.6	-14.7	-15.4	-7.2	1.1	13.5	16.5	12.7	6.3	-1.4	-13.2	-14.2	(34)
(35)	Mean Daily Temperature Range	MDBR	5.2	5.4	5.6	5.7	5.0	6.9	6.8	5.7	4.0	3.5	4.2	4.9	(35)	
(36)		5% DB	MCDBR	9.0	8.6	8.1	7.2	7.3	11.6	10.4	9.2	7.8	3.5	5.7	8.1	(36)
(37)			MCWBR	8.8	8.5	8.0	7.0	6.1	7.2	6.0	5.9	5.7	3.2	5.7	8.0	(37)
(38)		5% WB	MCDWB	9.2	8.7	8.1	7.2	7.4	11.2	9.5	8.7	7.5	3.4	5.7	8.0	(38)
(39)			MCWBR	9.1	8.6	8.0	7.0	6.2	7.4	6.1	6.0	5.8	3.1	5.7	7.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	N/A	0.196	0.243	0.299	0.330	0.327	0.336	0.320	0.290	0.216	N/A	N/A	(40)	
(41)		taud	N/A	2.069	2.201	2.113	2.167	2.383	2.468	2.540	2.541	2.181	N/A	N/A	(41)	
(42)		Ebn at Noon	0	570	785	827	843	866	845	820	748	526	0	0	(42)	
(43)		Edh at Noon	0	38	70	108	117	98	88	73	54	32	0	0	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.00	0.39	1.98	4.40	5.90	6.28	5.25	3.22	1.65	0.47	0.00	0.00	(44)	
(45)		RadStd	0.00	0.03	0.09	0.19	0.49	0.51	0.53	0.37	0.16	0.05	0.00	0.00	(45)	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days					
			99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (4 neighbors)		+0.66	+1.25	+1.60	N/A	N/A	N/A	-273	-260	N/A	N/A	(47)

Nomenclature: See separate page