

GLADMAN POINT, NU, Canada

WMO: 729720

Lat: 68.670N

Lon: 97.800W

Elev: 14

StdP: 101.16

Time Zone: -7.00 (NAM)

Period: 82-93

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-44.7	-43.1	-40.4	0.1	-36.5	-39.6	0.1	-36.2	15.7	-29.0	13.3	-30.7	2.7	N/A	1.162

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.7	15.5	11.9	13.5	10.3	11.5	9.1	12.2	15.2	10.5	13.1	9.1	11.3	4.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.2	7.7	14.1	8.8	7.0	11.8	7.5	6.4	10.5	34.5	15.5	30.6	13.2	27.3	11.4	16.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.3	12.5	11.0	DB	-46.1	18.7	2.3	2.3	-47.7	20.3	-49.0	21.7	-50.3	23.0	-51.9	24.7	
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	-15.3	-35.5	-34.8	-30.5	-21.9	-10.0	1.2	7.7	4.7	-0.1	-10.7	-24.1	-30.4
	DBStd	16.33	5.45	5.87	5.76	6.61	5.59	3.97	3.47	2.91	3.43	6.35	7.47	6.11
	HDD10.0	9245	1411	1254	1257	956	621	265	90	168	304	643	1023	1253
	HDD18.3	12264	1669	1487	1515	1206	879	514	330	423	554	901	1273	1512
	CDD10.0	23	0	0	0	0	0	1	18	3	0	0	0	0
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.5	5.1	5.0	5.6	5.3	5.3	5.3	5.1	5.8	6.0	6.4	5.6	5.1
Precipitation	PrecAvg	125	2	2	3	5	10	10	25	28	20	14	5	3
	PrecMax	201	8	10	10	22	38	36	61	70	42	36	15	15
	PrecMin	70	0	0	0	0	0	0	6	1	6	2	0	0
	PrecStd	31	2	3	3	5	8	8	15	16	10	8	4	3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-13.6	-13.6	-12.3	-3.4	1.0	14.9	19.6	16.7	9.6	2.3	-4.5	-8.2
		MCWB	-13.9	-13.9	-12.7	-3.9	0.4	10.9	13.5	13.4	8.3	1.8	-5.1	-8.5
	2%	DB	-19.4	-19.1	-14.8	-5.8	0.3	11.2	16.5	13.2	8.0	0.5	-7.0	-11.2
		MCWB	-19.7	-19.4	-15.0	-6.1	0.0	8.7	12.3	10.4	6.9	0.4	-7.3	-11.4
	5%	DB	-23.3	-23.0	-17.3	-9.1	-0.5	9.0	14.9	11.0	6.5	-0.5	-9.1	-17.0
		MCWB	-23.5	-23.2	-17.6	-9.5	-0.7	7.1	11.2	8.8	5.8	-0.7	-9.4	-17.3
	10%	DB	-26.5	-26.2	-20.9	-11.4	-1.6	7.0	13.3	9.2	4.7	-1.9	-12.2	-21.6
		MCWB	-26.7	-26.5	-21.2	-11.7	-1.9	5.6	10.2	7.5	4.0	-2.1	-12.5	-21.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-11.0	-13.2	-12.7	-3.7	0.7	11.3	14.6	13.8	8.7	1.9	-4.6	-7.2
		MCDB	-10.3	-13.0	-12.4	-3.4	0.8	14.4	18.8	16.4	9.4	2.1	-4.3	-7.2
	2%	WB	-18.1	-16.4	-15.1	-5.9	0.1	8.8	12.8	10.9	7.1	0.4	-7.1	-10.9
		MCDB	-17.9	-16.2	-14.9	-5.5	0.4	11.0	16.1	12.5	7.8	0.5	-6.8	-10.6
	5%	WB	-21.6	-20.0	-16.9	-9.2	-0.7	7.1	11.5	9.0	5.8	-0.6	-9.1	-15.6
		MCDB	-21.5	-19.8	-16.6	-8.9	-0.4	8.9	14.5	10.8	6.7	-0.5	-8.8	-15.3
	10%	WB	-24.0	-23.0	-20.6	-11.4	-1.9	5.6	10.3	7.6	4.0	-2.0	-11.9	-20.6
		MCDB	-23.9	-22.6	-20.4	-11.0	-1.6	6.9	13.0	9.1	4.6	-1.8	-11.5	-20.3
Mean Daily Temperature Range	5% DB	MDBR	5.8	5.8	6.4	7.5	6.0	4.1	5.7	4.6	3.1	4.9	5.4	5.5
		MCDBR	11.6	9.6	9.3	8.1	4.5	7.4	8.3	7.7	4.7	3.5	6.5	8.7
		MCWBR	10.1	8.3	8.4	8.0	4.6	5.7	5.3	5.5	3.9	3.5	6.4	8.0
	5% WB	MCDBR	11.8	8.8	8.6	7.9	4.6	7.0	7.8	7.0	4.7	3.6	6.1	7.7
		MCWBR	11.5	8.8	8.4	7.8	4.7	5.6	5.7	5.3	4.1	3.5	6.1	7.7
Clear-Sky Solar Irradiance	taub	0.153	0.210	0.243	0.312	0.332	0.337	0.379	0.339	0.312	0.235	0.159	N/A	
	taud	1.889	2.062	2.224	2.051	2.081	2.300	2.293	2.454	2.406	2.136	1.896	N/A	
	Ebn at Noon	98	591	807	818	845	859	800	802	720	531	70	0	
	Edh at Noon	6	44	72	118	130	108	106	81	64	40	5	0	
All-Sky Solar Radiation	RadAvg	0.02	0.41	1.93	4.20	6.17	6.35	5.40	3.54	1.69	0.53	0.07	0.00	
	RadStd	0.00	0.04	0.10	0.20	0.48	0.47	0.40	0.29	0.16	0.08	0.01	0.00	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.60	+0.97	N/A	N/A	N/A	N/A	-233	-229	N/A	N/A

Nomenclature: See separate page